

中国认可
国际互认
检测
TESTING
CNAS L0116



报告查询
No.2113346615Y

TEST REPORT

NAME OF SAMPLE Dry Type Transformer

MODEL SCB14-2500/10-NX2

CUSTOMER Sichuan Zhongxin General Electric Power Co., Ltd.

TEST CATEGORY Type Test

NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)

(ZHEJIANG FANGYUAN ELECTRICAL EQUIPMENT TESTING CO., LTD.)

声 明

一、本实验室保证检测的公正性、独立性和诚实性，对报告的内容负责，报告中由委托方提供的信息的真实性由委托方负责。

二、本实验室出具的 CA 认证报告可通过扫描报告封面二维码或登录网址：<http://www.fydqjc.ltd:51036/#/search/pdfVerify> 上传完整版报告以查询真伪；纸质版报告未盖本实验室红色检验检测专用章、骑缝章无效；纸质版报告复印件未重新加盖本实验室红色检验检测专用章、骑缝章无效。

三、本报告无编制、审核、批准人签字无效；本报告涂改无效。

四、本实验室接受的送检样品，其代表性和真实性由委托方负责。本实验室对委托方提供的样品及相关技术资料保密。

五、本实验室不负责抽样时，本报告的检测数据和结果只对收到的样品负责。委托方若对本报告有异议，应及时向本实验室提出。政府行政管理部门下达的指令性任务，被检方对抽检结果有异议时，应按政府行政管理部门文件规定及国家相关法律、法规规定进行。

六、本报告中包含与规范或标准的符合性声明时，除特别约定、规范或标准有明确规定外，本实验室根据 IEC 导则第 115 号（IEC Guide 115:2023）4.3.3 条和 4.3.4 条考虑测量不确定度并做出符合性判定。

七、本报告各页均为报告不可分割之部分，未完整使用本报告全文由此造成的任何不良后果，本实验室不负相应的法律责任。

DECLARATION

1. Our laboratory guarantees impartiality, independence and honesty of inspection, and is responsible for the content of report. The customer is responsible for the information they provide.
2. The CA certification test report can be checked authenticity by scanning the QR code which is on test report cover or entering the website: <http://www.fydqjc.ltd:51036/#/search/pdfVerify> to upload the whole test report. The paper test report is invalid without the red special inspection stamp and paging seal of our laboratory. The paper copy of test report is invalid without the red special inspection stamp and paging seal of our laboratory.
3. The test report is invalid without signatures of the compiler, reviewer and authorized personnel. The test report is invalid if altered.
4. The customer is responsible for the representation and authenticity of the sample(s) they provide. Our laboratory keeps confidential of the sample(s) and related technical data provided by the customer.
5. The test results shown in this report is only applicable for the sample(s) received when our laboratory has not been responsible for the sampling stage. If there is any dissent of the report, the entrusting party shall notify our laboratory timely. For the mandatory inspection given by governmental administration departments, any dissent about the sample being tested or test results on the report should be dealt with in accordance with national regulations.
6. When a statement of conformity to a specification or standard is provided in the test report, the statement is made with measurement uncertainty accounted according to clause 4.3.3 and clause 4.3.4 of IEC GUIDE 115:2023, unless otherwise specified in special agreements, standards or specifications.
7. All the pages of the report are integral parts of the report. Our laboratory will not be responsible for any undesirable consequences caused by using separate page(s) of the report.

浙江方圆电气设备检测有限公司

地址：嘉兴市广穹路 400 号

邮编：314001 网址：www.fydqjc.cn

联系方式：

低压元件部：

0573-82077822、82077990（强制性认证检测、自愿性认证检测）

0573-82077811、82077511（委托检测、国际认证检测）

E-mail: fangyuantest_dy@163.com

低压成套部：

0573-82099578（强制性认证检测、自愿性认证检测）

0573-82077898（委托检测、国际认证检测）

E-mail: fangyuantest_ct@163.com

高压电器部：0573-82077919、82077099

新能源电器部：0573-82077355

智能电器部：0573-82077855

电磁兼容部：0573-82077600

防爆电器部：0573-82077233

避雷器与绝缘子部：0573-82079633

环境检测部：0573-82077277

计量中心：0573-82077033

E-mail: fangyuantest_hv@163.com

E-mail: fangyuantest_xny@163.com

E-mail: fangyuantest_zn@163.com

E-mail: fangyuantest_emc@163.com

E-mail: fangyuantest_ex@163.com

E-mail: fangyuantest_blq@163.com

E-mail: fangyuantest_hjjc@163.com

E-mail: fangyuantest_mc@163.com

NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)

TEST REPORT

Product	Dry Type Transformer	Test category	Type test
Model	SCB14-2500/10-NX2	Serial No.	202105151
Client	Sichuan Zhongxin General Electric Power Co., Ltd.	Manufacturer	Sichuan Zhongxin General Electric Power Co., Ltd.
Client 's address	(Industrial Zone)No.998, Xinghua 5 Road, Xinjin District, Chengdu City	Manufacturer's address	(Industrial Zone)No.998, Xinghua 5 Road, Xinjin District, Chengdu City
Sample(s) deliverer	Sichuan Zhongxin General Electric Power Co., Ltd.	Date of manufacture	2021-05
Receiving number of sample(s)	1 set	Receiving date of sample(s)	2021-08-04
Test requirements decision criteria	GB/T 1094.1-2013 Power transformers-Part 1: General GB/T 1094.3-2017 Power transformers-Part 3: Insulation levels, dielectric tests and external clearances in air GB/T 1094.5-2008 Power transformers-Part 5: Ability to withstand short circuit GB/T 1094.10-2003 Power transformers-Part 10: Determination of sound levels GB/T 1094.11-2007 Power transformers-Part 11: Dry-type transformers GB/T 10228-2015 Specification and technical requirements for dry-type power transformers GB/T 35710-2017 Rated power evaluation guide for 35 kV and below power transformers GB 20052-2020 Minimum allowable values of energy efficiency and the energy efficiency grades for power transformers IEC 60076-1:2011 Power transformers-Part 1: General IEC 60076-3:2013 Power transformers-Part 3: Insulation levels, dielectric tests and external clearances in air +AMD1: 2018 IEC 60076-5: 2006 Power transformers-Part 5: Ability to withstand short circuit IEC 60076-10:2001 Power transformers-Part 10: Determination of sound levels IEC 60076-11:2004 Power transformers-Part 11: Dry-type transformers Power of attorney requirements		
Test items	Routine test, type test, special test, commission test (Detailed test items are reported at test items and summary of results)		
Description and condition of sample(s)	The sample is sent by the customer, the appearance is perfect, and it is suitable for testing.		
Test date	2021-08-05 ~ 2021-08-13	Test location	No. 400 Guangqiong Road, Jiaxing City
Test summary	The entrusted sample have been tested according to GB/T 1094.1-2013, GB/T 1094.3-2017, GB/T 1094.5-2008, GB/T 1094.10-2003, GB/T 1094.11-2007, GB/T 10228-2015, GB/T 35710-2017, GB 20052-2020, IEC 60076-1: 2011, IEC 60076-3: 2013+AMD1: 2018, IEC 60076-5: 2006, IEC 60076-10:2001, IEC 60076-11:2004 and power of attorney requirements. The inspection results of the inspected items all meet the requirements of the standard (decision criteria). Test seal Date of approval: 2025-07-14		
Remarks	This report is a translation of report 2113346615. The GB/T 1094.10-2003, GB/T 1094.11-2007, GB/T 10228-2015 and GB 20052-2020 standards in the original report were obsoleted at the time of this report (2025-07-14).		

Approved by:

Verified by:

Complied by:

TEST REPORT**NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)****1, Sample parameters**

Rate power:	2500kVA
Rate voltage:	10kV/0.4kV
Rate current:	144.3A/3608.5A
Rate frequency:	50Hz
Phase number:	3
Tapping range:	(10±2×2.5%) kV /0.4kV
Connection symbol:	Dyn11
Cooling method:	AN/AF
Thermal class of insulation:	H
Insulation level:	h.v. line terminal LI /AC 75/35 kV
	l.v. line terminal and neutral point terminal LI/AC 3kV

2, Test requirements

GB/T 1094.1-2013	Power transformers-Part 1: General
GB/T 1094.3-2017	Power transformers-Part 3: Insulation levels, dielectric tests and external clearances in air
GB/T 1094.5-2008	Power transformers-Part 5: Ability to withstand short circuit
GB/T 1094.10-2003	Power transformers-Part 10: Determination of sound levels
GB/T 1094.11-2007	Power transformers-Part 11: Dry-type transformers
GB/T 10228-2015	Specification and technical requirements for dry-type power transformers
GB/T 35710-2017	Rated power evaluation guide for 35 kV and below power transformers
GB 20052-2020	Minimum allowable values of energy efficiency and the energy efficiency grades for power transformers
IEC 60076-1: 2011	Power transformers-Part 1: General
IEC 60076-3: 2013 +AMD1: 2018	Power transformers-Part 3: Insulation levels, dielectric tests and external clearances in air
IEC 60076-5: 2006	Power transformers-Part 5: Ability to withstand short circuit
IEC 60076-10: 2001	Power transformers-Part 10: Determination of sound levels
IEC 60076-11: 2004	Power transformers-Part 11: Dry-type transformers
Power of attorney requirements	

3, The sample specification


The dry type transformer is for indoors use, the structure of the coil is a non-circular concentric coil.

TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)

Photo of nameplate and sample(s) under test

Photo of nameplate



Front photo of sample



Side photo of sample



TEST REPORT		NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)				
Test items and summary of results						
Series number	Test category	Test items	Required value	Measured value		Conclusion
			Standard (Entrusted requirements)	Before short-circuit test	After short-circuit test	
01	Routine test	Measurement of voltage ratio and check of phase displacement	Voltage ratio tolerance of principal tapping: obtaining the lower of the following values between $\pm 0.5\%$ of declared ratio and $\pm 1/10$ of the actual percentage impedance Other tapping: Turn ratio $\pm 0.5\%$ of design value Connection symbol: Dyn11	-0.04% ~-0.02%	-0.04% ~-0.02%	Pass
02		Measurement of d.c. insulation resistance each winding to earth and between windings.	Provide measured value of insulation resistance (M Ω): HV--LV and earth LV--HV and earth HV and LV--earth	$>99.9 \times 10^3$ $>99.9 \times 10^3$ $>99.9 \times 10^3$	$>99.9 \times 10^3$ $>99.9 \times 10^3$ $>99.9 \times 10^3$	Measured
03		Measurement of winding resistance	Unbalance rate of winding resistance (max): Line resistance $\leq 2\%$	HV(line): 1.44% LV(line): 1.30%	HV(line): 1.44% LV(line): 1.33%	Pass
04		Measurement of no-load loss and current	No load current (%): $\leq 0.700^{+30\%}$ No-load loss (kW): ≤ 2.450	0.195 2.315	0.195 2.321	Pass
05		Measurement of short-circuit impedance and load loss	Reference temperature ($^{\circ}\text{C}$): 145 Short-circuit impedance (%): $6.0^{\pm 10\%}$ Load loss (kW): ≤ 16.605 Total loss (kW): ≤ 19.055	145 6.05 16.317 18.632	145 6.07 16.338 18.659	Pass
06		Applied voltage test	HV(kV): 35 Duration: 60s LV(kV): 3 Duration: 60s	35.4kV 60s 3.06kV 60s	35.5kV 60s 3.02kV 60s	Pass
07		Induced voltage withstand test	Applied voltage on LV side(kV): $2U_r$ Frequency(Hz): >50 Duration(s): $120 \times (\text{rate frequency}/\text{test frequency})$	0.805 150 40	0.807 150 40	Pass

TEST REPORT		NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)				
Test items and summary of results						
Series number	Test category	Test items	Required value	Measured value		Conclusion
			Standard (Entrusted requirements)	Before short-circuit test	After short-circuit test	
08	Routine test	Partial discharge measurement	Applied voltage(kV): 1.3U _r Duration(s): 180 Discharge magnitude (pC): ≤5	0.523 180 A:4.0~4.5 B:3.6~4.1 C:3.6~4.4	0.526 180 A:3.8~4.3 B:3.8~4.1 C:3.7~4.5	Pass
09	Type test	Measurement of no-load loss and current at 90% and 110% of rated voltage	No load current (%):measured 90%U _r No-load loss (kW): measured	0.140 1.452		Measured
No load current (%):measured 110%U _r No-load loss (kW): measured			0.264 3.062			
10		Temperature rise test	HV winding temperature rise limit (K): ≤125 LV winding temperature rise limit (K): ≤125	116.6 119.2		Pass
11		Power measurement of fan and oil pump motor	Providing the measured power value of fan motor (W)	230.2		Measured
12		Lightning impulse test	10kV winding: LI(kV): 75 ^{±3%}	LI(kV): 74.52~77.13		Pass
13		Determination of sound levels	Sound pressure level $\overline{L_{pA}}$ (dB): Sound power level L_{WA} dB(A): ≤72	54.8 70.1		Pass

TEST REPORT		NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)			
Test items and summary of results					
Series number	Test category	Test items	Required value	Measured value	Conclusion
			Standard (Entrusted requirements)		
14	Special test	Short-circuit withstand test	Test times of each phase: 3 times Duration(ms): 500 ^{±10%} Test current and voltage waveform have no abnormality After the short-circuit test, the coil, lead and support structure have no obvious displacement and deformation, and no discharge marks are found on the surface of the device. The reactance variation in phase before and after the test is less than 7.5% Routine retests shall be passed after short-circuit test	3 times per phase 519~541 Test current and voltage waveform have no abnormality After the short-circuit test, the coil, lead and support structure have no obvious displacement and deformation, and no discharge marks are found on the surface of the device. The maximum reactance variation in phase is 5.20% Routine retests after short-circuit test is passed	Pass
15	Commission test	Measurement of the harmonics of the no-load current	Providing harmonics of the no-load current of each phase	See 4.15	Measured
16		Power evaluation test on transformer	Rated power (kVA): 2500	2500	Pass
Note: /					

TEST REPORT	NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)
--------------------	---

4, Test items and results**4.1 Measurement of voltage ratio and check of phase displacement (routine test)**

Test date: 2021-08-05

HV winding		LV winding		Transformer ratio by calculation	Measured voltage ratio deviation (%)			Connection symbol
Tapping position	Voltage (kV)	Tapping position	Voltage (kV)		AB/ab	BC/bc	CA/ca	
2-3	10.500	/	0.400	26.250	-0.02	-0.03	-0.02	Dyn11
3-4	10.250			25.625	-0.03	-0.04	-0.02	
4-5	10.000			25.000	-0.04	-0.03	-0.03	
5-6	9.750			24.375	-0.03	-0.04	-0.02	
6-7	9.500			23.750	-0.04	-0.02	-0.02	

Test conclusion: Pass.**4.2 Measurement of d.c insulation resistance between each winding to earth and between winding (routine test)**

Test date: 2021-08-05

Ambient temperature: 27.3°C Relative humidity: 63.4%

Measured parts	Measured insulation resistance (MΩ)
HV--LV and earth	$> 99.9 \times 10^3$
LV--HV and earth	$> 99.9 \times 10^3$
HV and LV--earth	$> 99.9 \times 10^3$

Test conclusion: Measured.**4.3 Measurement of winding resistance (routine test)**

Test date: 2021-08-05

Ambient temperature: 27.3°C Relative humidity: 63.4%

Winding	Tapping position	Measured resistance (Ω)			Resistance unbalance rate (%)
		A~B	B~C	C~A	
HV	2-3	0.1610	0.1592	0.1609	1.12
	3-4	0.1574	0.1555	0.1572	1.21
	4-5	0.1539	0.1519	0.1538	1.31
	5-6	0.1496	0.1477	0.1495	1.28
	6-7	0.1464	0.1443	0.1462	1.44
LV	/	a~b	b~c	c~a	/
		0.2993×10^{-3}	0.2998×10^{-3}	0.3032×10^{-3}	1.30

Test conclusion: Pass.

TEST REPORT		NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)						
4.4 Measurement of no-load loss and current (routine test)					Test date: 2021-08-05			
The test circuit is shown in test schematic diagram 1								
Voltage multiple	Applied voltage (V)		No-load current		No-load loss (kW)			
	r.m.s. value	Average value	(A)	(%)	Measured value	Corrected value		
100%U _r	400.8	400.6	7.02	0.195	2.316	2.315		
Test conclusion: Pass.								
4.5 Measurement of short-circuit impedance and load loss (routine test)					Test date: 2021-08-05			
The test circuit is shown in test schematic diagram 2					Ambient temperature: 27.3°C			
Winding	Tapping position	Applied current		Average voltage (V)	HV short-circuit impedance (per phase)		Load loss (kW)	Total loss (kW)
		I(A)	I/I _r (%)		(%)	(Ω)	Corrected value	Corrected value
					t=145°C I=I _r	t=145°C I=I _r	t=145°C I=I _r	t=145°C I=I _r
HV-LV	2-3	72.06	52.4	335.2	6.11	2.69	16.180	18.495
	4-5	75.54	52.3	315.4	60.5	2.42	16.317	18.632
	6-7	83.58	55.0	312.1	5.99	2.16	16.448	18.763
Test conclusion: Pass.								
4.6 Applied voltage test (routine test)					Test date: 2021-08-06			
The test circuit is shown in test schematic diagram 3.								
Ambient temperature: 26.8°C Relative humidity: 67.1% Atmospheric pressure: 100.7kPa								
Testing position		Test voltage (kV)		Duration (s)		Test conclusion		
HV-- LV and earth		35.4		60		Pass		
LV-- HV and earth		3.06		60				
4.7 Induced voltage withstand test (routine test)					Test date: 2021-08-06			
The test circuit is shown in test schematic diagram 4.								
Ambient temperature: 26.8°C Relative humidity: 67.1% Atmospheric pressure: 100.7kPa								
Tapping position	Applied voltage (kV)		Frequency (Hz)	Duration (s)	Test conclusion			
	LV side							
4-5	0.805		150	40	Pass			
4.8 Partial discharge measurement (routine test)					Test date: 2021-08-06			
Ambient temperature: 26.8°C								
Frequency (Hz)	Applied voltage		Duration	Partial discharge magnitude(pC)				
	(kV)	Multiple		A	B	C		
150	0.724	1.8U _r	30s	/	/	/		
	0.523	1.3U _r	180s	4.0~4.5	3.6~4.1	3.6~4.4		
Test conclusion: Pass.								

TEST REPORT**NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)****4.9 Measurement of no-load loss and current at 90% and 110% of rated voltage (type test)**

Test date: 2021-08-05

Voltage multiple	Applied voltage (V)		No-load current		No-load loss (kW)	
	r.m.s. value	Average value	(A)	(%)	Measured value	Corrected value
90%U _r	360.5	360.3	5.04	0.140	1.453	1.452
110%U _r	440.6	440.3	9.52	0.264	3.064	3.062

Test conclusion: Measured.**4.10 Temperature rise test (type test)**

Test date: 2021-08-09~08-10

The test circuit is shown in test schematic diagram 5.

Testing method: simulation load method. Tapping position: 4-5.

Temperature rise test under no-load loss: the specified voltage should be applied is 400V and the actual voltage applied is 400V. Test time from 08:15 to 17:30 (2021-08-09).

Temperature rise test under load loss: the specified current should be applied is 144.3A and the actual current applied is 144.4A. Test time from 18:00 to 08:50 (2021-08-09~10).

Temperature-rise data under no-load loss

Winding	Resistance measurement (Ω)		Ambient temperature ($^{\circ}\text{C}$)		Winding temperature rise (K)
	Hot resistance	Cold resistance	Measured hot resistance	Measured cold resistance	
HV	0.1569	0.1519	26.4	27.3	9.5
LV	0.3190×10^{-3}	0.2998×10^{-3}			17.7

Temperature-rise data under load loss

Winding	Resistance measurement (Ω)		Ambient temperature ($^{\circ}\text{C}$)		Winding temperature rise (K)
	Hot resistance	Cold resistance	Measured hot resistance	Measured cold resistance	
HV	0.2176	0.1519	28.1	27.3	112.5
LV	0.4270×10^{-3}	0.2998×10^{-3}			110.4

Temperature rise calculation result


Winding temperature rise (K)	HV (K)	116.6
	LV (K)	119.2

Test conclusion: Pass.


TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)

HV winding thermal resistance curve
(Temperature-rise test under no-load loss)




LV winding thermal resistance curve
(Temperature-rise test under no-load loss)




TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)

HV winding thermal resistance curve
(Temperature-rise test under load loss)



LV winding thermal resistance curve
(Temperature-rise test under load loss)



TEST REPORT		NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)	
4.11 Power measurement of fan and oil pump motor (type test)			Test date: 2021-08-06
	Test voltage (V)	Test current (A)	Test power (W)
☒ Fan motor	220	1.09	230.2
☐ Oil pump motor	/	/	/
Test conclusion: Measured.			
4.12 Lightning impulse test (type test)			Test date: 2021-08-13
The test circuit is shown in the test schematic 6.			
Ambient temperature: 28.2°C Relative humidity: 64.6% Atmospheric pressure: 100.7kPa			
Test items and voltage			
Withstand terminals	Rated withstand voltage (kV)		Tapping position
	Lightning full wave		
A, B, C	75 ^{±3%}		4-5
Test procedure: Terminal One negative reduced level full wave impulse; Three negative full level full wave impulses. Test records: T1: wave front time; T2: time to half of peak value; Upk: peak voltage. For the waveforms, please check the lightning impulse oscilloscope. Voltage ranges of oscillograms are as below:			
LI(kV)			
74.52~77.13			
Test conclusion: Pass.			

TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)

Lightning impulse oscilloscope





Tested terminal: A

Test polarity: negative

Tapping position: 4-5

Channel 1: voltage wave

Channel 2: current wave



TEST REPORT**NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)****Lightning impulse oscilloscope**





Tested terminal: B

Test polarity: negative

Tapping position: 4-5

Channel 1: voltage wave

Channel 2: current wave



TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)

Lightning impulse oscilloscope





Tested terminal: C

Test polarity: negative

Tapping position: 4-5

Channel 1: voltage wave

Channel 2: current wave



TEST REPORT**NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)****4.13 Determination of sound level (type test)**

Test date: 2021-08-06

The test circuit is shown in test schematic diagram 7.

4.13.1 Rough estimation of the load current sound power level

Calculation formula: $L_{WA,IN} \approx 39 + 18 \lg \frac{S_r}{S_p} \approx 46.2 \text{ dB(A)}$

$L_{WA,IN}$: A-weighted sound power level of transformer at rated frequency, rated current and short-circuit impedance, unit dB(A)

In the formula: S_r : rated power, 2.50MVA;

S_p : reference power, 1MVA.

Because $L_{WA,IN}$ is less 8 dB(A) than the guaranteed sound power level 72dB(A), according to standard requirement, it need not to measure load current sound power level.

4.13.2 Measurement of sound pressure level and calculation of sound power level

The transformer is rated excitation, the prescribed contour shall be spaced 1.0m away from the principal radiating surface, the distance between measured points is 0.85m, the number of measured points is 15, the height of measured point is 0.80m.

Measuring environmental conditions

Ambient temperature: 26.8°C

The total area of the surface of the test room $S_v(\text{m}^2)$	The average acoustic absorption coefficient α	Sound absorption A (m^2)	Distance from the principal radiating surface (m)	Measuring surface area $S(\text{m}^2)$	Environmental correction K (dB)
3358.6	0.15	503.8	1.0	33.3	1.02

Measurement results

dB(A)

Status of cooling device	Background noise average value		The uncorrected average A-weighted sound pressure level $\overline{L}_{PAO}$	A-weighted sound pressure level $\overline{L}_{pA} = 10 \lg(10^{0.1\overline{L}_{PAO}} - 10^{0.1\overline{L}_{bgA}}) - K$	A weighted sound power level $L_{WA} = \overline{L}_{pA} + 10 \lg \frac{S}{S_0}$
	Before the test	After the test			
AN	35.3	35.2	55.9	54.8	70.1

Note: $\overline{L}_{PAO}$: the uncorrected average A-weighted sound pressure level $\overline{L}_{PAO} = 10 \lg(\frac{1}{N} \sum_{i=1}^N 10^{0.1L_{pAi}})$

$\overline{L}_{bgA}$: the lower of background sound A-weighted sound pressure level measured at each measuring point before and after the test $\overline{L}_{bgA} = 10 \lg(\frac{1}{M} \sum_{i=1}^M 10^{0.1L_{bgAi}})$

M: the total number of microphone position

Test conclusion: Pass

TEST REPORT			NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)					
4.14 Short-circuit withstand test (special test)							Test date: 2021-08-12	
4.14.1 Current calculation of short-circuit test (reference temperature 145°C)							Ambient temperature: 28.7°C	
Tapping position		Phase asymmetric short circuit current First peak(A)		Phase symmetrical short-circuit current Root mean square(A)		Peak coefficient (K√2)		
2-3		132.9 ^{±5%}		54.6 ^{±10%}		2.44		
4-5		133.8 ^{±5%}		55.1 ^{±10%}		2.43		
6-7		134.6 ^{±5%}		55.6 ^{±10%}		2.42		
4.14.2 Current injection of short-circuit test								
Three-phase power supply should be used for total of 9 tests, current and voltage waveforms should be normal.								
The first peak value of the asymmetric short-circuit current and the root mean square of the symmetric short-circuit current are the measured value ratio and the calculated current value.								
Tapping position	Times	Applied voltage terminal	Measurement of current					
			Phase asymmetric short circuit current First peak		Phase symmetrical short-circuit current Root mean square		Duration (ms)	Oscillogram No
			Measured value (kA)	(%)	Measured value (kA)	(%)		
2-3	1st	a	132.3	-0.451	54.1	-0.916	525	S2146615001
		b	113.0	-15.0	54.3	-0.549		
		c	79.9	-39.9	54.3	-0.549		
	2nd	a	133.2	0.226	54.7	0.183	523	S2146615002
		b	109.5	-17.6	54.6	0.000		
		c	89.6	-32.6	54.7	0.183		
	3rd	a	133.6	0.527	54.8	0.366	528	S2146615003
		b	113.4	-14.7	54.7	0.183		
		c	81.4	-38.8	54.7	0.183		
	Times		Measurement of reactance					
			Phase reactance (Ω)			Phase reactance deviation (%)		
			X _A	X _B	X _C	X _A	X _B	X _C
	Before the test		8.17	7.98	7.81	/	/	/
	1st		8.22	7.99	7.83	0.62	0.20	0.25
	2nd		8.24	8.02	7.86	0.88	0.48	0.71
	3rd		8.28	8.04	7.87	1.34	0.75	0.85

TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)

Tapping position	Times	Applied voltage terminal	Current measurement					
			Phase asymmetric short circuit current First peak		Phase symmetrical short-circuit current Root mean square		Duration (ms)	Oscillogram No
			Measured value (kA)	(%)	Measured value (kA)	(%)		
6-7	1st	a	110.5	-17.9	56.6	1.80	531	S2146615007
		b	99.9	-25.8	56.4	1.44		
		c	134.3	-0.223	56.4	1.44		
	2nd	a	108.6	-19.3	56.3	1.26	534	S2146615008
		b	105.3	-21.8	56.8	2.16		
		c	134.6	0.000	56.7	1.98		
	3rd	a	112.4	-16.5	56.7	1.98	541	S2146615009
		b	99.7	-25.9	56.8	2.16		
		c	134.3	-0.223	56.6	1.80		
	Times		Measurement of reactance					
			Phase reactance(Ω)			Phase reactance deviation (%)		
			X _A	X _B	X _C	X _A	X _B	X _C
	Before the test		6.36	6.25	6.19	/	/	/
	1st		6.49	6.42	6.41	2.03	2.65	3.64
	2nd		6.50	6.44	6.44	2.30	2.93	4.11
3rd		6.51	6.47	6.51	2.37	3.44	5.20	

The maximum phase reactance deviation is: 5.20%


4.14.3 The out-of-tank inspection

After the short-circuit test, the out-of-tank inspection does not reveal any defects such as displacements, deformation of windings, connections or supporting structures and no traces of discharge are found on the device.

For the pictures before and after the test, see Page 27 to Page 28.


TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)




TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)



TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)



TEST REPORT		NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)						
4.14.4 Routine retest								
4.14.4.1 Measurement of voltage ratio and check of phase displacement (routine test)								Test date: 2021-08-13
HV winding		LV winding		Transformer ratio by calculation	Measured voltage ratio deviation (%)			Connection symbol
Tapping position	Voltage (kV)	Tapping position	Voltage (kV)		AB/ab	BC/bc	CA/ca	
2-3	10.500	/	0.400	26.250	-0.02	-0.03	-0.03	Dyn11
3-4	10.250			25.625	-0.03	-0.04	-0.02	
4-5	10.000			25.000	-0.04	-0.03	-0.03	
5-6	9.750			24.375	-0.03	-0.04	-0.03	
6-7	9.500			23.750	-0.04	-0.02	-0.02	
Test conclusion: Pass.								
4.14.4.2 Measurement of d.c. insulation resistance between each winding to earth and between winding (routine test)								Test date: 2021-08-13
					Ambient temperature: 28.2°C		Relative humidity: 64.6%	
Testing position				Measured insulation resistance (MΩ)				
HV--LV and earth				$>99.9 \times 10^3$				
LV--HV and earth				$>99.9 \times 10^3$				
HV and LV--earth				$>99.9 \times 10^3$				
Test conclusion: Measured.								
4.14.4.3 Measurement of winding resistance (routine test)								Test date: 2021-08-13
Ambient temperature: 28.2°C								
Winding	Tapping position	Measured resistance (Ω)			Resistance unbalance rate (%)			
		A~B	B~C	C~A				
HV	2-3	0.1616	0.1597	0.1616	1.18			
	3-4	0.1579	0.1560	0.1577	1.21			
	4-5	0.1544	0.1524	0.1544	1.30			
	5-6	0.1501	0.1482	0.1501	1.27			
	6-7	0.1469	0.1448	0.1467	1.44			
LV	/	a~b	b~c	c~a	/			
		0.3002×10^{-3}	0.3008×10^{-3}	0.3042×10^{-3}	1.33			
Test conclusion: Pass.								

4.14.4.9 Test conclusion: short circuit withstand test is pass.

TEST REPORT		NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)	
4.15 Measurement of the harmonics of the no-load current (commission test)			Test date: 2021-08-06
Number of no-load current harmonics	THD(%): 20.6	THD(%): 26.3	THD(%): 28.4
	Phase A (%)	Phase B (%)	Phase C (%)
1	100	100	100
2	2.6	3.0	2.7
3	9.7	10.6	12.4
4	1.8	1.9	1.6
5	16.8	22.4	23.6
6	0.0	0.0	0.0
7	5.6	9.5	8.4
8	0.0	0.0	0.3
9	0.6	0.7	0.4
10	0.0	0.0	0.0
11	1.8	2.6	2.0
12	0.2	0.1	0.0
13	1.8	2.5	2.2
14	0.0	0.0	0.0
15	0.0	0.0	0.0
16	0.0	0.4	0.0
17	0.0	0.3	0.2
18	0.0	0.0	0.0
19	0.0	0.0	0.0
Test conclusion: Measured.			

TEST REPORT**NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)****4.16 Power evaluation test on transformer (commission test)**

Test date: 2021-08-05

4.16.1 Measurement of winding resistance

Winding	Tapping position	Measured resistance (Ω)			Ambient temperature of resistance testing ($^{\circ}\text{C}$)	Ambient temperature of loss testing ($^{\circ}\text{C}$)
		R_{AB}	R_{BC}	R_{CA}		
HV	4-5	0.1539	0.1519	0.1538	27.3	27.3
LV	/	R_{ab}	R_{bc}	R_{ca}		
		0.2993×10^{-3}	0.2998×10^{-3}	0.3032×10^{-3}		

4.16.2 Measurement of short-circuit impedance and load loss under preset power

Tapping position 4-5

No.	Preset power (kVA)	Short-circuit impedance			Load loss impedance				
		Specified value (%)	Measured value (%)	Within the allowable range of error or not	Average voltage (V)	Average current (A)	Measured loss (kW)	Corrected current (A) $t=145^{\circ}\text{C}$	Corrected load loss (kW) $t=145^{\circ}\text{C}$
1	2500	$6.0^{+10\%}$	6.05	Yes	315.4	75.54	3.266	144.3	16.317

4.16.3 Measurement of transformer power

Test date: 2021-08-05/08-10

Ambient temperature: 27.3/26.8 $^{\circ}\text{C}$

Tapping position 4-5

The preset power of the short-circuit impedance within the allowable value range of the standard short-circuit impedance error in the actual measurement results (kVA): 2500

Preset power 1 (kVA)	Measured no-load loss (kW)	The temperature rise results content the requirements or not
2500	2.316	Yes

The measured power of the transformer conforms to the nominal rated power of the nameplate: 2500kVA.

Test conclusion: Pass.

TEST REPORT**NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)**

HV side before short-circuit withstand test :



LV side before short-circuit withstand test :



TEST REPORT**NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)**

HV side after short-circuit withstand test :




LV side after short-circuit withstand test :




TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)

Test schematic diagram 1 of no-load loss and no-load current measurement




Test schematic diagram 2 of short-circuit impedance and load loss measurement




TEST REPORT

NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)

Test schematic diagram 3 of applied voltage test





Test schematic diagram 4 of induced voltage test




TEST REPORT**NATIONAL CENTER OF QUALITY INSPECTION
FOR ELECTRICAL SAFETY (ZHEJIANG)**

Test schematic diagram 5 of temperature-rise test



TEST REPORT	NATIONAL CENTER OF QUALITY INSPECTION FOR ELECTRICAL SAFETY (ZHEJIANG)
--------------------	---

Test schematic diagram 6 of lightning impulse test



Test schematic diagram 7 of sound level test

