



中国认可
国际互认
检测
TESTING
CNAS L1020



实验室名称：苏州电器科学研究院股份有限公司
国家电器产品质量检验检测中心

Lab Name: Suzhou Electrical Apparatus Science Research Institute Co., Ltd.
China National Center for Quality Inspection and Test of Electrical
Apparatus Products

No 23M1237-S

型式试验报告 Type Test Report

委 托 单 位：四川众信通用电力有限公司

Client: Sichuan Zhongxin General Electric Power Co., Ltd.

产 品 名 称：油浸式电力变压器

Name of Product: Oil Immersed Transformer

产 品 型 号：SZ22-63000/110-NX1

Product Type:

检 验 类 别：型式试验

Test Category: Type test

本实验室对出具的检验（试验）结果负责，未经实验室书面同意，
不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall
not be reproduced except in full, written approval of the laboratory.

Suzhou Electrical Apparatus Science Research Institute Co., Ltd.

Test Report

No: 23M1237-S

Total 79 Page 01

Client	Sichuan Zhongxin General Electric Power Co.,Ltd.	Test category	Type test
Manufacturer	Sichuan Zhongxin General Electric Power Co.,Ltd.	Date of sample receiving	Sep. 01, 2023
Name of sample	Oil Immersed Transformer	Type of sample	SZ22-63000/110-NX1
Address of manufacturer	(Industrial Zone) No.998, Xinghua 5 Road, Xinjin District, Chengdu City	Original number or date of production	202308961
Date of test	From Sep. 03, 2023 to Sep. 12, 2023	Number of sample	1 set
Test items	Routine test Type test (including calculation of the winding hot-spot temperature-rise) Measurement of bushing capacitances and dielectric dissipation factor ($\tan\delta$) Measurement of frequency response Short-circuit withstand test Measurement of no-load excitation characteristics Long-duration no-load test Measurement of zero-sequence impedances on three-phase transformers Measurement of the harmonics of the no-load current Vacuum deflection test on liquid-immersed transformers Pressure deflection test on liquid-immersed transformers	Test standards	GB/T 1094.1—2013 GB/T 1094.2—2013 GB/T 1094.3—2017 GB/T 1094.5—2008 GB/T 1094.10—2022 GB/T 6451—2015 GB/T 7595—2017 JB/T 10088—2016 GB 20052—2020 Commission requirements
Test conclusion	The test results of routine test, type test (including calculation of the winding hot-spot temperature-rise), measurement of bushing capacitances and dielectric dissipation factor ($\tan\delta$), measurement of frequency response, short-circuit withstand test, measurement of no-load excitation characteristics, long-duration no-load test, measurement of zero-sequence impedances on three-phase transformers, measurement of the harmonics of the no-load current, vacuum deflection test on liquid-immersed transformers and pressure deflection test on liquid-immersed transformers of the oil immersed transformer (type: SZ22-63000/110-NX1) are in accordance with test standards and commission requirements. The sample has passed the above tests. Measured parameters of no-load loss and load loss of the sample meet the requirements of energy efficiency grade 1 of GB 20052—2020. Signing and issuing date: 2023-09-25 Note: the conclusion is valid only for the inspected and tested sample.		
Remarks	/		

Compiled by: 杨小伟 Proofread by: 王亚红 Checked by: 袁小勇 Approved by: 李华

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	№: 23M1237-S Total 79 Page 02
-------------	---	----------------------------------

1. Sample parameters

Rated power: 63000kVA

Rated voltage: 110/10.5kV

Rated current: 330.7/3464.2A

Rated frequency: 50Hz

Number of phases: 3

Tapping ranges: $\pm 8 \times 1.25\%$

Connection symbol: YNd11

Cooling method: ONAN

Thermal class of insulation: A

Insulation level: HV	Um/LI/LIC/AC	126/480/530/200kV
HVN	Um/LI/AC	72.5/325/140kV
LV	Um/LI/LIC/AC	12/75/85/35kV

2. Test standards

GB/T 1094.1—2013 *Power transformers—Part 1: General*

GB/T 1094.2—2013 *Power transformers—Part 2: Temperature rise for liquid-immersed transformers*

GB/T 1094.3—2017 *Power transformers—Part 3: Insulation levels, dielectric tests and external clearances in air*

GB/T 1094.5—2008 *Power transformers—Part 5: Ability to withstand short circuit*

GB/T 1094.10—2022 *Power transformers—Part 10: Determination of sound levels*

GB/T 6451—2015 *Specification and technical requirements for oil-immersed power transformers*

GB/T 7595—2017 *Quality of transformer oils in service*

JB/T 10088—2016 *Sound level for 6kV~1000kV power transformers*

GB 20052—2020 *Minimum allowable values of energy efficiency and the energy efficiency grades for power transformers*

Commission requirements

3. Sample description

The oil immersed transformer is for outdoor use. The structure of the coil is circular concentric type and external photos of the sample have been attached.

Test Report

Suzhou Electrical Apparatus Science Research Institute Co., Ltd.

No: 23M1237-S
Total 79 Page 03

Photos of the sample



油浸式电力变压器

组别	容量 (kVA)	电压 (kV)	型号	数量
1	1000	10	SZ22-1000/10-AX1	1
2	1000	10	SZ22-1000/10-AX1	1
3	1000	10	SZ22-1000/10-AX1	1
4	1000	10	SZ22-1000/10-AX1	1
5	1000	10	SZ22-1000/10-AX1	1
6	1000	10	SZ22-1000/10-AX1	1
7	1000	10	SZ22-1000/10-AX1	1
8	1000	10	SZ22-1000/10-AX1	1
9	1000	10	SZ22-1000/10-AX1	1
10	1000	10	SZ22-1000/10-AX1	1
11	1000	10	SZ22-1000/10-AX1	1
12	1000	10	SZ22-1000/10-AX1	1
13	1000	10	SZ22-1000/10-AX1	1
14	1000	10	SZ22-1000/10-AX1	1
15	1000	10	SZ22-1000/10-AX1	1
16	1000	10	SZ22-1000/10-AX1	1
17	1000	10	SZ22-1000/10-AX1	1

技术参数:

- 额定容量: 1000 kVA
- 额定电压: 10 kV
- 额定电流: 57.74 A
- 短路阻抗: 4.5%
- 空载损耗: 1.2 kW
- 负载损耗: 10.38 kW

四川众信通用电力有限公司

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 04	
Summary of test results					
No	Test items	Specified value	Measured value		Concl- usion
		Standards (commission requirements)	Before short-circuit test	After short-circuit test	
1	Measurement of d.c. insulation resistance between each winding to earth and between windings (routine test)	Providing value of insulation resistance Providing absorption ratio Providing polarity index	See 4.1	See 4.19.4.1	/
2	Check of core and frame insulation for liquid-immersed transformers with core or frame insulation (routine test)	Providing value of insulation resistance at 20℃(GΩ): ≥0.5	See 4.2	See 4.19.4.2	PASS
3	Measurement of dissipation factor (tanδ) of the insulation system capacitances (routine test)	Dielectric dissipation factor tanδ (20℃): measured	See 4.3	See 4.19.4.3	/
4	Determination of capacitances windings-to-earth and between windings (routine test)	Providing value of capacitance	See 4.4	See 4.19.4.4	/
5	Measurement of bushing capacitances and dielectric dissipation factor (tanδ) (commission test)	Providing value of capacitance Providing dielectric dissipation factor tanδ	See 4.5	See 4.19.4.5	/
7	Auxiliary wiring insulation test (AuxW) (routine test)	Wiring for auxiliary power and control circuit: 2kV 60s	2kV 60s	2kV 60s	PASS
8	Measurement of voltage ratio and check of phase displacement (routine test)	Voltage ratio tolerance of principal tapping: obtaining the lower of the following values between ±0.5% of declared ratio and ±1/10 of the actual percentage impedance Connection symbol: YNd11	See 4.7	See 4.19.4.7	PASS
8	Measurement of winding resistance (routine test)	Maximum resistance unbalance rate Phase resistance: ≤2% Line resistance: ≤1%	HV (phase): 0.51% LV (line):0.91%	HV (phase):0.44% LV (line): 0.93%	PASS

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.				№: 23M1237-S Total 79 Page 05			
No	Test items	Specified value		Measured value				Concl- usion	
		Standards (commission requirements)		Before short-circuit test		After short-circuit test			
9	Measurement of no-load loss and current (routine test)	I_0 (%): 0.42 P_0 (kW): 25.000	+30% +0%	0.12 22.2504		0.12 22.4023		PASS	
10	Measurement of no-load loss and current at 90% and 110% of rated voltage (type test)	I_0 (%): P_0 (kW):	measured measured	90% 0.10 19.0375	110% 0.24 34.4140	90% 0.10 19.0517	110% 0.25 34.9875	/	
11	Measurement of short-circuit impedance and load loss (routine test)	t: 75℃ Z (%): 10.5 P_k (kW): 209.000 P_{total} (kW): 234.000	 ±7.5% +0% +0%	10.26 200.6415 222.8919		10.28 201.0593 223.4616		PASS	
12	Tests on on-load tap-changers (routine test)	According to clause 11.7 of GB/T1094.1-2013		Meet the requirements		Meet the requirements		PASS	
13	Lightning impulse test (LI, LIC, LIN) (routine test, type test)	HV: Full wave (kV): 480 Chopped wave (kV): 530 Neutral point (kV): 325		/ /		479.29~483.65 530.75~536.27 325.10~328.20		PASS	
		LV: Full wave (kV): 75 Chopped wave (kV): 85				75.28~77.06 85.72~86.29			
14	Applied voltage test (AV) (routine test)	HV and neutral point: 140kV LV: 35kV	60s 60s	140kV 35kV	60s 60s	140kV 35kV	60s 60s	PASS	
15	Line terminal AC withstand test (LTAC) (routine test)	Phase-to-earth test						PASS	
		Applied voltage (kV): 21	ac: 21	ab: 21	bc: 21	ac: 21	ab: 21		bc: 21
		Induced voltage (kV): 200	A: 200	B: 200	C: 200	A: 200	B: 200		C: 200
		Duration (s): 120 (f_n/f) Frequency (Hz): >50	30 200		30 200				

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 06	
No	Test items	Specified value	Measured value		Conclusion
		Standards (commission requirements)	Before short-circuit test	After short-circuit test	
16	Induced voltage withstand test and induced voltage test with partial discharge measurement (IVW, IVPD) (routine test)	Phase-to-earth voltage			PASS
		0.4U _r /√3 (kV)	25.4	25.4	
		Discharge magnitude ≤50pC	A: <15; B: <15; C: <10	A: <15; B: <20; C: <15	
		1.2U _r /√3 (kV)	76.2	76.2	
		Duration (min): 1	1	1	
		Discharge magnitude ≤100pC	A: <35; B: <30; C: <30	A: <30; B: <30; C: <35	
		1.58U _r /√3 (kV)	100.3	100.3	
		Duration (min): 5	5	5	
		Discharge magnitude ≤100pC	A: <70; B: <80; C: <75	A: <80; B: <80; C: <75	
		2.0U _r /√3 (kV)	127.0	127.0	
		Duration (min): 0.5	0.5	0.5	
		1.58U _r /√3 (kV)	100.3	100.3	
		Duration (min): 60	60	60	
		Discharge magnitude ≤100pC	A: <70; B: <80; C: <95	A: <80; B: <90; C: <95	
		1.2U _r /√3 (kV)	76.2	76.2	
		Duration (min): 1	1	1	
		Discharge magnitude ≤100pC	A: <30; B: <35; C: <50	A: <35; B: <35; C: <45	
		0.4U _r /√3 (kV)	25.4	25.4	
		Discharge magnitude ≤50pC	A: <15; B: <20; C: <20	A: <15; B: <25; C: <20	
		Frequency (Hz): >50	200		

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 07	
No	Test items	Specified value	Measured value		Conclusion
		Standards (commission requirements)	Before short-circuit test	After short-circuit test	
17	Insulating liquid test, measurement of dissolved gasses in dielectric liquid from each separate oil compartment except diverter switch compartment (routine test, type test)	Breakdown voltage (kV): ≥ 45 $\tan\delta$ (90°C): $\leq 0.5\%$ Water content (mg/L): ≤ 20	65.7 0.12% 10.3	63.1 0.12% 10.5	PASS
		Providing gas chromatograph analysis: Hydrogen: $< 30\mu\text{L/L}$ Acetylene: 0 Total hydrocarbon: $< 20\mu\text{L/L}$	See 4.17	See 4.19.4.17	
18	Measurement of frequency response (special test)	Providing frequency response characteristics curve	See 4.18	See 4.19.4.18	PASS
19	Short-circuit withstand test (special test)	Test times of each phase: 3 times Duration (s): $0.25\pm 10\%$ The test oscillogram shall be normal. The reactance variation in phase before and after the test is not more than 2%. The outside and out-of-tank inspection does not reveal any obvious defects. Routine retests shall be passed after short-circuit test.	3 times $0.256\sim 0.259$ Without abnormality The maximum reactance variation in phase is 0.26% Without obvious defects Routine retests are passed.		PASS
20	Measurement of no-load excitation characteristics (commission test)	Providing no-load excitation characteristic curve	See 4.20		/
21	Long-duration no-load test (commission test)	Applied voltage (kV): $1.1U_n$ Duration (h): 12 Without acetylene in oil	$1.1U_n$ 12 For gas chromatograph analysis, see 4.19.4.17		PASS
22	Measurement of zero-sequence impedances on three-phase transformers (special test)	Providing zero-sequence impedance value (Ω)	See 4.22		/
23	Measurement of the harmonics of the no-load current (commission test)	Providing harmonics of the no-load current of each phase	Harmonics of the no-load current of I_1-I_{19}		/

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 08	
No	Test items	Specified value	Measured value		Concl- usion
		Standards (commission requirements)			
24	Temperature-rise test (including calculation of the winding hot-spot temperature-rise) (type test)	Top oil temperature-rise limit (K):53 Winding temperature-rise limit (K):60 Winding hot-spot temperature-rise limit (K):78 Tank surface and metallic structural parts temperature-rise (K): 75	Top oil temperature-rise:50.7 HV winding temperature-rise:55.0 LV winding temperature-rise: 56.2 HV winding hot-spot temperature-rise:69.2 LV winding hot-spot temperature-rise:70.8 Tank surface and metallic structural parts temperature-rise: 57.9		PASS
25	Leak testing with pressure for liquid-immersed transformers (routine test)	Main transformer: Applied pressure (kPa): 30 Duration (h): 24 No oil leakage or damage	30 24 No oil leakage or damage		PASS
		On-load tap-changer tank: Applied pressure (kPa):30 Duration (h): 24 No oil leakage or damage	30 24 No oil leakage or damage		
26	Determination of sound levels (type test)	At no-load condition: Sound pressure level $\overline{L_{PA}}$ dB (A): Sound power level L_{WA} dB (A): ≤ 80	54 74		PASS
		At load condition: Sound pressure level $\overline{L_{PA}}$ dB (A): Sound power level L_{WA} dB (A): ≤ 80	50 70		
		The sum of no-load sound power level and load sound power level: Sound power level L_{SUM} dB (A): ≤ 80	75		
27	Vacuum deflection test on liquid-immersed transformers (special test)	Applied vacuum degree (kPa):0.133 Elastic deflection of tank wall (mm): ≤ 40 Elastic deflection of tank cover (mm): ≤ 18 Permanent deflection of tank wall (mm): ≤ 1 Permanent deflection of tank cover (mm): ≤ 1 No damage	See 4.27		PASS
28	Pressure deflection test on liquid-immersed transformers (special test)	Applied positive pressure (kPa):100 Elastic deflection of tank wall (mm): ≤ 40 Elastic deflection of tank cover (mm): ≤ 18 Permanent deflection of tank wall (mm): ≤ 1 Permanent deflection of tank cover (mm): ≤ 1 No damage	See 4.28		PASS
Blank below					

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			№: 23M1237-S Total 79 Page 09	
4. Test items and results					
4.1 Measurement of d.c. insulation resistance between each winding to earth and between windings (routine test)					
Test date: Sep. 05, 2023 Relative humidity: 72%; Oil temperature: 24.7℃					
Measured part	R ₁₅ (GΩ)	R ₆₀ (GΩ)	R ₆₀₀ (GΩ)	Absorption ratio (R ₆₀ /R ₁₅)	Polarity index (R ₆₀₀ /R ₆₀)
HV—LV and earth	44.1	61.7	81.4	1.40	1.32
LV—HV and earth	22.6	31.5	45.8	1.39	1.45
HV, LV—earth	30.5	43.2	59.7	1.42	1.38
4.2 Check of core and frame insulation for liquid-immersed transformers with core or frame insulation (routine test)					
Test date: Sep. 05, 2023 Relative humidity: 72%; Oil temperature: 24.7℃					
Measured part	Measured insulation resistance (GΩ)		Insulation resistance corrected to 20℃ (GΩ)		
Core—earth	5.86		7.09		
Frame—earth	4.34		5.25		
Core—frame	6.07		7.34		
4.3 Measurement of dissipation factor (tanδ) of the insulation system capacitances (routine test)					
Test date: Sep. 05, 2023 Relative humidity: 72%; Oil temperature: 24.7℃					
Measured part	Dielectric dissipation factor tanδ (%)	Dielectric dissipation factor tanδ corrected to 20℃ (%)		Capacitance (pF)	
HV—LV and earth	0.39	0.34		11583	
LV—HV and earth	0.42	0.37		13824	
HV, LV—earth	0.45	0.40		10635	
4.4 Determination of capacitances windings-to-earth and between windings (routine test)					
Test date: Sep. 05, 2023 See 4.3.					

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 10		
4.5 Measurement of bushing capacitances and dielectric dissipation factor ($\tan\delta$) (commission test) Test date: Sep. 05, 2023 Relative humidity: 72%; Oil temperature: 24.7°C					
Measured content	Applied voltage	No			
		A	B	C	O
		202307101	202307102	202307103	202307104
$\tan\delta$ (%)	10kV	0.29	0.32	0.29	0.37
Nominal capacitance (pF)		173	174	175	294
Measured capacitance (pF)		177	179	173	291
4.6 Auxiliary wiring insulation test (AuxW) (routine test) Test date: Sep. 05, 2023 Relative humidity: 72%; Ambient temperature: 24.9°C; Air pressure: 100.8kPa					
Part of applied voltage		Test voltage (kV)	Test duration (s)	Result	
Wiring for auxiliary power and control circuits		2	60	PASS	

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.				№: 23M1237-S Total 79 Page 11		
4.7 Measurement of voltage ratio and check of phase displacement (routine test)								Test date: Sep. 05, 2023
HV winding		LV winding		Transformation ratio by calculation	Measured voltage ratio tolerance (%)			Connection symbol
Tapping position	Voltage (kV)	Tapping position	Voltage (kV)		AB/ab	BC/bc	CA/ca	
1	121.000	/	10.5	11.524	0.09	0.06	0.13	YNd11
2	119.625			11.393	0.11	0.08	0.17	
3	118.250			11.262	0.08	0.05	0.13	
4	116.875			11.131	0.09	0.06	0.13	
5	115.500			11.000	0.11	0.08	0.19	
6	114.125			10.869	0.07	0.03	0.12	
7	112.750			10.738	0.07	0.04	0.14	
8	111.375			10.607	0.09	0.07	0.16	
9b	110.000			10.476	0.08	0.07	0.21	
10	108.625			10.345	0.08	0.08	0.18	
11	107.250			10.214	0.08	0.04	0.20	
12	105.875			10.083	0.10	0.06	0.16	
13	104.500			9.952	0.09	0.07	0.17	
14	103.125			9.821	0.11	0.08	0.17	
15	101.750			9.690	0.12	0.09	0.17	
16	100.375			9.560	0.07	0.08	0.13	
17	99.000			9.429	0.08	0.07	0.18	

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			No: 23M1237-S Total 79 Page 12
4.8 Measurement of winding resistance (routine test)					Test date: Sep. 05, 2023 Oil temperature: 24.6℃
Winding	Tapping position	Measured value (Ω)			Resistance unbalance rate (%)
		A~O a~b	B~O b~c	C~O c~a	
HV	1	0.2271	0.2276	0.2269	0.31
	2	0.2242	0.2247	0.2241	0.27
	3	0.2212	0.2215	0.2209	0.27
	4	0.2180	0.2185	0.2179	0.28
	5	0.2147	0.2149	0.2144	0.23
	6	0.2112	0.2116	0.2109	0.33
	7	0.2085	0.2089	0.2083	0.29
	8	0.2048	0.2052	0.2045	0.34
	9b	0.2009	0.2016	0.2015	0.35
	10	0.2045	0.2048	0.2039	0.44
	11	0.2078	0.2081	0.2074	0.34
	12	0.2111	0.2116	0.2108	0.38
	13	0.2140	0.2145	0.2137	0.37
	14	0.2172	0.2176	0.2165	0.51
	15	0.2199	0.2204	0.2197	0.32
	16	0.2234	0.2239	0.2228	0.49
	17	0.2267	0.2276	0.2265	0.48
LV	/	4.086×10 ⁻³	4.049×10 ⁻³	4.068×10 ⁻³	0.91


Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.				№: 23M1237-S Total 79 Page 13			
4.9 Measurement of no-load loss and current (routine test)						Test date: Sep. 05, 2023			
Voltage multiple	Applied voltage (kV)		No-load current		No-load loss (kW)				
	Average value	r.m.s. value	(A)	(%)	Measured value	Corrected value			
90%Ur	9.453	9.463	3.52	0.10	19.059	19.0375			
100%Ur	10.527	10.543	4.27	0.12	22.285	22.2504			
110%Ur	11.548	11.715	8.29	0.24	34.919	34.4140			
Remarks: at 100%Ur, the difference between r.m.s. voltage and average voltage is within 3%.									
4.10 Measurement of no-load loss and current at 90% and 110% of rated voltage (type test)									
See 4.9.									
4.11 Measurement of short-circuit impedance and load loss (routine test)						Test date: Sep. 05, 2023 Oil temperature: 24.6℃			
Winding	Tapping position	Applied current I		Measured voltage (kV)	Measured load loss (kW)	Short-circuit impedance (for each phase)		Load loss (kW)	Total loss (kW)
		(A)	I/Ir (%)			HV impedance (Ω)	(%)	Corrected value	Corrected value
						t=75℃ I=Ir	t=75℃ I=Ir	t=75℃ I=Ir	t=75℃ I=Ir
HV LV	1	159.45	53.04	6.795	49.215	24.61	10.59	194.5790	216.8294
	9b	179.58	54.31	6.128	53.168	19.70	10.26	200.6415	222.8919
	17	196.06	53.36	5.321	58.695	15.67	10.07	231.5167	253.7671

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	№: 23M1237-S Total 79 Page 14
4.12 Tests on on-load tap-changers (routine test)		Test date: Sep. 05, 2023
Operation tests: a. with the transformer de-energized, eight complete cycles of operation (a cycle of operation goes from one end of the tapping range to the other, and back again); b. with the transformer de-energized, and with the auxiliary voltage reduced to 85% of its rated value, one complete cycle of operation; c. with the transformer energized at rated voltage and frequency at no load, one complete cycle of operation; d. with one winding short-circuited and rated current in the tapped winding, 10 cycles of tap-change operations across the range of two steps on each side from the middle tapping (the tapchanger will pass 20 times through the changeover position). Test result: PASS		

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			№: 23M1237-S Total 79 Page 15		
4.13 Lightning impulse test (LI, LIC, LIN) (routine test, type test) This test is not applicable before short-circuit withstand test.							
4.14 Applied voltage test (AV) (routine test)					Test date: Sep. 05, 2023		
Relative humidity: 72%; Ambient temperature: 24.9℃; Oil temperature: 24.9℃; Air pressure: 100.8kPa							
Part of applied voltage		Test voltage (kV)		Test duration (s)		Result	
HV and neutral point—LV and earth		140		60		PASS	
LV—HV, neutral point and earth		35		60			
4.15 Line terminal AC withstand test (LTAC) (routine test)							
Test date: Sep. 05, 2023							
Relative humidity: 72%; Ambient temperature: 24.9℃; Oil temperature: 24.9℃; Air pressure: 100.8kPa							
Phase-to-earth test							
Part of applied voltage	Tapping position	Applied voltage (kV)	Induced voltage (kV)		Frequency (Hz)	Test duration (s)	Result
		LV	HV				
ab	5	21	A	200	200	30	PASS
bc		21	B	200			
ca		21	C	200			

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 16	
4.16 Induced voltage withstand test and induced voltage test with partial discharge measurement (IVW, IVPD) (routine test)					
Test date: Sep. 05, 2023 Relative humidity: 72%; Ambient temperature: 24.9°C; Oil temperature: 24.7°C; Air pressure: 100.8kPa HV tapping position is 9b. Frequency is 200Hz.					
Applied voltage		Duration (min)	Partial discharge magnitude (pC)		
Multiple	Phase-to-earth voltage (kV)		A	B	C
$0.4U_r/\sqrt{3}$	25.4	/	<15	<15	<10
$1.2U_r/\sqrt{3}$	76.2	1	<35	<30	<30
$1.58U_r/\sqrt{3}$	100.3	5	<70	<80	<75
$2.0U_r/\sqrt{3}$	127.0	0.5	/	/	/
$1.58U_r/\sqrt{3}$	100.3	5	<70	<75	<70
		10	<65	<70	<95
		15	<70	<80	<95
		20	<70	<75	<90
		25	<65	<70	<90
		30	<60	<70	<90
		35	<60	<75	<90
		40	<65	<75	<90
		45	<65	<75	<90
		50	<65	<75	<90
		55	<65	<75	<90
		60	<65	<75	<90
$1.2U_r/\sqrt{3}$	76.2	1	<30	<35	<50
$0.4U_r/\sqrt{3}$	25.4	/	<15	<20	<20
Remarks: $U_r=110\text{kV}$.					

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 17				
4.17 Insulating liquid test, measurement of dissolved gasses in dielectric liquid from each separate oil compartment except diverter switch compartment (routine test, type test)							
Test date: Sep. 05, 2023 Relative humidity: 67%; Ambient temperature: 24.4 °C							
Dielectric dissipation factor (90 °C)	Breakdown voltage (kV)		Water content (mg/L)				
0.12%	65.7		10.3				
Gas chromatograph analysis (before all tests) Test date: Sep. 05, 2023 μL/L							
H ₂	CO	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbon
0.83	7.54	143.89	1.04	0	0.32	0	1.36
Gas chromatograph analysis (after dielectric test, before temperature-rise test) Test date: Sep. 05, 2023 μL/L							
H ₂	CO	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbon
1.02	9.48	150.13	1.06	0	0.33	0	1.39
Gas chromatograph analysis (after temperature-rise test, before short-circuit test) Test date: Sep. 06, 2023 μL/L							
H ₂	CO	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbon
1.14	11.05	158.42	1.08	0	0.33	0	1.41




Test Report


Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.No: 23M1237-S
Total 79 Page 19

LV windings frequency response curve before short circuit test


ab



bc



ca





Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.				№: 23M1237-S Total 79 Page 20		
4.19 Short-circuit withstand test (special test)						Test date: Sep. 08, 2023		
Single-phase supply should be used and test voltage shall be supplied between one HV line terminal and the other two line terminals connected together. HV neutral point is earthed. LV side is connected by short-circuit and earthed. The test oscillogram shall be normal. For the test oscillogram, see P ₂₃₋₃₁ . The percentages of peak current and symmetrical current are the ratio of applied current value to calculated current value.								
4.19.1 Current calculation of short-circuit test (reference temperature 75°C)								
Tapping position		Symmetrical value of phase current (A)		Peak value of phase current (A)		Coefficient (K√2)		
1		2692		6865		2.55		
9b		3017		7693		2.55		
17		3360		8568		2.55		
4.19.2 Current injection of short-circuit test								
Tapping position / phase category	Applied voltage terminal	Times	Measurement of current					Oscillogram No
			Symmetrical value of phase current		Peak value of phase current		Duration (s)	
			Measured value (A)	(%)	Measured value (A)	(%)		
1/A	A-BC	The first time	2628	97.62	6863	99.97	0.258	23M1237-S-T001
		The second time	2654	98.59	6867	100.03	0.256	23M1237-S-T002
		The third time	2620	97.33	6772	98.65	0.257	23M1237-S-T003
		Times	Measurement of reactance					
			Reactance values of phase (Ω)			Variation in phase reactance (%)		
			A	B	C	A	B	C
		Before tests	24.046	24.391	24.074	/	/	/
		The first time	24.074	24.608	24.410	0.12	0.09	0.08
		The second time	24.092	24.610	24.412	0.19	0.10	0.09
		The third time	24.101	24.610	24.412	0.23	0.10	0.09
The maximum reactance variation in phase is 0.23%.								


Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.					№: 23M1237-S Total 79 Page 21	
Tapping position / phase category	Applied voltage terminal	Times	Measurement of current					
			Symmetrical value of phase current		Peak value of phase current		Duration (s)	Oscillogram No
			Measured value (A)	(%)	Measured value (A)	(%)		
9b/B	B-CA	The first time	2979	98.74	7720	100.35	0.258	23M1237-S-T004
		The second time	2924	96.92	7546	98.09	0.256	23M1237-S-T005
		The third time	2898	96.06	7480	97.23	0.258	23M1237-S-T006
		Times	Measurement of reactance					
			Reactance values of phase (Ω)			Variation in phase reactance (%)		
			A	B	C	A	B	C
		Before tests	19.296	19.573	19.343	/	/	/
		The first time	19.343	19.673	19.592	0.24	0.14	0.10
		The second time	19.343	19.679	19.591	0.24	0.17	0.09
		The third time	19.343	19.685	19.594	0.24	0.20	0.11
The maximum reactance variation in phase is 0.24%.								


Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.					№: 23M1237-S Total 79 Page 22	
Tapping position / phase category	Applied voltage terminal	Times	Measurement of current					
			Symmetrical value of phase current		Peak value of phase current		Duration (s)	Oscillogram No
			Measured value (A)	(%)	Measured value (A)	(%)		
17/C	C-AB	The first time	3209	95.51	8327	97.19	0.259	23M1237-S-T007
		The second time	3264	97.14	8472	98.88	0.257	23M1237-S-T008
		The third time	3285	97.77	8490	99.09	0.257	23M1237-S-T009
		Times	Measurement of reactance					
			Reactance values of phase (Ω)			Variation in phase reactance (%)		
			A	B	C	A	B	C
		Before tests	15.298	15.540	15.336	/	/	/
		The first time	15.336	15.701	15.565	0.25	0.22	0.16
		The second time	15.336	15.702	15.570	0.25	0.22	0.19
		The third time	15.337	15.702	15.579	0.26	0.22	0.25
The maximum reactance variation in phase is 0.26%.								
4.19.3 Outside and out-of-tank inspection								
The outside inspection indicates no anomalies. The out-of-tank inspection does not reveal any obvious distortion and displacement of coil, lead and supporting structures after the short-circuit test and no traces of discharge are found. For the pictures before and after the short-circuit test, see P ₆₉₋₇₀ .								


Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 23		
Oscillogram						
23M1237-S-T001						
800.0 kV U -800.0 kV 25.0 kA I -25.0 kA 扫描编号: 1 215.8 ms 50.00 ms/div 715.8 ms						
Tapping position / phase category	Applied voltage terminal	Peak value of phase current (A)		Symmetrical value of phase current (A)		Duration (s)
		Measured value (A)	Measured /calculated (%)	Measured value (A)	Measured /calculated (%)	
1/A	A-BC	6863	99.97	2628	97.62	0.258

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 24		
Oscillogram						
23M1237-S-T002						
800.0 kV U -800.0 kV 25.0 kA I -25.0 kA  扫描编号: 1215.8 ms50.00 ms/div715.8 ms						
Tapping position / phase category	Applied voltage terminal	Peak value of phase current (A)		Symmetrical value of phase current (A)		Duration (s)
		Measured value (A)	Measured /calculated (%)	Measured value (A)	Measured /calculated (%)	
1/A	A-BC	6867	100.03	2654	98.59	0.256








Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 28		
Oscillogram						
23M1237-S-T006						
800.0 kV U -800.0 kV 25.0 kA I -25.0 kA  扫描编号: 1215.8 ms50.00 ms/div715.8 ms						
Tapping position / phase category	Applied voltage terminal	Peak value of phase current (A)		Symmetrical value of phase current (A)		Duration (s)
		Measured value (A)	Measured /calculated (%)	Measured value (A)	Measured /calculated (%)	
9b/B	B-CA	7480	97.23	2898	96.06	0.258


Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	№: 23M1237-S Total 79 Page 29
-------------	--	----------------------------------

Oscillogram



Tapping position / phase category	Applied voltage terminal	Peak value of phase current (A)		Symmetrical value of phase current (A)		Duration (s)
		Measured value (A)	Measured /calculated (%)	Measured value (A)	Measured /calculated (%)	
17/C	C-AB	8327	97.19	3209	95.51	0.259

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 30		
Oscillogram						
23M1237-S-T008						
800.0 kV U -800.0 kV 25.0 kA I -25.0 kA 扫描编号: 1 215.8 ms 50.00 ms/div 715.8 ms						
Tapping position / phase category	Applied voltage terminal	Peak value of phase current (A)		Symmetrical value of phase current (A)		Duration (s)
		Measured value (A)	Measured /calculated (%)	Measured value (A)	Measured /calculated (%)	
17/C	C-AB	8472	98.88	3264	97.14	0.257

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 31		
Oscillogram						
23M1237-S-T009						
800.0 kV U -800.0 kV 25.0 kA I -25.0 kA  扫描编号: 1215.8 ms50.00 ms/div715.8 ms						
Tapping position / phase category	Applied voltage terminal	Peak value of phase current (A)		Symmetrical value of phase current (A)		Duration (s)
		Measured value (A)	Measured /calculated (%)	Measured value (A)	Measured /calculated (%)	
17/C	C-AB	8490	99.09	3285	97.77	0.257


Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			№: 23M1237-S Total 79 Page 32	
4.19.4 Routine retests					
4.19.4.1 Measurement of d.c. insulation resistance between each winding to earth and between windings (routine test)					
Test date: Sep. 11, 2023 Relative humidity: 63%; Oil temperature: 26.2℃					
Measured part	R ₁₅ (GΩ)	R ₆₀ (GΩ)	R ₆₀₀ (GΩ)	Absorption ratio (R ₆₀ /R ₁₅)	Polarity index (R ₆₀₀ /R ₆₀)
HV—LV and earth	36.8	54.2	74.7	1.47	1.38
LV—HV and earth	19.7	27.2	39.9	1.38	1.47
HV, LV—earth	25.4	37.1	52.6	1.46	1.42
4.19.4.2 Check of core and frame insulation for liquid-immersed transformers with core or frame insulation (routine test)					
Test date: Sep. 11, 2023 Relative humidity: 63%; Oil temperature: 26.2℃					
Measured part	Measured insulation resistance (GΩ)		Insulation resistance corrected to 20℃ (GΩ)		
Core—earth	5.42		6.97		
Frame—earth	3.95		5.08		
Core—frame	5.36		6.89		
4.19.4.3 Measurement of dissipation factor (tanδ) of the insulation system capacitances (routine test)					
Test date: Sep. 11, 2023 Relative humidity: 63%; Oil temperature: 26.2℃					
Measured part	Dielectric dissipation factor tanδ (%)	Dielectric dissipation factor tanδ corrected to 20℃ (%)		Capacitance (pF)	
HV—LV and earth	0.40	0.34		11726	
LV—HV and earth	0.44	0.37		13974	
HV, LV—earth	0.46	0.39		10596	
4.19.4.4 Determination of capacitances windings-to-earth and between windings (routine test)					
Test date: Sep. 11, 2023 See 4.19.4.3.					

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 33		
4.19.4.5 Measurement of bushing capacitances and dielectric dissipation factor ($\tan\delta$) (commission test) Test date: Sep. 11, 2023 Relative humidity: 63%; Oil temperature: 26.2℃					
Measured content	Applied voltage	No			
		A	B	C	O
		202307101	202307102	202307103	202307104
$\tan\delta$ (%)	10kV	0.28	0.30	0.27	0.36
Nominal capacitance (pF)		173	174	175	294
Measured capacitance (pF)		179	181	172	297
4.19.4.6 Auxiliary wiring insulation test (AuxW) (routine test) Test date: Sep. 11, 2023 Relative humidity: 56%; Ambient temperature: 26.1℃; Air pressure: 101.0kPa					
Part of applied voltage		Test voltage (kV)	Test duration (s)	Result	
Wiring for auxiliary power and control circuits		2	60	PASS	

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.				№: 23M1237-S Total 79 Page 34		
4.19.4.7 Measurement of voltage ratio and check of phase displacement (routine test)								
Test date: Sep. 11, 2023								
HV winding		LV winding		Transformation ratio by calculation	Measured voltage ratio tolerance (%)			Connection symbol
Tapping position	Voltage (kV)	Tapping position	Voltage (kV)		AB/ab	BC/bc	CA/ca	
1	121.000	/	10.5	11.524	0.10	0.08	0.12	YNd11
2	119.625			11.393	0.11	0.10	0.14	
3	118.250			11.262	0.10	0.06	0.15	
4	116.875			11.131	0.13	0.09	0.15	
5	115.500			11.000	0.13	0.10	0.17	
6	114.125			10.869	0.08	0.05	0.14	
7	112.750			10.738	0.08	0.06	0.16	
8	111.375			10.607	0.08	0.05	0.13	
9b	110.000			10.476	0.06	0.08	0.19	
10	108.625			10.345	0.07	0.06	0.16	
11	107.250			10.214	0.07	0.05	0.18	
12	105.875			10.083	0.08	0.05	0.15	
13	104.500			9.952	0.11	0.07	0.19	
14	103.125			9.821	0.13	0.10	0.16	
15	101.750			9.690	0.11	0.08	0.15	
16	100.375			9.560	0.08	0.06	0.14	
17	99.000			9.429	0.11	0.10	0.20	

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			№: 23M1237-S Total 79 Page 35	
4.19.4.8 Measurement of winding resistance (routine test)					Test date: Sep. 11, 2023 Oil temperature: 26.1℃	
Winding	Tapping position	Measured value (Ω)			Resistance unbalance rate (%)	
		A~O a~b	B~O b~c	C~O c~a		
HV	1	0.2282	0.2287	0.2279	0.35	
	2	0.2251	0.2256	0.2249	0.31	
	3	0.2221	0.2224	0.2218	0.27	
	4	0.2192	0.2198	0.2191	0.32	
	5	0.2156	0.2161	0.2153	0.37	
	6	0.2288	0.2292	0.2286	0.26	
	7	0.2096	0.2101	0.2093	0.38	
	8	0.2058	0.2061	0.2055	0.29	
	9b	0.2019	0.2024	0.2018	0.30	
	10	0.2057	0.2062	0.2055	0.34	
	11	0.2095	0.2100	0.2091	0.43	
	12	0.2331	0.2337	0.2328	0.39	
	13	0.2151	0.2154	0.2147	0.33	
	14	0.2189	0.2194	0.2185	0.41	
	15	0.2221	0.2226	0.2218	0.36	
	16	0.2251	0.2256	0.2248	0.36	
	17	0.2281	0.2289	0.2279	0.44	
LV	/	4.107×10 ⁻³	4.069×10 ⁻³	4.082×10 ⁻³	0.93	

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.				№: 23M1237-S Total 79 Page 36			
4.19.4.9 Measurement of no-load loss and current (routine test)						Test date: Sep. 11, 2023			
Voltage multiple	Applied voltage (kV)		No-load current		No-load loss (kW)				
	Average value	r.m.s. value	(A)	(%)	Measured value	Corrected value			
90%Ur	9.456	9.471	3.58	0.10	19.082	19.0517			
100%Ur	10.533	10.548	4.32	0.12	22.435	22.4023			
110%Ur	11.592	11.760	8.55	0.25	35.502	34.9875			
Remarks: at 100%Ur, the difference between r.m.s. voltage and average voltage is within 3%.									
4.19.4.10 Measurement of no-load loss and current at 90% and 110% of rated voltage (type test) See 4.19.4.9.									
4.19.4.11 Measurement of short-circuit impedance and load loss (routine test)						Test date: Sep. 11, 2023 Oil temperature: 26.1°C			
Winding	Tapping position	Applied current I		Measured voltage (kV)	Measured load loss (kW)	Short-circuit impedance (for each phase)		Load loss (kW)	Total loss (kW)
		(A)	I/I _r (%)			HV impedance (Ω)	(%)	Corrected value	Corrected value
						t=75°C I=I _r	t=75°C I=I _r	t=75°C I=I _r	t=75°C I=I _r
HV LV	1	161.76	53.81	6.898	50.952	24.62	10.60	194.9401	217.3424
	9b	176.15	53.27	6.025	51.486	19.75	10.28	201.0593	223.4616
	17	200.17	54.48	5.436	61.584	15.68	10.08	232.0265	254.4288

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	№: 23M1237-S Total 79 Page 37
4.19.4.12 Tests on on-load tap-changers (routine test) Test date: Sep. 11, 2023 Operation tests: a. with the transformer de-energized, eight complete cycles of operation (a cycle of operation goes from one end of the tapping range to the other, and back again); b. with the transformer de-energized, and with the auxiliary voltage reduced to 85% of its rated value, one complete cycle of operation; c. with the transformer energized at rated voltage and frequency at no load, one complete cycle of operation; d. with one winding short-circuited and rated current in the tapped winding, 10 cycles of tap-change operations across the range of two steps on each side from the middle tapping (the tapchanger will pass 20 times through the changeover position). Test result: PASS 		

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 38
4.19.4.13 Lightning impulse test (LI, LIC, LIN) (routine test, type test)			Test date: Sep. 11, 2023
Atmospheric conditions of test: Relative humidity: 54%; Ambient temperature: 25.8°C; Oil temperature: 25.7°C; Air pressure:101.0kPa.			
Test items and voltage			
Withstand terminal	Rated withstand voltage (kV)		Tapping position
	Lightning full wave	Lightning chopped wave	
A, B, C	480	530	A:1; B:9b; C:17
O	325	/	1
a, b, c	75	85	/
Test sequence: Line terminal: One negative reduced level full wave impulse; One negative full level full wave impulse; One negative reduced level chopped wave impulse; Two negative full level chopped wave impulses; Two negative full level full wave impulses. Neutral point: One negative reduced level full wave impulse; Three negative full level full wave impulses. Test records: T1: wave front time; T2: time to half-value; Tc: time to chopping; Upk: peak voltage. For waveform diagram, see P ₃₉₋₄₅ . Voltage ranges of oscillograms are as below:			
Withstand terminal	Full wave (kV)	Chopped wave (kV)	
A, B, C	479.29~483.65	530.75~536.27	
O	325.10~328.20	/	
a, b, c	75.28~77.06	85.72~86.29	


Test Report

Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.

No: 23M1237-S

Total 79 Page 39

Tested terminal: A Test polarity: negative Channel 1: voltage wave Channel 2: current wave




Test Report

Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.

No: 23M1237-S
Total 79 Page 40

Tested terminal: B Test polarity: negative Channel 1: voltage wave Channel 2: current wave



Test Report

Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.

No: 23M1237-S


Total 79 Page 41

Tested terminal: C

Test polarity: negative

Channel 1: voltage wave

Channel 2: current wave



Test Report


Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.No: 23M1237-S
Total 79 Page 42

Tested terminal: O

Test polarity: negative

Channel 1: voltage wave

Channel 2: current wave




Test Report

Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.

№: 23M1237-S

Total 79 Page 43

Tested terminal: a Test polarity: negative Channel 1: voltage wave Channel 2: current wave




Test Report

Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.

No: 23M1237-S

Total 79 Page 44

Tested terminal: b Test polarity: negative Channel 1: voltage wave Channel 2: current wave




Test Report

Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.

№: 23M1237-S
Total 79 Page 45


Tested terminal: c Test polarity: negative Channel 1: voltage wave Channel 2: current wave



Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			№: 23M1237-S Total 79 Page 46		
4.19.4.14 Applied voltage test (AV) (routine test) Test date: Sep. 11, 2023 Relative humidity: 56%; Ambient temperature: 26.1℃; Oil temperature: 25.6℃; Air pressure: 101.0kPa							
Part of applied voltage		Test voltage (kV)		Test duration (s)		Result	
HV and neutral point—LV and earth		140		60		PASS	
LV—HV, neutral point and earth		35		60			
4.19.4.15 Line terminal AC withstand test (LTAC) (routine test) Test date: Sep. 11, 2023 Relative humidity: 56%; Ambient temperature: 26.1℃; Oil temperature: 25.6℃; Air pressure: 101.0kPa Phase-to-earth test							
Part of applied voltage	Tapping position	Applied voltage (kV)	Induced voltage (kV)		Frequency (Hz)	Test duration (s)	Result
		LV	HV				
ab	5	21	A	200	200	30	PASS
bc		21	B	200			
ca		21	C	200			

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 47	
4.19.4.16 Induced voltage withstand test and induced voltage test with partial discharge measurement (IVW, IVPD) (routine test)					
Test date: Sep. 11, 2023 Relative humidity: 56%; Ambient temperature: 26.1 °C; Oil temperature: 26.1 °C; Air pressure: 101.0kPa HV tapping position is 9b. Frequency is 200Hz.					
Applied voltage		Duration (min)	Partial discharge magnitude (pC)		
Multiple	Phase to earth voltage (kV)		A	B	C
$0.4U_r/\sqrt{3}$	25.4	/	<15	<20	<15
$1.2U_r/\sqrt{3}$	76.2	1	<30	<30	<35
$1.58U_r/\sqrt{3}$	100.3	5	<80	<80	<75
$2.0U_r/\sqrt{3}$	127.0	0.5	/	/	/
$1.58U_r/\sqrt{3}$	100.3	5	<75	<80	<70
		10	<70	<75	<90
		15	<70	<75	<95
		20	<75	<75	<90
		25	<75	<80	<90
		30	<80	<80	<90
		35	<80	<90	<90
		40	<80	<90	<90
		45	<75	<85	<90
		50	<75	<85	<90
		55	<75	<80	<90
		60	<75	<80	<90
$1.2U_r/\sqrt{3}$	76.2	1	<35	<35	<45
$0.4U_r/\sqrt{3}$	25.4	/	<15	<25	<20
Remarks: $U_r=110\text{kV}$.					

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.					№: 23M1237-S Total 79 Page 48	
4.19.4.17 Insulating liquid test, measurement of dissolved gases in dielectric liquid from each separate oil compartment except diverter switch compartment (routine test, type test)							
Test date: Sep. 08, 2023 Relative humidity: 61%; Ambient temperature:22.9℃							
Dielectric dissipation factor (90℃)		Breakdown voltage (kV)			Water content (mg/L)		
0.12%		63.1			10.5		
Gas chromatograph analysis (after short-circuit test, before dielectric retests)							
Test date: Sep. 08, 2023 μL/L							
H ₂	CO	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbon
1.43	15.91	180.42	1.14	0	0.36	0	1.50
Gas chromatograph analysis (after dielectric retests, before long-duration no-load test)							
Test date: Sep. 11, 2023 μL/L							
H ₂	CO	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbon
1.49	18.01	187.64	1.16	0	0.37	0	1.53
Gas chromatograph analysis (after long-duration no-load test, after all tests)							
Test date: Sep. 12, 2023 μL/L							
H ₂	CO	CO ₂	CH ₄	C ₂ H ₆	C ₂ H ₄	C ₂ H ₂	Total hydrocarbon
1.26	13.58	169.21	1.11	0	0.34	0	1.45




Test Report


Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.№: 23M1237-S
Total 79 Page 50

LV windings frequency response curve after short circuit test


ab



bc



ca



Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	№: 23M1237-S Total 79 Page 51
-------------	--	----------------------------------

4.20 Measurement of no-load excitation characteristics (commission test)		Test date: Sep. 11, 2023
Voltage	Measured voltage (kV)	Measured current (A)
0.1Un	1.052	0.3615
0.2Un	2.126	0.7315
0.3Un	3.158	1.125
0.4Un	4.215	1.517
0.5Un	5.246	1.924
0.6Un	6.325	2.345
0.7Un	7.327	2.742
0.8Un	8.427	3.201
0.9Un	9.482	3.685
0.95Un	9.978	3.985
1.0Un	10.521	4.315
1.05Un	11.062	5.876
1.1Un	11.552	8.292

Remarks: Un=10.5kV.

No-load excitation characteristic curve

Voltage (kV)	Current (A)
1.052	0.3615
2.126	0.7315
3.158	1.125
4.215	1.517
5.246	1.924
6.325	2.345
7.327	2.742
8.427	3.201
9.482	3.685
9.978	3.985
10.521	4.315
11.062	5.876
11.552	8.292

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	№: 23M1237-S Total 79 Page 52	
-------------	---	----------------------------------	--

4.21 Long-duration no-load test (commission test)

Test date: Sep. 12, 2023

1.1 times rated voltage is applied on LV side for 12h. No C₂H₂ is found in oil and the content of total hydrocarbon has no obvious variation before and after the test. For the gas in oil chromatograph analysis data, see 4.19.4.17.

Duration (h)	Voltage (kV)	Current (A)	No-load loss (kW)
1	11.593	8.39	35.388
2	11.551	8.38	35.655
3	11.585	8.36	35.497
4	11.427	8.42	35.695
5	11.569	8.46	35.392
6	11.667	8.36	35.598
7	11.762	8.42	35.727
8	11.472	8.41	35.375
9	11.564	8.34	35.579
10	11.749	8.39	35.606
11	11.560	8.46	35.685
12	11.600	8.46	35.478

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.				№: 23M1237-S Total 79 Page 53	
4.22 Measurement of zero-sequence impedances on three-phase transformers (special test)						
Test date: Sep. 05, 2023						
Connection symbol	Power supply terminal	Open-circuit terminal	Short-circuit terminal	Applied current (A)	Measured voltage (V)	Impedance (Ω)
YNd11	ABC—O	abc	/	124.265	706.654	17.06
						

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			№: 23M1237-S Total 79 Page 54	
4.23 Measurement of the harmonics of the no-load current (commission test)					Test date: Sep. 05, 2023	
No	CH-A THD(%) =20.79		CH-B THD(%) =21.92		CH-C THD(%) =23.42	
	In (A)	In/I1 (%)	In (A)	In/I2 (%)	In (A)	In/I3 (%)
01	4.87	100.00	3.80	100.00	4.17	100.00
02	0.08	1.68	0.05	1.29	0.06	1.38
03	0.45	9.26	0.33	8.63	0.32	7.63
04	0.02	0.48	0.02	0.55	0.03	0.82
05	0.86	17.65	0.71	18.63	0.88	21.06
06	0.01	0.24	0.01	0.32	0.02	0.46
07	0.26	5.26	0.28	7.26	0.26	6.24
08	0.02	0.31	0.01	0.36	0.01	0.25
09	0.05	1.06	0.05	1.29	0.06	1.46
10	0.00	0.09	0.00	0.08	0.01	0.12
11	0.06	1.23	0.04	1.15	0.05	1.26
12	0.00	0.00	0.00	0.04	0.00	0.06
13	0.02	0.48	0.03	0.68	0.02	0.58
14	0.00	0.00	0.00	0.00	0.00	0.00
15	0.05	1.06	0.03	0.76	0.04	0.91
16	0.00	0.00	0.00	0.00	0.00	0.00
17	0.02	0.32	0.01	0.19	0.01	0.35
18	0.00	0.00	0.00	0.00	0.00	0.00
19	0.00	0.00	0.00	0.00	0.00	0.00


Test Report			Suzhou Electrical Apparatus Science Research Institute Co., Ltd.						№: 23M1237-S Total 79 Page 55		
4.24 Temperature-rise test (including calculation of the winding hot-spot temperature-rise) (type test)											
Test date: from Sep. 05, 2023 to Sep. 06, 2023											
Measurement of top oil temperature rise: Short-circuit method is adopted in the test. Tapping position is 17. LV side is short-circuited. Test duration is 13h of which the stabilization time is 3h. It is required to apply 253.7671kW of total loss and 252.5260kW is actually applied during testing. Measurement of HV, LV winding temperature-rise: 367.40A current is required and 366.86A is actually applied during testing.											
Measured data											
Measurement of top oil temperature-rise and average oil temperature-rise			Measurement of average temperature-rise of windings-to-oil							Ambient temperature (°C)	
Top oil temperature (°C)	Average oil temperature (°C)	Total loss injection/ specified total loss (%)	Current injection/ rated current (%)	Cold resistance (Ω)		Average oil temperature (°C)		Average winding temperature (°C)		Total loss	Measurement of cold resistance
76.8	66.9	99.51	99.85	HV	0.4532	At the instant of shut down	67.0	HV	81.2	26.3	24.6
				LV	4.086 ×10 ⁻³	At the end of cooling curve	65.7	LV	82.4		
Calculations of temperature-rise											
Top oil temperature-rise (K)				50.7							
Winding temperature-rise (K)				HV		55.0					
				LV		56.2					
Winding hot-spot temperature-rise (K)				HV		69.2					
				LV		70.8					
Temperature-rise of tank surface and metallic structural parts (K)				/		57.9					
Remarks: the calculated results of temperature-rise are the corrected value under specified total loss and rated current. Both HV and LV winding hot-spot factors are 1.3.											

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	No: 23M1237-S Total 79 Page 56
-------------	--	-----------------------------------

Winding temperature curve

Average winding temperature data

Average HV winding temperature	81.2℃
--------------------------------	-------



Test Report

Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.№: 23M1237-S
Total 79 Page 57


Winding temperature curve


Average winding temperature data

Average LV winding
temperature

82.4°C

Average temperature of LV winding at the instant of shutdown is 82.4°C





Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 59	
4.25 Leak testing with pressure for liquid-immersed transformers (routine test)				
Test date: from Sep. 03, 2023 to Sep. 05, 2023				
Test method	Applied part	Applied pressure (kPa)	Duration (h)	Result
Static pressure method	Main part of transformer	30	24	No oil leakage or damage
	On-load tap-changer tank	30	24	No oil leakage or damage
Remarks: the tank of product is of general structure. No oil leakage or damage is found before leak testing.				

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 60		
4.26 Determination of sound levels (type test) Test date: Sep. 05, 2023 4.26.1 Rough estimation of the load current sound power level Equation: $L_{WA, IN} \approx 39 + 18 \lg \frac{S_r}{S_p} = 71.4 \text{ dB (A)}$ where: S_r—the rated power is 63MVA; S_p—the reference power is 1MVA. Because $L_{WA, IN}$ is less 8.6dB (A) than limit value 80.0dB (A) of assured sound power level, according to standard requirement, it need to measure load current sound power level. 4.26.2 At no-load condition 4.26.2.1 Measurement of sound pressure level and calculation of sound power level The transformer is excited at rated conditions. The prescribed contour shall be spaced 1.0m away from the principal radiating surface. Walk-around measurement is adopted in the test with 1/3 octave band. The height 1 of the measured point is 1.0m. The height 2 of the measured point is 2.0m.					
Test environment					
The total area of the surface of the test room $S_v \text{ (m}^2\text{)}$	The average acoustic absorption coefficient α	The amount of acoustic absorption A $\text{(m}^2\text{)}$	Distance from the principal radiating surface (m)	The area of the measurement surface S $\text{(m}^2\text{)}$	Environmetal correction K (dB)
3293.2	0.2	658.6	1.0	102.7	2.1
Measured values (dB)					
Status of cooling device	Average of background noise		Average noise value of transformer $\overline{L_{PA0}}$	A weighted sound pressure level $\overline{L_{PA}} = 10 \lg(10^{0.1\overline{L_{PA0}}} - 10^{0.1\overline{L_{bgA}}}) - K$	A weighted sound power level $L_{WA} = \overline{L_{PA}} + 10 \lg(S/S_0)$
	Before the test	After the test			
/	32.4	32.3	56.4	54	74
Remarks: $\overline{L_{PA0}}$: the uncorrected average A-weighted sound pressure level; $\overline{L_{PA0}} = 10 \lg \left(\frac{1}{N} \sum_{i=1}^N 10^{0.1L_{PAi}} \right)$ $\overline{L_{bgA}}$: the lower of the two calculated average A weighted background noise pressure level.					

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 61
4.26.2.2 Values of frequency spectrum during the test			
Octave band (Hz)	Initial $\overline{L_{bgA}}$ (dB)	Final $\overline{L_{bgA}}$ (dB)	$\overline{L_{PA0}}$ (dB)
50	11.5	12.1	28.6
63	12.8	12.5	31.9
80	12.4	12.8	34.5
100	20.5	20.7	32.6
125	18.6	19.2	34.2
160	20.7	21.1	35.1
200	18.9	19.2	36.5
250	20.5	20.2	40.6
315	21.6	21.1	41.2
400	19.2	19.5	43.9
500	21.5	21.1	44.8
630	20.9	20.8	49.5
800	22.1	21.8	48.2
1000	23.6	23.1	47.6
1250	17.6	18.2	44.6
1600	16.8	17.2	46.2
2000	16.2	16.5	43.2
2500	17.5	17.2	41.6
3150	14.9	14.2	41.9
4000	13.2	13.5	38.2
5000	13.5	13.9	32.6
6300	10.3	10.8	31.5
8000	9.1	9.9	26.5
10000	8.6	9.2	22.6
Remarks: for frequency spectra of sound pressure see P ₆₂ .			

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	№: 23M1237-S Total 79 Page 62
-------------	---	----------------------------------

Mean pressure spectrum

Frequency/Hz	Average sound pressure level/dB(A)/20μPa
50	28
63	32
80	35
100	32
125	34
160	35
200	36
250	40
315	41
400	43
500	44
630	49
800	48
1000	47
1250	44
1600	45
2000	43
2500	41
3150	41
4000	38
5000	32
6300	31
8000	26
10000	22

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			№: 23M1237-S Total 79 Page 63	
4.26.3 At load condition						
4.26.3.1 Measurement of sound pressure level and calculation of sound power level						
The transformer is excited at rated conditions. The prescribed contour shall be spaced 1.0m away from the principal radiating surface. Walk-around measurement is adopted in the test with 1/3 octave band. The height of the measured point is 1.0m. The height 2 of the measured point is 2.0m.						
Test environment						
The total area of the surface of the test room Sv (m ²)	The average acoustic absorption coefficient α	The amount of acoustic absorption A (m ²)	Distance from the principal radiating surface (m)	The area of the measurement surface S (m ²)	Environmetal correction K (dB)	
3293.2	0.2	658.6	1.0	102.7	2.1	
Measured values (dB)						
Status of cooling device	Average of background noise		Average noise value of transformer $\overline{L_{PA0}}$	A weighted sound pressure level $\overline{L_{PA}} = 10\lg(10^{0.1\overline{L_{PA0}}} - 10^{0.1\overline{L_{bgA}}}) - K$	A weighted sound power level $L_{WA} = \overline{L_{PA}} + 10\lg(S/S_0)$	
	Before the test	After the test				
/	32.4	32.3	52.5	50	70	
Remarks: $\overline{L_{PA0}}$: the uncorrected average A-weighted sound pressure level; $\overline{L_{PA0}} = 10\lg(\frac{1}{N} \sum_{i=1}^N 10^{0.1L_{PAi}})$						
$\overline{L_{bgA}}$: the lower of the two calculated average A weighted background noise pressure level.						

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 64
4.26.3.2 Values of frequency spectrum during the test			
Octave band (Hz)	Initial $\overline{L_{bgA}}$ (dB)	Final $\overline{L_{bgA}}$ (dB)	$\overline{L_{PA0}}$ (dB)
50	11.5	12.1	28.5
63	12.8	12.5	30.5
80	12.4	12.8	31.4
100	20.5	20.7	32.1
125	18.6	19.2	33.2
160	20.7	21.1	33.8
200	18.9	19.2	35.6
250	20.5	20.2	37.0
315	21.6	21.1	39.8
400	19.2	19.5	39.5
500	21.5	21.1	41.1
630	20.9	20.8	42.5
800	22.1	21.8	43.8
1000	23.6	23.1	41.9
1250	17.6	18.2	40.8
1600	16.8	17.2	42.5
2000	16.2	16.5	42.1
2500	17.5	17.2	39.8
3150	14.9	14.2	39.2
4000	13.2	13.5	36.8
5000	13.5	13.9	31.5
6300	10.3	10.8	28.7
8000	9.1	9.9	22.5
10000	8.6	9.2	19.6
Remarks: for frequency spectra of sound pressure see P ₆₅ .			

Test Report	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.	№: 23M1237-S Total 79 Page 65
-------------	--	----------------------------------

Average sound pressure level/dB(A)/20μPa

Mean pressure spectrum

Frequency/Hz	Average sound pressure level/dB(A)/20μPa
50	28
63	30
80	31
100	32
125	33
160	34
200	35
250	36
315	38
400	39
500	40
630	42
800	44
1000	41
1250	40
1600	42
2000	41
2500	39
3150	38
4000	36
5000	31
6300	28
8000	22
10000	19

Frequency/Hz

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 66	
4.26.4 The sum of no-load sound power level and load sound power level					
(dB)					
Cooling method	A weighted sound power level (no-load sound level) $L_{WA, UN}$	A weighted sound power level (load sound level) $L_{WA, IN}$	A weighted sound power level $L_{WA, SN}=10lg(10^{0.1L_{WA, UN}} + 10^{0.1L_{WA, IN}})$		
ONAN	74	70	75		
					

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.							№: 23M1237-S Total 79 Page 67																																																																																																																																							
4.27 Vacuum deflection test on liquid-immersed transformers (special test)										Test date: Sep. 03, 2023																																																																																																																																						
Test method			Applied pressure (kPa)					Duration (min)																																																																																																																																								
Vacuum degree			0.133					5																																																																																																																																								
<table border="1"> <tr> <th colspan="2" rowspan="4">Measured items</th> <th colspan="11">Measured point</th> </tr> <tr> <th colspan="9">Tank wall</th> <th colspan="2">Tank cover</th> </tr> <tr> <th colspan="3">HV side</th> <th colspan="3">LV side</th> <th>Left side</th> <th>Right side</th> <th colspan="2">Middle of length</th> </tr> <tr> <th>Left</th> <th>Middle</th> <th>Right</th> <th>Left</th> <th>Middle</th> <th>Right</th> <th>Middle</th> <th>Middle</th> <th>Left</th> <th>Middle</th> <th>Right</th> </tr> <tr> <td rowspan="5">Vacuum degree</td> <td>Initial distance (mm)</td> <td>165</td> <td>167</td> <td>168</td> <td>171</td> <td>175</td> <td>176</td> <td>165</td> <td>170</td> <td>156</td> <td>155</td> <td>153</td> </tr> <tr> <td>Distance after pressure injection (mm)</td> <td>168</td> <td>171</td> <td>172</td> <td>174</td> <td>180</td> <td>180</td> <td>170</td> <td>173</td> <td>160</td> <td>159</td> <td>156</td> </tr> <tr> <td>Distance without pressure (mm)</td> <td>165</td> <td>168</td> <td>169</td> <td>171</td> <td>175</td> <td>177</td> <td>166</td> <td>170</td> <td>156</td> <td>156</td> <td>157</td> </tr> <tr> <td>Elastic deflection (mm)</td> <td>3</td> <td>4</td> <td>4</td> <td>3</td> <td>5</td> <td>4</td> <td>5</td> <td>3</td> <td>4</td> <td>4</td> <td>3</td> </tr> <tr> <td>Permanent deflection (mm)</td> <td>0</td> <td>1</td> <td>1</td> <td>0</td> <td>0</td> <td>1</td> <td>1</td> <td>0</td> <td>0</td> <td>1</td> <td>1</td> </tr> <tr> <td colspan="2">Remarks</td> <td colspan="11">No damage</td> </tr> <tr> <td colspan="13"> Remarks: 1. the tank of product is of general structure. 2. the described left and right sides of test point are viewed from HV side. 3. The test points are obtained from the 1/2 height of the tank in vertical direction, 1/4, 1/2 and 3/4 position respectively in horizontal direction. </td> </tr> </table>													Measured items		Measured point											Tank wall									Tank cover		HV side			LV side			Left side	Right side	Middle of length		Left	Middle	Right	Left	Middle	Right	Middle	Middle	Left	Middle	Right	Vacuum degree	Initial distance (mm)	165	167	168	171	175	176	165	170	156	155	153	Distance after pressure injection (mm)	168	171	172	174	180	180	170	173	160	159	156	Distance without pressure (mm)	165	168	169	171	175	177	166	170	156	156	157	Elastic deflection (mm)	3	4	4	3	5	4	5	3	4	4	3	Permanent deflection (mm)	0	1	1	0	0	1	1	0	0	1	1	Remarks		No damage											Remarks: 1. the tank of product is of general structure. 2. the described left and right sides of test point are viewed from HV side. 3. The test points are obtained from the 1/2 height of the tank in vertical direction, 1/4, 1/2 and 3/4 position respectively in horizontal direction.												
Measured items		Measured point																																																																																																																																														
		Tank wall									Tank cover																																																																																																																																					
		HV side			LV side			Left side	Right side	Middle of length																																																																																																																																						
		Left	Middle	Right	Left	Middle	Right	Middle	Middle	Left	Middle	Right																																																																																																																																				
Vacuum degree	Initial distance (mm)	165	167	168	171	175	176	165	170	156	155	153																																																																																																																																				
	Distance after pressure injection (mm)	168	171	172	174	180	180	170	173	160	159	156																																																																																																																																				
	Distance without pressure (mm)	165	168	169	171	175	177	166	170	156	156	157																																																																																																																																				
	Elastic deflection (mm)	3	4	4	3	5	4	5	3	4	4	3																																																																																																																																				
	Permanent deflection (mm)	0	1	1	0	0	1	1	0	0	1	1																																																																																																																																				
Remarks		No damage																																																																																																																																														
Remarks: 1. the tank of product is of general structure. 2. the described left and right sides of test point are viewed from HV side. 3. The test points are obtained from the 1/2 height of the tank in vertical direction, 1/4, 1/2 and 3/4 position respectively in horizontal direction.																																																																																																																																																

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.							№: 23M1237-S Total 79 Page 68				
4.28 Pressure deflection test on liquid-immersed transformers (special test)												Test date: Sep. 03, 2023	
Test method			Applied pressure (kPa)						Duration (min)				
Positive pressure			100						5				
Measured items		Measured point											
		Tank wall									Tank cover		
		HV side			LV side			Left side	Right side	Middle of length			
		Left	Middle	Right	Left	Middle	Right	Middle	Middle	Left	Middle	Right	
Positive pressure	Initial distance (mm)	165	168	169	171	175	177	166	170	156	156	157	
	Distance after pressure injection (mm)	160	162	164	167	170	172	159	165	152	152	155	
	Distance without pressure (mm)	165	167	168	171	175	176	165	169	156	155	156	
	Elastic deflection (mm)	5	6	5	4	5	5	7	5	4	4	2	
	Permanent deflection (mm)	0	1	1	0	0	1	1	1	0	1	1	
Remarks		No damage											
Remarks: 1. the tank of product is of general structure. 2. the described left and right sides of test point are viewed from HV side. 3. The test points are obtained from the 1/2 height of the tank in vertical direction, 1/4, 1/2 and 3/4 position respectively in horizontal direction.													

HV side before short-circuit:



LV side before short-circuit:



Test Report

Suzhou Electrical Apparatus Science
Research Institute Co., Ltd.

№: 23M1237-S


Total 79 Page 70


HV side after short-circuit:




LV side after short-circuit:









Sound levels arrangement diagram

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 76	
Instruments used in the tests					
No	Test items	Name & type of instrument	Number & validity		Accuracy class
1	Measurement of d.c. insulation resistance between each winding to earth and between windings	Digital mega-ohm meter F1550C	ER17-017	2024-04-26	200k~5/10/20/50/100GΩ class 5, others class 20
2	Check of core and frame insulation for liquid-immersed transformers with core or frame insulation				
3	Measurement of dissipation factor (tanδ) of the insulation system capacitances	Movable insulation diagnostic and analysis system MIDAS2880	ER19-002	2024-02-09	Capacity: ±0.3%rdg±0.3pF Inductance: ±0.5%rdg±0.5mH
4	Measurement of bushing capacitances and dielectric dissipation factor (tanδ)				
5	Determination of capacitances windings-to-earth and between windings				
6	Measurement of winding resistance	DC resistance tester JYR (50C)	ER16-025	2024-03-03	0.2%±0.2μΩ
7	Measurement of voltage ratio and check of phase displacement	Transformer ratio tester JYT (A)	RI15-045	2024-05-25	AC10V: ≤150±0.1% 150~500±0.3%; AC160V: < 2000±0.1% 2000~10000±0.3%; Automatic DC supply <1000 ±0.1% 1000~5000 ±0.3%
8	Measurement of short-circuit impedance and load loss	Transformer power loss test system TMS580-200-4000	749-1237	2024-07-02	Voltage range: 100V~200kV, accuracy; 0.12% Current range: 1A~4000A, accuracy; 0.15%
9	Measurement of no-load loss and current				
10	Measurement of no-load loss and current at 90% and 110% of rated voltage				
11	Tests on on-load tap-changers				
12	Insulating liquid test, measurement of dissolved gasses in dielectric liquid from each separate oil compartment except diverter switch compartment	High precision full-automatic capacitance, inductance and dielectric loss measuring bridge 2840-Combi	ER18-003	2024-06-19	±0.2%rdg±0.01pF; ±0.5%rdg±1×10 ⁻⁵
		Automatic dielectric strength tester NRNY-1004A	ER18-007	2024-05-15	±2%
		Moisture analyzer CA-200	CA02-002	2024-02-09	±3μg (water for 10μg to 1mg or above) RSD 0.3% or under (water for 1mg or above)
		Gas chromatogram analyzer 7890B	749-1732	2024-10-20	/

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.			№: 23M1237-S Total 79 Page 77	
Instruments used in the tests						
No	Test items	Name & type of instrument	Number & validity		Accuracy class	
13	Applied voltage test	Assemblies equipment of power-frequency partial discharge-free test YDTW-300/300	745-051	2024-04-26	/	
		Capacitor voltage divider TAWF-400/300	745-051-1	2024-04-26	/	
14	Auxiliary wiring insulation test	Power-frequency withstand voltage tester PFT6-5	745-083	2023-10-12	/	
15	Line terminal AC withstand test	Transformer power loss test system TMS580-200-4000	749-1237	2024-07-02	Voltage range: 100V~200kV, accuracy; 0.12% Current range: 1A~4000A, accuracy; 0.15%	
16	Induced voltage withstand test and induced voltage test with partial discharge measurement	Transformer power loss test system TMS580-200-4000	749-1237	2024-07-02	Voltage range: 100V~200kV, accuracy; 0.12% Current range: 1A~4000A, accuracy; 0.15%	
		Multi-channel partial discharge tester DDX9121	745-058	2024-06-28	Resolution of partial discharge meter: 10 bits, partial discharge capture: 8 bits (7+), phase resolution 0.1°, linear error <1%, ratio factor indeterminacy <1%, linear (10-100% FS) <1%, resolution 11 bits, measuring model Peak / √2 true RMS, synchronism: local voltage, HV source (automatic), rewrite HV synchronism by manual, synchronism lock range: 20Hz to 400Hz	
17	Temperature-rise test	Transformer power loss test system TMS580-200-4000	749-1237	2024-07-02	Voltage range: 100V~200kV, accuracy; 0.12% Current range: 1A~4000A, accuracy; 0.15%	
		Thermocouple type T	TT33-129/130/131/132/133/134	2024-01-11	/	
		Data acquisition/switch unit 34970A	TT11-065	2024-01-11	V±5.25%, A±1.5%, T±1℃, Ω±0.81%	
		Infrared thermal camera Ti480 RPO	TT14-033	2024-05-28	±2℃ or ±2% of reading, take larger one	
		DC resistance tester JYR (50C)	ER16-079	2024-05-19	0.2%±0.2μΩ	
		DC resistance tester JYR (50C)	ER16-056	2024-08-14	0.2%±0.2μΩ	
		Electronic stopwatch PC396	HT15-010	2024-02-17	/	

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 78	
Instruments used in the tests					
No	Test items	Name & type of instrument	Number & validity		Accuracy class
18	Measurement of no-load excitation characteristics	Transformer power loss test system TMS580-200-4000	749-1237	2024-07-02	Voltage range: 100V~200kV, accuracy; 0.12% Current range: 1A~4000A, accuracy; 0.15%
19	Long-duration no-load test				
20	Measurement of zero-sequence impedances on three-phase transformers				
21	Measurement of the harmonics of the no-load current				
22	Determination of sound levels	Transformer power loss test system TMS580-200-4000	749-1237	2024-07-02	Voltage range: 100V~200kV, accuracy; 0.12% Current range: 1A~4000A, accuracy; 0.15%
		Sound level meter 2270	SP01-013	2024-05-25	Class 1
		Sound level calibrator 4231	SP01-020	2024-05-25	Class 1
		Steel tapeline 5m	LS05-032	2024-03-06	/
23	Short-circuit withstand test	Data collector 1-GEN16T-2	EI56-019	2023-11-23	Class 1.5
		LCR automatic tester UC2860XD	ER16-091	2024-06-05	±0.05%
		Voltage transformer TEMP-1000HU	EH112-001	2023-10-22	Class 0.2
		Voltage transformer VEOS525	EH111-001	2024-09-16	Class 0.2, class 3P
		Voltage transformer VEOS525	EH111-002	2024-09-16	Class 0.2, class 3P
		Voltage transformer VEOS525	EH111-003	2024-09-16	Class 0.2, class 3P
		Current diverter FLT1-30/2.5	EI30-016	2023-10-17	Class 0.2
		Current diverter FLT1-30/2.5	EI30-017	2023-10-17	Class 0.2
		Current diverter FLT1-30/2.5	EI30-018	2023-10-17	Class 0.2
		Low sensitivity current diverter FLP1	EI31-081	2025-02-08	Class 0.2
		Low sensitivity current diverter FLP1	EI31-082	2025-02-08	Class 0.2
		Resistance and capacitance general mixed voltage divider TBF252kV-400pF/500MΩ	EV39-004	2024-04-10	/

Test Report		Suzhou Electrical Apparatus Science Research Institute Co., Ltd.		№: 23M1237-S Total 79 Page 79	
Instruments used in the tests					
No	Test items	Name & type of instrument	Number & validity		Accuracy class
24	Lightning impulse test	Assemblies testing equipment of impulse voltage generator CJDY-2400kV/360kJ	750-008	2025-07-04	/
		Weakly damped capacitor voltage divider DDF-2400/400	750-008-1	2025-07-04	/
25	Measurement of frequency response	Transformer winding deformation tester FRAX99	ER16-021	2024-02-09	/
26	Leak testing with pressure for liquid-immersed transformers	Pressure gauge Y-100	FP81-428	2024-01-17	Class 1.6
27	Vacuum deflection test on liquid-immersed transformers	Vacuum gauge	FP81-515	2024-02-04	Class 2.5
		Steel tapeline 5m	LS05-032	2024-03-06	/
28	Pressure deflection test on liquid-immersed transformers	Pressure gauge Y-100	FP81-428	2024-01-17	Class 1.6
		Steel tapeline 5m	LS05-032	2024-03-06	/
The remainder of this page is intentionally left blank.					

声 明

1. 报告未加盖检验检测专用章和联页章的无效;
2. 报告涂改无效;
3. 报告无编制、校对、审核、批准人签字无效;
4. 本报告只对所检验的样品有效;
5. 对采信客户提供的且本实验室无法核实其真实性的信息, 由客户自行承担 responsibility。

DECLARATION

1. The report is invalid without special seal for testing and page combining seal on the report;
2. The report is invalid if altered;
3. The report is invalid without signatures of persons for drawing up, proof-reading, reviewing and approval;
4. The report is valid only for the inspected and tested samples.
5. The client shall be responsible for the information provided by the client and the authenticity of which cannot be verified by our laboratory.

注 意 事 项

1. 对本报告如有异议者请于收到报告之日起十五天内向本单位提出, 谢谢合作。
2. 如对本报告无异议, 请于收到报告之日起一个月内取回样品, 生产单位取样品时应携带取样凭证、对本报告的书面认可报告, 方可领回样品。逾期不取者, 则由本单位自行处理。

NOTICE

1. In case there is any objection to this report, please raise it to the laboratory within fifteen days starting from the date of receiving the report. Thank you for your cooperation.
2. In case there is no objection, please take back the samples within one month starting from the date of receiving the report, when the manufacturer is going to take back the samples, certificate for sample taking and along with the written approval for the report should be brought in presence, only then the samples could be taken back. On time due, the samples will be in the laboratory's own disposal.

本试验报告共 79 页 其中图 30 幅 照片 3 张
The test report is in total 79 pages including 30 figures and 3 photos

打字 杨小伟 校对 孟凡超 装订 杨小伟
Typist Yang Xiaowei Proofreader MengFanchao Binder Yang Xiaowei

地址 (Address): 江苏省苏州市吴中区越溪前珠路 5 号 No.5 Qianzhu Rd., Yuexi, Wuzhong District, Suzhou

电话 (Tel): (0512) 66556600 (总机) 68252753 68081201 传真 (Fax): (0512) 68081686

邮编 (Post code): 215104 http: //www.eeti.cn E-mail: eservice @eeti.cn

