

No:AK1300904-2025(1)



240020349812



中国认可
国际互认
检测
TESTING
CNAS L1177

检验检测报告

TEST REPORT

Sample: DRY-TYPE TRANSFORMER

Model, Type: SCB18-2500/10-NX1 2500kVA

Client: Sichuan Zhongxin General Electric Energy Co.,Ltd.

Test Kind: Type test



山东省产品质量检验研究院

Shandong Institute for Product Quality Inspection

国家输配电设备质量检验检测中心（山东）

National Inspection and Testing Center for Power Transmission and Distribution Equipment (Shandong)

声 明

- 1、本报告无“检验检测专用章”及无主检、审核、批准人签字无效。
- 2、本报告涂改无效。
- 3、除全文复制外，不得部分复制本报告。
- 4、送样检验检测，本报告仅对收到样品所检项目的符合性情况负责，其代表性和真实性由委托人负责。
- 5、委托人不得擅自使用本机构的检验检测结果进行不当宣传。
- 6、如对本报告有异议，请于收到报告之日起 15 日内向本机构以书面形式提出，逾期不予受理。

STATEMENT

- 1、This report is not valid without the Special Stamp For Testing And Inspection or signatures of the conductor, the reviewer and the approver.
- 2、This report is not valid if altered.
- 3、This report can only be reproduced in whole and may not be partially reproduced.
- 4、This report of sample-delivery test is valid only for the conformity of the items of the receiving samples. The client is responsible for its authenticity and integrity.
- 5、The client shall not use the test and inspection results for improper publicity.
- 6、If there is any objection concerning the report, please submit it in writing to this agency within 15 days upon reception of the report. The overdue request will not be accepted.

地址：山东省济南市经十东路 31000 号

邮编：250102

电话/传真：(0531) 51758099

地址：山东省济南市山大北路 81 号

邮编：250100

电话/传真：(0531) 51757150

地址：山东省济南市章丘区世纪大道 16288 号

邮编：250220

电话/传真：(0531) 88618119

地址：山东省聊城市茌平区茌东大道 1 号

邮编：252125

电话/传真：(0635) 4571607

地址：山东省济南市市中区南辛庄西路 276 号

邮编：250024

电话/传真：(0531) 51757161 / 51757162

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report

Page 1 of 43

Sample	DRY-TYPE TRANSFORMER	Test Kind	Type test
Client	Sichuan Zhongxin General Electric Energy Co.,Ltd	Model, Type	SCB18-2500/10-NX1 2500kVA
Manufacturer	Sichuan Zhongxin General Electric Energy Co.,Ltd	Grade	Qualified, Energy efficiency grade 1
Address of Client	(Industrial Zone) No.998,Xinghua 5 Road,Xinjin District,Chengdu City,Sichuan Province,China	Registered Trademark	/
Sampling Location	/	Client Representative	Xia Fawan
Sample Batch	/	Receipt Date	2025-10-16
Sample Quantity	1	Producing Date	2025-08
Sample Description	Intact	Batch No.	B250162
Environmental for Test	See the test	Test Date	2025-10-17 to 2025-10-21
Test Standard	GB/T 1094.1-2013、GB/T 1094.3-2017、GB/T 1094.5-2008、GB/T 1094.10-2022、GB/T 1094.11-2022、JB/T 501-2021、JB/T 501-2006、GB/T 35710-2017、IEC 60076-1:2011、IEC 60076-3:2013、IEC 60076-5:2006、IEC 60076-10:2016、IEC 60076-11:2018		
Decision Standard	GB/T 1094.1-2013、GB/T 1094.3-2017、GB/T 1094.5-2008、GB/T 1094.11-2022、GB/T 10228-2023、GB 20052-2024、JB/T 501-2006、GB/T 35710-2017、IEC 60076-1:2011、IEC 60076-3:2013、IEC 60076-5:2006、IEC 60076-11:2018、 <i>Technique service contract of Dry-type Power Transformer- SDQI(G)0402-2025</i>		
Test Item	Measurement of voltage ratio and check of phase displacement + Measurement of winding resistance + Measurement of d.c. insulation resistance each winding to earth and between windings + Applied voltage test(AV) + Induced voltage withstand tests(IVW) + Measurement of no-load loss and current + Measurement of no-load loss and current at 90% and 110% of rated voltage + Measurement of short-circuit impedance and load loss + Partial discharge measurement + Measurement of the harmonics of the no-load current + Measurement of sound level + Temperature-rise test + Power transformer rated power evaluation test + Short-circuit withstand test + Lightning impulse test+Measurement of zero-sequence impedance(s) on three-phase transformers+Measurement of the power taken by the fan and liquid pump motors		
Test Conclusion	The inspection items of the sample were qualified according to GB/T 1094.1-2013、IEC 60076-1:2011、GB/T 1094.3-2017、IEC 60076-3:2013、GB/T 1094.5-2008、IEC 60076-5:2006、GB/T 1094.11-2022、IEC 60076-11:2018、GB/T 10228-2023、GB 20052-2024、JB/T 501-2006、GB/T 35710-2017、 <i>Technique service contract of Dry-type Power Transformer- SDQI(G)0402-2025</i> . (Chapter Inspection Unit)		
Note	1.This report contains the cover and second cover."/"/ Indicates no content. 2.Testing Address: No.31000, Jingshidong Road, Jinan, Shandong. Testing Address: No.1, Chidong Avenue, Chiping District, Liaocheng City. 3.At the request of client,the measurement of the harmonics of the no-load current item should be tested according to JB/T 501-2006. 4.Test data extracted from AK1300904-2025.		

Approved by: 陈大伟

Reviewed by: 李春霞

Tested by: 刘兴贵

Date: 2025-11-24

Date: 2025-11-24

Date: 2025-11-24

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

Test results

No.	Test item	Test requirements Guarantee value (tolerance)	Test results		Verdict
			Before short circuit	After short circuit	
1	Measurement of voltage ratio and check of phase displacement (Routine test)	Voltage ratio at no load no more than: the lower value between a and b on principal tapping or the extreme tapplings: a. $\pm 0.5\%$ of the specified ratio. b. $\pm 1/10$ of the actual percentage impedance on the principal tapping: ($\pm 0.594\%$) Other taps: $\pm 0.5\%$ of the design value of turns ratio. Phase displacement: Dyn11	Principal tapping: 0.02%~0.04% Other tapplings: 0.03%~0.07% Dyn11	Principal tapping: 0.03%~0.04% Other tapplings: 0.04%~0.08% Dyn11	Pass
2	Measurement of winding resistance (Routine test)	DC Resistance Unbalance Rate: Line (%): ≤ 2	h.v.: ≤ 0.36 l.v.: 1.03	h.v.: ≤ 0.33 l.v.: 1.21	Pass
3	Measurement of d.c. insulation resistance each winding to earth and between windings (Routine test)	Provide insulation resistance (GΩ) :/	H-L.E: 516 L-H.E: 558 H.L-E: 532	H-L.E: 493 L-H.E: 537 H.L-E: 519	No verdict
4	Applied voltage test(AV) (Routine test)	h.v.: 35kV 60s l.v.: 3 kV 60s No voltages collapse occurred.	35kV 60s 3 kV 60s No voltages collapse occurred.	35 kV 60s 3 kV 60s No voltages collapse occurred.	Pass
5	Induced voltage withstand tests(IVW) (Routine test)	Applied voltage(kV): 0.8 Induced AC voltage (kV): 20 Test time (s): $120 \times (f_n/f)$ Frequency(Hz): > 50 No voltages collapse occurred.	0.8 20 30 200 No voltages collapse occurred.	0.8 20 30 200 No voltages collapse occurred.	Pass
6	Measurement of zero-sequence impedance(s) on three-phase transformers (Special test)	Provide zero-sequence impedance(Ω) :/	0.00380	/	No verdict
7	Measurement of no-load loss and current (Routine test)	I_0 (%): $\leq 0.6 (1+30\%)$ P_0 (W): ≤ 2080	0.18 2045.46	0.18 2046.57	Pass
8	Measurement of no-load loss and current at 90 % and 110 % of rated voltage (Type test)	at 90 % of rated voltage: I_0 (%): / P_0 (W) :/ at 110 % of rated voltage: I_0 (%): / P_0 (W) :/	0.13 1433.39 0.28 3070.82	/	No verdict
9	Measurement of short-circuit impedance and load loss (Routine test)	t: 145°C Z (%) : $6.0 (1 \pm 10\%)$ P_k (W) : ≤ 16605 P_{Total} (W) : ≤ 18685	Tapping: 3 5.94 16323.86 18369.32	Tapping: 3 5.95 16348.37 18394.94	Pass

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

No.	Test item	Test requirements Guarantee value (tolerance)	Test results		Verdict
			Before short circuit	After short circuit	
10	Partial discharge measurement (Routine test)	Applied voltage (kV) :1.3Ur Test time (min) :3 The maximum level of partial discharges (pC) :≤5	3 A: <4 B: <4 C: <4	3 A: <4 B: <4 C: <4	Pass
11	Measurement of the power taken by the fan and liquid pump motors (Type test)	the power taken by the fan motors (W) : /	535.29		No verdict
12	Measurement of the harmonics of the no-load current (Special test)	Provide the harmonics of the no-load current each phase	See 4.12 I ₁ -I ₂₀ the harmonics of the no-load current		No verdict
13	Measurement of sound level (Type test)	Sound pressure level \overline{L}_{pA} dB (A) : /	41.9		Pass
		Sound power level \overline{L}_{WA} dB (A) : ≤62	57.8		
13	Measurement of sound level (Type test)	method of cooling:AF Sound pressure level \overline{L}_{pA} dB (A) : /	43.4		No verdict
		Sound power level \overline{L}_{WASN} dB (A) : /	62.6		
14	Temperature-rise test (Type test)	Winding temperature rise limit (K) : ≤125	h.v.:92.9 l.v.:106.0		Pass
15	Power transformer rated power evaluation test (Entrust test)	See GB/T 35710-2017	See 4.15		Evaluation power 2500kV A
16	Short-circuit withstand test (Special test)	Three tests on each phase The duration of each test: (s): 0.5(1±10%) the oscillograms no anomalies indication.	3		Pass
		The biggest reactance difference(%): ≤2.0	0.495~0.508		
		The out-of-tank inspection not reveal any defects	Pass		
		The dielectric tests and other routine tests,have been successfully repeated	0.96		
			Pass		
17	Lightning impulse test (Type test)	Full impulse (kV):75(1±3%)	74.59~75.14 Transients record no significant differences		Pass

Note: There are no technical requirement in the standard, so Measurement of d.c. insulation resistance each winding to earth and between windings and Measurement of no-load loss and current at 90 % and 110 % of rated voltage , Measurement of the harmonics of the no-load current , Measurement of the power taken by the fan and liquid pump motors, Measurement of zero-sequence impedance(s) on three-phase transformers and method of cooling:AF Measurement of sound level test items have no single verdict.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

1. Samper parameters

Rated power:	2500kVA
Rated voltages:	10/0.4kV
Rate currents:	144.3/3608.4A
Number of phases:	3
Rated frequency:	50Hz
Tapping range:	$\pm 2 \times 2.5\%$
Connection symbol:	Dyn11
Type of cooling:	AN/AF
Coil structure:	circular concentric coil
Temperature class of insulation:	H
Insulation level:	h.v. Um/LI/AC 12/75/35kV l.v. AC 3kV

2. The sample describes

- (1) Indoor.
- (2) The sample phase sequence marking of high and low winding is clear and accurate.
- (3) The sample external appearance has no collision, damage.

3. Test Standard

GB/T 1094.1-2013 *Power transformers-Part 1:General*
 GB/T 1094.3-2017 *Power transformers -Part 3: Insulation levels, dielectric tests and external clearances in air*
 GB/T 1094.5-2008 *Power transformers-Part 5:Ability to withstand short circuit*
 GB/T 1094.10-2022 *Power transformers-Part 10:Determination of sound levels*
 GB/T 1094.11-2022 *Power transformers-Part 11:Dry-type transformers*
 GB/T10228-2023 *Specification and technical requirements for dry-type power transformers*
 JB/T 501-2021 *Test guide for power transformers*
 JB/T 501-2006 *Test guide for power transformers*
 GB 20052-2024 *Minimum allowable values of energy efficiency and the energy efficiency grades for power transformers*
 GB/T 35710-2017 *Rated power evaluation guide for 35 kV and below power transformers*
Technique service contract of Dry-type Power Transformer-SDQI(G)0402-2025
 IEC 60076-1:2011 *Power transformers - Part 1: General*
 IEC 60076-3:2013 *Power transformers - Part 3: Insulation levels, dielectric tests and external clearances in air*
 IEC 60076-5:2006 *Power transformers - Part 5: Ability to withstand short circuit*
 IEC 60076-10:2016 *Power transformers - Part 10: Determination of sound levels*
 IEC 60076-11:2018 *Power transformers - Part 11:Dry-type transformers*

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

4. Test items and results

4.1 Measurement of voltage ratio and check of phase displacement(routine test)

Date: 2025-10-17

Ambient temperature:17.0°C; RH:63.9 %; Barometric pressure:100.30kPa

H.V. winding		L.V. winding	Voltage ratio	Voltage ratio Deviation (%)			Connection symbol
Tapping	Voltage (kV)	Voltage (kV)		AB/ab	BC/bc	CA/ca	
1	10.5	0.4	26.250	0.06	0.07	0.06	Dyn11
2	10.25		25.625	0.04	0.05	0.04	
3	10		25.000	0.02	0.04	0.03	
4	9.75		24.375	0.03	0.05	0.04	
5	9.5		23.750	0.05	0.06	0.05	

4.2 Measurement of winding resistance (routine test)

Date: 2025-10-17

Winding temperature:17.0°C; Ambient temperature: 17.0°C; RH:63.9 %; Barometric pressure:100.30kPa

Winding	Tapping	Winding resistance			Resistance Unbalance Rate (%)
		A-B (Ω) a-b (m Ω)	B-C (Ω) b-c (m Ω)	C-A (Ω) c-a (m Ω)	
High-voltage	1	0.1843	0.1846	0.1849	0.32
	2	0.1771	0.1773	0.1775	0.23
	3	0.1701	0.1704	0.1707	0.35
	4	0.1642	0.1645	0.1648	0.36
	5	0.1586	0.1588	0.1590	0.25
Low-voltage	/	0.2323	0.2335	0.2347	1.03
		a-o (m Ω)		0.1275	

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

Page 6 of 43

4.3 Measurement of d.c. insulation resistance each winding to earth and between windings (routine test)

Date: 2025-10-17

Ambient temperature:16.8°C; RH:64.1 %; Barometric pressure:100.28kPa

Measurement position	Insulation resistance (GΩ)
High-voltage winding—low-voltage winding, iron core, clamp, oil tank and earth	516
Low-voltage winding—high-voltage winding, iron core, clamp, oil tank and earth	558
High-voltage winding,low-voltage winding—iron core, clamp, oil tank and earth	532

4.4 Applied voltage test(AV) (routine test)

Date: 2025-10-17

Ambient temperature:16.8°C; RH:64.1 %; Barometric pressure:100.28kPa

Position	Test voltage (kV)	Time(s)	Test result
High-voltage winding—earth and low-voltage	35	60	Pass
Low-voltage winding—earth and high-voltage	3	60	

4.5 Induced voltage withstand tests(IVW) (routine test)

Date: 2025-10-17

Ambient temperature:16.8°C; RH:64.1 %; Barometric pressure:100.28kPa

Tapping	Applied voltage (kV)	Induced AC voltage (kV)	Induction factor	Frequency (Hz)	Test time (s)	Test result
	L.V.	H.V.				
3	0.8	20	2	200	30	Pass

4.6 Measurement of zero-sequence impedance(s) on three-phase transformers (special test)

Date: 2025-10-17

Ambient temperature:16.4 °C; RH: 64.5 %; Barometric pressure:100.24 kPa

Connection symbol	Power supply terminal	Open circuit terminal	Short circuit terminal	Applied current(A)	Measuring voltage(V)	Impedance(Ω)
Dyn11	abc-o	A, B, C	/	3000	3.801	0.00380

The test current for each phase is I/3

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

Page 7 of 43

4.7 Measurement of no-load loss and current (routine test)						Date: 2025-10-17			
Ambient temperature:16.6°C; RH:64.3 %; Barometric pressure:100.26kPa ; Transformer temperature :16.6°C									
Test voltage (V)		No-load current		No-load loss (W)					
The mean value of voltage	The r.m.s. value of voltage	(A)	(%)	The measured	The corrected				
401.46	400.68	6.63	0.18	2041.49	2045.46				
4.8 Measurement of no-load loss and current at 90 % and 110 % of rated voltage (Type test)						Date: 2025-10-17			
Ambient temperature:16.6°C; RH:64.3 %; Barometric pressure:100.26kPa ; Transformer temperature :16.6°C									
Proportion of rated voltage	Test voltage (V)		No-load current		No-load loss (W)				
	The mean value of voltage	The r.m.s. value of voltage	(A)	(%)	The measured	The corrected			
90%	360.95	360.14	4.65	0.13	1430.18	1433.39			
110%	441.27	440.39	9.97	0.28	3064.71	3070.82			
4.9 Measurement of short-circuit impedance and load loss (routine test)						Date: 2025-10-17			
Ambient temperature:16.6°C; RH:64.3 %; Barometric pressure:100.26kPa									
Winding	Tapping	The supplied current		The measured voltage (V)	Short-circuit impedance		Load loss (W)		Total loss (W)
		(A)	I/I _r (%)		(%)	(Ω)	The measured	The corrected	The corrected
					t=145°C I=I _r	/	t=145°C I=I _r	t=145°C I=I _r	
H.V. - L.V.	1	109.68	79.8	503.71	6.03	2.66	8260.31	16117.29	18162.75
	3	116.24	80.6	477.17	5.94	2.38	8544.83	16323.86	18369.32
	5	123.45	81.3	450.32	5.85	2.11	8769.28	16582.73	18628.19
4.10 Partial discharge measurement(routine test)						Date: 2025-10-17			
Ambient temperature:16.4°C; RH:64.5 %; Barometric pressure:100.24kPa									
The background noise level (pC)		Applied voltage			Time	Partial discharge level (pC)			
Before the test	After the test	Factor	Frequency (Hz)	(kV)		A	B	C	
A: <2	A: <2	1.8U _r	200	0.72	30s	/	/	/	
B: <2	B: <2								
C: <2	C: <2	1.3U _r	200	0.52	3min	<4	<4	<4	
4.11 Measurement of the power taken by the fan and liquid pump motors (Type test)						Date: 2025-10-17			
Ambient temperature:16.4°C; RH:64.5 %; Barometric pressure:100.24kPa									
Voltage (V)		Current (A)		The measured power (W)					
220.26		2.4548		535.29					

Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

4.12 Measurement of the harmonics of the no-load current (Special test)

Date: 2025-10-17

Ambient temperature:16.5°C; RH:64.5 %; Barometric pressure:100.25kPa

harmonic order	A (%)	B (%)	C (%)
1	100.00	100.00	100.00
2	1.56	1.39	1.49
3	3.81	3.72	3.81
4	1.75	1.93	1.26
5	5.32	5.47	5.16
6	1.26	1.32	1.12
7	2.92	2.99	2.95
8	0.78	0.82	0.73
9	1.62	1.65	1.42
10	0.44	0.49	0.47
11	0.85	0.92	0.16
12	0.44	0.42	0.38
13	0.17	0.25	0.21
14	0.02	0.01	0.01
15	0.00	0.00	0.01
16	0.00	0.01	0.01
17	0.00	0.00	0.00
18	0.00	0.00	0.00
19	0.00	0.00	0.00
20	0.00	0.00	0.00
Apply voltage (V)	401.06	frequency, rate (Hz)	50

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment (Shandong)

Test Report (continued)

4.13 Determination of sound level for each method of cooling (Type test)

Date: 2025-10-17

Ambient temperature: 16.2 °C; RH:64.7 %; Barometric pressure:100.22 kPa; Transformer temperature :16.2°C

4.13.1 Determination of sound level for method of cooling:AN

4.13.1.1 The load current sound power level:

Equation:
$$L_{WA,lr} \approx 39 + 18 \times \lg \frac{S_r}{S_p} = 46.2 \text{ dB(A)}$$

Where: $L_{WA,lr}$ — the A-weighted sound power level of the transformer at rated current, rated frequency and impedance voltage, dB (A) .

S_r —the rated power in megavolt amperes, 2.5 MVA

S_p —the reference power ,1MVA.

The calculated value is 10 dB or more below the sound power level estimated 62 dB(A) at no-load excitation, load current sound measurements are not appropriate.

4.13.1.2 The sound power level measurements

The L.V. Winding test voltage:400V; Frequency:50Hz; Tapping:3;

Measuring point:14; Measuring point height:0.900m; Distance of measuring point:1.000m.

Environmental conditions

The total area of the surface of the test room S_{Vi} (m ²)		The average acoustic absorption coefficient a_i		The sound absorption area of the test room A (m ²)	Distance to the principal radiating surface (m)	The area of the measurement surface S (m ²)	Environmental correction K (dB)
Hard ground	Ceiling and walls	Hard ground	Ceiling and walls				
66.93	266.13	0.1	0.3	86.532	1.0	39.2	4.49


Result dB (A)

Type of cooling	$\overline{L_{pA0}} = 10 \times \lg \left(\frac{1}{N} \sum_{i=1}^N 10^{0.1L_{pAi}} \right)$	$\overline{L_{pA}} = 10 \times \lg \left(10^{0.1\overline{L_{pA0}}} - 10^{0.1\overline{L_{bgA}}} \right) - K$	$L_{WA} = \overline{L_{pA}} + 10 \times \lg \frac{S}{S_0}$
AN	46.5	41.9	57.8


Note: The initial average background noise pressure levels:28.4dB(A),The final average background noise pressure levels:28.4dB(A).

$\overline{L_{bgA}}$: The lower of the two total spatially average A-weighted background noise levels.

Layout of sound pressure level measuring points



Layout of background noise measuring points



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment (Shandong)

Test Report (continued)

4.13.2 Determination of sound level for method of cooling:AF

4.13.2.1 The load current sound power level:

Equation:
$$L_{WA,lr} \approx 39 + 18 \times \lg \frac{S_r}{S_p} = 46.2 \text{ dB(A)}$$

Where: $L_{WA,lr}$ — the A-weighted sound power level of the transformer at rated current, rated frequency and impedance voltage, dB (A) .

S_r — the rated power in megavolt amperes, 2.5 MVA

S_p — the reference power ,1MVA.

4.13.2.2 The sound power level measurements

The L.V. Winding test voltage:400V; Frequency:50Hz; Tapping:3;

Measuring point:24; Measuring point height:0.900m; Distance of measuring point:0.917m.

Environmental conditions

The total area of the surface of the test room S_{Vi} (m ²)		The average acoustic absorption coefficient a_i		The sound absorption area of the test room A (m ²)	Distance to the principal radiating surface (m)	The area of the measurement surface S (m ²)	Environmental correction K (dB)
Hard ground	Ceiling and walls	Hard ground	Ceiling and walls				
66.93	266.13	0.1	0.3	86.532	2.0	83.6	6.87



Result dB (A)

Type of cooling	$\overline{L_{pA0}} = 10 \times \lg \left(\frac{1}{N} \sum_{i=1}^N 10^{0.1L_{pAi}} \right)$	$\overline{L_{pA}} = 10 \times \lg \left(10^{0.1\overline{L_{pA0}}} - 10^{0.1\overline{L_{bgA}}} \right) - K$	$L_{WA} = \overline{L_{pA}} + 10 \times \lg \frac{S}{S_0}$
AF	50.3	43.4	62.6

Note: The initial average background noise pressure levels:28.4dB(A),The final average background noise pressure levels:28.4dB(A).

$\overline{L_{bgA}}$: The lower of the two total spatially average A-weighted background noise levels.

Layout of sound pressure level measuring points Layout of background noise measuring points



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

4.14 Temperature-rise test(Type test)

Date: 2025-10-17 to 2025-10-18

Ambient temperature: 13.2-17.1 °C

Test by simulated load method, tapping:3, Open-circuit test time:13h, Rated voltage: 0.4kV, The supplied voltage: 401.73V. The winding short-circuited test time:10h, Rated current :144.3A, The supplied current :144.68A . method of cooling :AN.

Open-circuit test carried out until stabilisation of the core and the winding temperature. Subsequently, the winding short-circuited test shall be carried out until stabilisation of the core and winding temperature is reached.

Measurement data of the open-circuit test

Winding	Ambient temperature (°C)			Measurement of resistance (Ω)						The winding average temperature rise (K)			
	During cold resistance		During thermal resistance	Cold resistance			Thermal resistance						
H.V. (BC)	17.0			15.3			0.1704			0.1759			25.1
L.V. (bc)							0.0002335			0.0002518			36.7
Sequence	1	2	3	4	5	6	7	8	9	10			
H.V. (BC) (Ω)	0.1759	0.1759	0.1759	0.1759	0.1759	0.1759	0.1759	0.1759	0.1759	0.1758	0.1758		
L.V. (bc) (mΩ)	0.2518	0.2518	0.2518	0.2518	0.2518	0.2518	0.2518	0.2518	0.2517	0.2517			

Measurement data of the winding short-circuited test


Winding	Ambient temperature (°C)			Measurement of resistance (Ω)						The winding average temperature rise (K)			
	During cold resistance		During thermal resistance	Cold resistance			Thermal resistance						
H.V. (BC)	17.0			15.6			0.1704			0.2292			104.0
L.V. (bc)							0.0002335			0.0003197			110.0
Sequence	1	2	3	4	5	6	7	8	9	10			
H.V. (BC) (Ω)	0.2286	0.2281	0.2277	0.2272	0.2268	0.2265	0.2261	0.2258	0.2256	0.2253			
L.V. (bc) (mΩ)	0.3189	0.3182	0.3176	0.3169	0.3164	0.3159	0.3155	0.3150	0.3146	0.3143			

Temperature rise calculation results

The winding average temperature rise of the open-circuit test (K)				The winding average temperature rise of the short-circuited test (K)				
H.V. (BC)		L.V. (bc)		H.V. (BC)		L.V. (bc)		
9.8		21.4		88.4		94.4		
The winding average temperature rise (K)				High-voltage				92.9
				Low-voltage				106.0


Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

Temperature-rise test-the open-circuit test
Hot resistance curve of High-voltage winding: F1




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

Temperature-rise test-the open-circuit test
Hot resistance curve of Low-voltage winding: F2



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)


Temperature-rise test-the winding short-circuited test
Hot resistance curve of High-voltage winding: F3



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

Temperature-rise test-the winding short-circuited test
Hot resistance curve of Low-voltage winding: F4



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

4.15 Power transformer rated power evaluation test (Entrust test) Date: 2025-10-17 to 10-18


Ambient temperature:16.6°C;RH:64.3%;Barometric pressure:100.26kPa

Winding	Tapping	The supplied current		The measured voltage (V)	Short-circuit impedance	Load loss (W)
		(A)	I/Ir (%)		(%)	The corrected
					t=145°C I=Ir	t=145°C I=Ir
H.V. - L.V.	3	116.2 4	80.6	477.17	5.94	16323.86
Assumed rated power 2500kVA					Calibration to rated current and reference temperature 145°C short-circuit impedance%	5.94
Whether short-circuit impedance Z_k is within the allowable range of standard short-circuit impedance(6.0%) error corresponding to the assumed rated power 2500kVA					Yes	
Assumed rated power 1600kVA					Calibration to rated current and reference temperature 145°C short-circuit impedance%	3.80
Whether short-circuit impedance Z_k is within the allowable range of standard short-circuit impedance(6.0%) error corresponding to the assumed rated power 1600kVA					No	
Assumed rated power 2000kVA					Calibration to rated current and reference temperature 145°C short-circuit impedance%	4.75
Whether short-circuit impedance Z_k is within the allowable range of standard short-circuit impedance(6.0%) error corresponding to the assumed rated power 2000kVA					No	
Assumed rated power 2500kVA temperature-rise test					See 4.14	
Whether the temperature rise test results meet the standard requirements corresponding to the preset capacity of 2500kVA					yes	
Appraisal results	The measured power of this transformer is 2500kVA, and the power marked on the nameplate is 2500kVA.Conform to reality.					

Note: The maximum power of the distribution transformer in the standard GB/T 10228-2023 is 2500 kVA, with only one adjacent capacity above the preset capacity.

Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)



Appraisal conclusion: The assumed rated power 2500kVA is transformer power, evaluation over.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

Page 18 of 43

4.16 Short-circuit withstand test (special test)

Date: 2025-10-20

Ambient temperature: 18.6°C; RH: 43%; Barometric pressure: 101.1 kPa

4.16.1 Calculation of short circuit current (Reference temperature 145°C)

Tapping	The peak value of the current (kA)	Value of symmetrical short-circuit current (kA)	Values for factor ($K\sqrt{2}$)
1	5.152 (1 ± 5%)	2.120 (1 ± 10%)	2.43
3	5.423 (1 ± 5%)	2.241 (1 ± 10%)	2.42
5	5.717 (1 ± 5%)	2.372 (1 ± 10%)	2.41

4.16.2 Short-circuit test apply current

Using a three-phase current test with a short circuit on the low-voltage side, the supply voltage is applied to the outer winding (high-voltage side).

Tapping	Phase	Sequence	Current					Duration (ms)	Oscillogram No.	
			The peak value of the current		Value of symmetrical short-circuit current					
			(kA)	(%)	(kA)	(%)				
1	A	1	5.334	103.53	2.148	101.32	503	B1		
		2	5.357	103.98	2.155	101.65	495	B2		
		3	5.342	103.69	2.151	101.46	503	B3		
			Reactance							
			Reactance (Ω)			Tolerance (%)				
			A	B	C	A	B	C		
		Before the test	2.6419	2.6440	2.6462	/	/	/		
		1	2.6468	2.6514	2.6521	0.19	0.28	0.22		
		2	2.6483	2.6536	2.6542	0.24	0.36	0.30		
		3	2.6507	2.6553	2.6567	0.33	0.43	0.40		

The biggest reactance difference is 0.43%.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

4.16.2 Short-circuit test apply current

Tapping	Phase	Sequence	Current					Duration (ms)	Oscillogram No.
			The peak value of the current		Value of symmetrical short-circuit current				
			(kA)	(%)	(kA)	(%)			
3	B	1	5.568	102.67	2.263	100.98	500	B4	
		2	5.593	103.13	2.275	101.52	500	B5	
		3	5.574	102.78	2.272	101.38	508	B6	
		Sequence	Reactance						
			Reactance (Ω)			Tolerance (%)			
		A	B	C	A	B	C		
		Before the test	2.3594	2.3616	2.3638	/	/	/	
		1	2.3684	2.3743	2.3751	0.38	0.54	0.48	
		2	2.3706	2.3768	2.3775	0.47	0.64	0.58	
		3	2.3724	2.3785	2.3762	0.55	0.72	0.52	

The biggest reactance difference is 0.72%.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

4.16.2 Short-circuit test apply current


Tapping	Phase	Sequence	Current						Oscillogram No.
			The peak value of the current		Value of symmetrical short-circuit current		Duration (ms)		
			(kA)	(%)	(kA)	(%)			
5	C	1	5.824	101.87	2.365	99.70	505	B7	
		2	5.853	102.38	2.378	100.25	505	B8	
		3	5.846	102.26	2.374	100.08	505	B9	
		Sequence	Reactance						
			Reactance (Ω)			Tolerance (%)			
			A	B	C	A	B	C	
		Before the test	2.0953	2.0982	2.1012	/	/	/	
		1	2.1084	2.1146	2.1157	0.63	0.78	0.69	
		2	2.1104	2.1165	2.1171	0.72	0.87	0.76	
		3	2.1123	2.1183	2.1198	0.81	0.96	0.89	

The biggest reactance difference is 0.96%.

The biggest reactance difference is 0.96%. After Short circuit test, reveal no defects such as displacements, deformation of windings, connections or supporting structures. No traces of internal electrical discharge were found.


The oscillograms no anomalies indication.

Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)


Test Report (continued)




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

Check before low voltage side short-circuit withstand test



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

Check after low voltage side short-circuit withstand test



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

Check before the high voltage side short-circuit withstand test



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

Check after the high voltage side short-circuit withstand test



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

4.16.3 Routine test retest

4.16.3.1 Measurement of voltage ratio and check of phase displacement

(routine test)

Date: 2025-10-21

Ambient temperature:14.1°C; RH:42.9%; Barometric pressure:100.50kPa

High-voltage winding		Low-voltage winding	Voltage ratio	Voltage ratio Deviation (%)			Connection symbol
Tapping	Voltage (kV)	Voltage (kV)		AB/ab	BC/bc	CA/ca	
1	10.5	0.4	26.250	0.06	0.08	0.07	Dyn11
2	10.25		25.625	0.04	0.06	0.05	
3	10		25.000	0.03	0.04	0.04	
4	9.75		24.375	0.04	0.06	0.05	
5	9.5		23.750	0.05	0.07	0.06	

4.16.3.2 Measurement of winding resistance (routine test)

Date: 2025-10-21

Winding temperature:14.1°C; Ambient temperature: 14.1°C; RH:42.9%; Barometric pressure:100.50kPa

Winding	Tapping	Winding resistance			Resistance Unbalance Rate (%)
		A-B (Ω) a-b (mΩ)	B-C (Ω) b-c (mΩ)	C-A (Ω) c-a (mΩ)	
High-voltage	1	0.1821	0.1824	0.1827	0.33
	2	0.1751	0.1753	0.1755	0.23
	3	0.1682	0.1683	0.1685	0.18
	4	0.1625	0.1627	0.1629	0.25
	5	0.1567	0.1569	0.1571	0.25
Low-voltage	/	0.2299	0.2313	0.2327	1.21
		a - o (mΩ)			0.1259

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

Page 35 of 43

4.16.3.3 Measurement of d.c. insulation resistance each winding to earth and between windings (routine test)

Date: 2025-10-21

Ambient temperature:13.9°C; RH:43.1%; Barometric pressure:100.48kPa

Measurement position	Insulation resistance (GΩ)
High-voltage winding—low-voltage winding, iron core, clamp, oil tank and earth	493
Low-voltage winding—high-voltage winding, iron core, clamp, oil tank and earth	537
High-voltage winding,low-voltage winding—iron core, clamp, oil tank and earth	519

4.16.3.4 Applied voltage test(AV)(routine test)

Date: 2025-10-21

Ambient temperature:13.9°C; RH:43.1%; Barometric pressure:100.48kPa

Position	Test voltage (kV)	Time(s)	Test result
High-voltage winding—earth and low-voltage	35	60	Pass
Low-voltage winding—earth and high-voltage	3	60	

4.16.3.5 Induced voltage withstand tests(IVW) (routine test)

Date: 2025-10-21

Ambient temperature:13.9°C; RH:43.1%; Barometric pressure:100.48kPa

Tapping	Applied voltage (kV)	Induced AC voltage (kV)	Induction factor	Frequency (Hz)	Test time(s)	Test result
	L.V.	H.V.				
3	0.8	20	2	200	30	Pass

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)

Page 36 of 43

4.16.3.6 **Measurement of no-load loss and current** (routine test) Date: 2025-10-21

Ambient temperature: 13.7°C; RH:43.3%; Barometric pressure:100.46kPa;Transformer temperature:13.7°C

Test voltage (V)		No-load current		No-load loss (W)	
The mean value of voltage	The r.m.s. value of voltage	(A)	(%)	The measured	The corrected
401.77	400.94	6.64	0.18	2042.35	2046.57

4.16.3.7 **Measurement of short-circuit impedance and load loss** (routine test)

Date: 2025-10-21

Ambient temperature: 13.7°C; RH:43.3%; Barometric pressure:100.46kPa;

Winding	Tapping	The supplied current		The measured voltage (V)	Short-circuit impedance		Load loss (W)		Total loss (W)
		(A)	I/I _r (%)		(%)	(Ω)	The measured	The corrected	The corrected
					t=145°C I=I _r	/	t=145°C I=I _r	t=145°C I=I _r	
H.V. - L.V.	1	110.16	80.1	506.73	6.04	2.66	7538.23	16134.63	18181.20
	3	116.57	80.8	479.31	5.95	2.38	7799.65	16348.37	18394.94
	5	123.69	81.4	451.95	5.86	2.12	8025.95	16599.44	18646.01

4.16.3.8 **Partial discharge measurement**(routine test) Date: 2025-10-21

Ambient temperature: 13.7°C; RH:43.3%; Barometric pressure:100.46kPa;

The background noise level (pC)		Applied voltage			Time	Partial discharge level (pC)			Test result
Before the test	After the test	Factor	Frequency (Hz)	(kV)		A	B	C	
A:<2	A:<2	1.8U _r	200	0.72	30s	/	/	/	Pass
B:<2	B:<2								
C:<2	C:<2	1.3U _r	200	0.52	3min	<4	<4	<4	

Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

4.17 **Lightning impulse test**(Type test)

Date: 2025-10-21

Ambient temperature:13.5°C;RH:43.5%;Barometric pressure:100.44kPa

The line terminals	A, B, C
Test polarity	Negative polarity
Tapping	3
Full impulse voltage (kV)	75 (1±3%)
The front time T ₁ (μs)	1.2 (1±30%)
The time to half-value T ₂ (μs)	50 (1±20%)
Test sequence	a) One reference impulse of a voltage between 50 % and 70 % of the full test voltage. b) Three subsequent impulses at full voltage.


Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)


Subject terminal: A

Test polarity: negative


50% ~ 70%full impulse




100%full impulse



100%full impulse



100%full impulse




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)


Subject terminal:B

Test polarity: negative


50% ~ 70%full impulse




100%full impulse



100%full impulse



100%full impulse




Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)

Test Report (continued)


Subject terminal: C

Test polarity: negative


50% ~ 70%full impulse




100%full impulse



100%full impulse



100%full impulse



Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)
Test Report (continued)

Sample and nameplate photos



容量 Capacity (kVA)		高压 High Voltage		低压 Low Voltage	
V	A	V	A	V	A
10500		2-3			
10250		3-4			
2500	10000	144.3	4-5		
	9750		5-6		
	9500		6-7		

产品型号 Product Type	SCB18-2500/10-NX1	标准代号 Standard code	GB1094.1.2-2013 GB/T 10228-2023	GB20052-2024 GB1094.3-2017	
产品代号 Product code	1ZX. 710. 2222A	联结组标号 Connection symbol	Dyn11		
绝缘水平 Insulation level	LI75AC35/LI AC 3	额定频率 Rated frequency	50HZ	相数 Number of phases	3
绝缘等级 Thermal Class	H	允许温升 Permissible temperature rise	125	K	
冷却方式 Cooling mode	AN/AF	使用条件 Service conditions	户内		
短路阻抗 Short-circuit impedance	5.94 %	防护等级 Protect Class/level	IP00		
出厂编号 EX-factory No.	B250162				
总重 Total weight	6592 KG	出厂日期 EX-factory date	2025	年 08 月	



众信通用
ZHONGXIN GENERAL

四川众信通用电能股份有限公司
Sichuan Zhongxin General Electric Energy Co., Ltd.

Shandong Institute for Product Quality Inspection
National Inspection and Testing Center for Power Transmission and Distribution Equipment
(Shandong)



Test Report (continued)

Annex: Test principle diagram



Shandong Institute for Product Quality Inspection
 National Inspection and Testing Center for Power Transmission and Distribution Equipment
 (Shandong)

Test Report (continued)



山东省产品质量检验研究院

山东省产品质量检验研究院（简称山东省质检院，英文缩写 SDQI）成立于 1980 年 2 月，隶属于山东省市场监督管理局（知识产权局），是集检测、科研、标准制定、技术服务于一体的第三方综合性检验机构。我院已获得国家级检验检测机构“一家一证”资质认定、山东省市场监督管理局检验检测机构资质认定，是中国合格评定国家认可委员会（CNAS）认可的检测实验室。

检验检测领域：

食品及食品添加剂、农产品、饲料、食品相关产品、化妆品、微生物、基因扩增、包装产品、快递用品、降解、轻工、装饰装修、建筑材料、机械产品、太阳能热水器、节能产品、输配电产品、家用电器、电磁兼容、消防及阻燃、玩具、文具、纤维纺织、石油化工、日用化工、肥料、农药、土壤、危险化学品、水处理剂、体育用品、环境监测等众多行业或领域。

认证检验业务：

IECEE CB 认证、澳洲 SAI 认证、巴西 INMETRO 认证、TÜV Rheinland 认证、CE 认证、海湾国家 GC 认证、欧盟 SOLAR KEYMARK 认证、CCC 强制性认证检验、CQC 自愿性认证检验、消防产品合格评定中心自愿性认证检验、资源节约及环保认证检验、绿色产品认证检验，能效标识能源效率检验、水效标识检验等。

八个国家质检中心：

- 国家包装产品质量检验检测中心（济南）
- 国家加工食品质量检验检测中心（山东）
- 国家装饰装修材料质量检验检测中心
- 国家节能产品质量检验检测中心
- 国家输配电设备质量检验检测中心（山东）
- 国家消防及阻燃产品质量检验检测中心（山东）
- 国家石油化工产品质量检验检测中心（山东）
- 国家体育用品质量检验检测中心（山东）

具有以下授权资质：

第一批国家级标准验证检验检测点试点单位、全国土壤污染状况详查实验室、全国塑料软包装工业产品质量控制与评价实验室、山东产品质量司法鉴定中心、山东省产品质量安全风险监测中心、山东省新旧动能转换行业公共实训基地、山东省新能源汽车电池及充电设施综合性能检测工程实验室、山东省碳排放第三方核查机构、山东省材料化学安全检测技术重点实验室等。