



No : AG1300955-2025 (1)



240020349812



中国认可
国际互认
检测
TESTING
CNAS L1177

检 验 检 测 报 告

TEST REPORT

Sample: Power transformer

Model , Type: SZ22-31500/35-NX1 31500kVA

Client: Sichuan Zhongxin General Electric
Energy Co., Ltd.

Test Kind: Type test



山东省产品质量检验研究院
Shandong Institute for Product Quality Inspection

国家输配电设备质量检验检测中心（山东）

National Inspection and Testing Center for Power Transmission and Distribution Equipment (Shandong)

声 明

- 1、本报告无“检验检测专用章”及无主检、审核、批准人签字无效。
- 2、本报告涂改无效。
- 3、除全文复制外，不得部分复制本报告。
- 4、送样检验检测，本报告仅对收到样品所检项目的符合性情况负责，其代表性和真实性由委托人负责。
- 5、委托人不得擅自使用本机构的检验检测结果进行不当宣传。
- 6、如对本报告有异议，请于收到报告之日起15日内向本机构以书面形式提出，逾期不予受理。

STATEMENT

- 1、 This report is not valid without the Special Stamp For Testing And Inspection or signatures of the conductor, the reviewer and the approver.
- 2、 This report is not valid if altered.
- 3、 This report can only be reproduced in whole and may not be partially reproduced.
- 4、 This report of sample-delivery test is valid only for the conformity of the items of the receiving samples. The client is responsible for its authenticity and integrity.
- 5、 The client shall not use the test and inspection results for improper publicity.
- 6、 If there is any objection concerning the report, please submit it in writing to this agency within 15 days upon reception of the report. The overdue request will not be accepted.

地址：山东省济南市经十东路31000号

邮编：250102

电话/传真：（0531）51758099

地址：山东省济南市山大北路81号

邮编：250100

电话/传真：（0531）51757150

地址：山东省济南市章丘区世纪大道16288号

邮编：250220

电话/传真：（0531）88618119

地址：山东省聊城市茌平区茌东大道1号

邮编：252125

电话/传真：（0635）4571607

地址：山东省济南市市中区南辛庄西路276号

邮编：250024

电话/传真：（0531）51757161 / 51757162

<http://www.sdqi.com.cn>

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report

Page 1 of 49

Sample	Power transformer	Test Kind	Type Test
Client	Sichuan Zhongxin General Electric Energy Co.,Ltd.	Model, Type	SZ22-31500/35-NX1 31500kVA
Manufacturer	Sichuan Zhongxin General Electric Energy Co.,Ltd.	Grade	Qualified products Energy efficiency grade 1
Address of Client	(Industrial Zone) No.998, Xinghua 5 Road, Xinjin District, Chengdu City, Sichuan Province, China	Registered Trademark	/
Sampling Location	/	Client Representative	Xia Fawan
Sample Batch	/	Receipt Date	2025-09-19
Sample Quantity	1 unit	Producing Date	2025-08
Sample Description	Intact	Batch No.	ZX2508161
Environmental for Test	See the test	Test Date	2025-09-19 to 2025-09-26
Test Standard	GB/T 1094.1-2013,GB/T 1094.2-2013,GB/T 1094.3-2017,GB/T 1094.5-2008,GB/T 1094.10-2022,GB/T 6451-2023, JB/T 501-2021,JB/T 501-2006,GB/T 7600-2014,GB/T 261-2021,GB/T 17623-2017,IEC 60076-1:2011,IEC 60076-2:2011, IEC 60076-3:2013+AMD1:2018,IEC 60076-5:2006,IEC 60076-10:2016		
Decision Standard	GB/T 1094.1-2013,GB/T 1094.2-2013,GB/T 1094.3-2017,GB/T 1094.5-2008,GB/T 6451-2023,GB/T 7595-2017, JB/T 10088-2016,JB/T 501-2021,GB 20052-2024,IEC 60076-1:2011,IEC 60076-2:2011,IEC60076-3:2013+AMD1:2018, IEC 60076-5:2006, <i>Technical Service Contract for Oil-immersed Power Transformers-SDQI (Y) 0401-2025</i>		
Test Item	Measurement of voltage ratio and check of phase displacement+Measurement of winding resistance+Measurement of d.c. insulation resistance each winding to earth and between windings and absorption ratio measurements+Check of core and frame insulation+ Measurement of dissipation factor($\tan\delta$) of the insulation system capacitances+ Determination of capacitances windings-to-earth and between windings+Applied voltage test(AV)+ Auxiliary wiring insulation test+ Induced voltage withstand test(IVW) + Measurement of zero-sequence impedance(s) on three-phase transformers+ Measurement of no-load loss and current+ Measurement of no-load loss and current at 90 % and 110 % of rated voltage+Measurement of short-circuit impedance and load loss+ Insulating liquids test+ Tests on on-load tap-changers-Operation test+ Leak testing with pressure for liquid immersed transformers+ Vacuum deflection test on liquid immersed transformers + Pressure deflection test for liquid immersed transformers+ Determination of sound levels+Temperature-rise test+Winding hot-spot temperature-rise(calculation)+Short-circuit withstand test+ Lightning impulse test+ Measurement of the harmonics of the no-load current		
Test Conclusion	According to the GB/T 1094.1-2013,GB/T 1094.2-2013,GB/T 1094.3-2017,GB/T 1094.5-2008,GB/T 6451-2023, GB/T 7595-2017,JB/T 10088-2016,JB/T 501-2021,GB 20052-2024,IEC 60076-1:2011,IEC 60076-2:2011, IEC 60076-3:2013+AMD1:2018,IEC 60076-5:2006 standards and <i>Technique service contract for Oil-immersed Power Transformer -SDQI (Y) 0401-2025</i> , all test items meet the requirements. (Chapter Inspection Unit)		
Note	a) This report includes the front cover and the second cover, “/” Indicates that no content. b) Testing Address: No. 1, Chidong Avenue, Chiping District, Liaocheng City. c) The client requires measurement of the harmonics of the no-load current of this item according to JB/T 501-2006 testing. d) This report is the English report for AG1300955-2025.		

Approved by: 徐仲春
Date: 2025-09-30Reviewed by: 魏秀秀
Date: 2025-09-30Tested by: 王晋凯
Date: 2025-09-30

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 2 of 49

No.	Testing items	Test requirements Guarantee value (Tolerance)	Test result		Verdict
			Before short circuit	After short circuit	
1	Measurement of voltage ratio and check of phase displacement (Routine test)	Voltage ratio at no load no more than: The lower value between a and b on principal tapping or the extreme tapings: a) $\pm 0.5\%$ of the specified ratio; b) $\pm 1/10$ of the actual percentage impedance. On other tapings: $\pm 0.5\%$ of the design value of turns ratio. Phase displacement: YNd11.	-0.05% to 0.20% YNd11	-0.04% to 0.21% YNd11	Qualified
2	Measurement of winding resistance (Routine test)	DC Resistance Unbalance Rate: Phase (%): ≤ 2 Line (%): ≤ 1	HV (Phase): ≤ 0.13 LV (Line): 0.08	HV (Phase): ≤ 0.15 LV (Line): 0.07	Qualified
3	Measurement of d.c. insulation resistance each winding to earth and between windings and absorption ratio measurements (Routine test)	Provide insulation resistance Provide absorptance (R_{60}/R_{15}):	See 4.3	See 4.22.3.3	/
4	Check of core and frame insulation (Routine test)	Core-to-earth (M Ω): ≥ 500 (20 $^{\circ}$ C) Frame-to-earth (M Ω): ≥ 500 (20 $^{\circ}$ C)	See 4.4	See 4.22.3.4	Qualified
5	Measurement of dissipation factor(tan δ) of the insulation system capacitances (Routine test)	Provide dissipation factor(tan δ)	See 4.5	See 4.22.3.5	/

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 3 of 49

No.	Testing items	Test requirements Guarantee value (Tolerance)	Test result		Verdict
			Before short circuit	After short circuit	
6	Determination of capacitances windings- to- earth and between windings (Routine test)	Provide capacitances(nF)	See 4.6	See 4.22.3.5	/
7	Applied voltage test(AV) (Routine test)	HV: 85 kV 60s LV: 35kV 60s	85 kV 60s 35 kV 60s No collapse of the test voltages occurred	85 kV 60s 35 kV 60s No collapse of the test voltages occurred	Qualified
8	Auxiliary wiring insulation test (Routine test)	On-load tap-changes control connection to earth: 2 kV 60s	2 kV 60s No collapse of the test voltages occurred	2 kV 60s No collapse of the test voltages occurred	Qualified
9	Induced voltage withstand test (IVW) (Routine test)	Applied voltage(kV):21 Induced AC voltage (kV):70 Duration (s): 30 Frequency(Hz):f>50	21 70 30 200 No collapse of the test voltages occurred	21 70 30 200 No collapse of the test voltages occurred	Qualified
10	Measurement of no-load loss and current (Routine test)	I_0 (%): ≤ 0.24 (tolerance +30%) P_0 (kW): ≤ 12.0	0.10 10.9998	0.11 11.1032	Qualified
11	Measurement of no- load loss and current at 90% and 110% of rated voltage (Type test)	At 90% of rated voltage: I_0 (%): / P_0 (kW): / At 110% of rated voltage: I_0 (%): / P_0 (kW): /	0.07 8.6794 0.14 14.0000	/	/

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 4 of 49

No.	Testing items	Test requirements Guarantee value (Tolerance)	Test result		Verdict
			Before short circuit	After short circuit	
12	Measurement of short-circuit impedance and load loss (Routine test)	t: 75°C Z(%): 10.0(tolerance $^{+7.5}_{-7.5}\%$) P _k (kW): ≤104.4 P _{total} (kW): ≤116.4	Tapping 4 10.06 102.1426 113.1424	Tapping 4 10.06 102.5219 113.6251	Qualified
13	Insulating liquids test (Routine test, Type test, Entrust test)	Breakdown voltage(kV): ≥40 tan δ (90±1°C): ≤0.010(1.0%) Moisture content(mg/L): ≤20 Average Flash point (closed) (°C): ≥135	68.4 0.426% 13.6 139.1	63.9 0.442% / /	Qualified
		Gas chromatography analysis of dissolved gas H ₂ (μL/L) : <30 C ₂ H ₂ (μL/L) : 0 Total hydrocarbon (μL/L) : <20	See 4.13	/	Qualified
14	Tests on on-load tap-changers-Operation test (Routine test)	After the transformer has been assembled, the on-load tap-changer is subjected to an operational test and does not fail.	Normal	Normal	Qualified
15	Leak testing with pressure for liquid-immersed transformers (tightness test)(Routine test)	Transformers: Applied pressure(kPa): 50 Duration(h): 24 No leakage.	50 24 No leakage	/	Qualified
		On-load tap-Changers oil chamber: Applied pressure(kPa): 50 Duration(h): 24 No leakage.	50 24 No leakage	/	Qualified
16	Vacuum deflection test on liquid immersed transformers (Special test)	Applied vacuum(kPa): <u>50</u> Duration(min): <u>5</u> Elastic deformation(mm): Box wall≤ <u>24</u> Box lid≤ <u>18</u> Permanent deformation(mm): Box wall≤ <u>10</u> Box lid≤ <u>8</u>	See 4.16	/	Qualified
17	Pressure deflection test on liquid immersed transformers (Special test)	Applied positive pressure(kPa): <u>45</u> Duration(min): <u>5</u> Elastic deformation(mm): Box wall≤ <u>24</u> Box lid≤ <u>18</u> Permanent deformation(mm): Box wall≤ <u>10</u> Box lid≤ <u>8</u>	See 4.16	/	Qualified

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 5 of 49

No.	Testing items	Test requirements Guarantee value (Tolerance)	Test result	Verdict
18	Measurement of zero-sequence impedance(s) on three-phase transformers (Special test)	Provide zero-sequence impedance (Ω /phase) :/	3.914	/
19	Measurement of the harmonics of the no-load current (Entrust test)	Provide the harmonics of the no-load current each phase	I ₁ -I ₁₉ the harmonics of the no-load current	/
20	Determination of sound levels (Type test)	Sound pressure level \overline{L}_{pA} dB(A): ≤ 58 Sound power level L_{WA} dB(A): ≤ 77	55.7 74.8	Qualified
21	Temperature- rise test (Type test)	Top insulating liquid temperature rise limit(K): ≤ 53 Winding temperature rise limit(K): ≤ 60 Tank and structural parts surface temperature-rise(K): ≤ 75	Top liquid temperature- rise: 51.1 High- voltage winding temperature- rise: 54.11 Low- voltage winding temperature- rise: 57.22 Tank and structural parts surface temperature-rise: 59.6	Qualified
22	Winding hot-spot temperature-rise (calculation) (Entrust test)	temperature-rise limit (K): ≤ 78	HV: 68.14 LV: 72.19	Qualified
23	Short-circuit withstand test (Special test)	Three tests on each phase The duration of each test(s): 0.25(tolerance $^{+10}_{-10}$ %) the oscillograms no anomalies indication. The biggest reactance difference(%): ≤ 2.0 The out-of-tank inspection not reveal any defects The dielectric tests and other routine tests, have been successfully repeated.	3 0.252 to 0.256 pass 1.17 pass pass	Qualified

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

No.	Testing items	Test requirements Guarantee value (Tolerance)	Test result	Verdict
24	Lightning impulse test (Type test)	a,b,c Full wave(kV): 75(tolerance $\pm\frac{3}{3}\%$) Chopped wave(kV):85(tolerance $\pm\frac{3}{3}\%$) A,B,C Full wave(kV): 200(tolerance $\pm\frac{3}{3}\%$) Chopped wave(kV):220(tolerance $\pm\frac{3}{3}\%$) O Full wave(kV): 200(tolerance $\pm\frac{3}{3}\%$)	Full wave: 75.2 to 76.3 No significant difference in transient waveforms Chopped wave: 83.8 to 85.7 No significant difference in transient waveforms Full wave: 199.1 to 203.0 No significant difference in transient waveforms Chopped wave: 219.2 to 223.8 No significant difference in transient waveforms Full wave: 198.5 to 200.4 No significant difference in transient waveforms	Qualified



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 7 of 49

1. Sample parameters

Rated power:	31500kVA
Rated voltage:	35/10.5kV
Rated current	519.6/1732.1A
Number of phases:	3 phase
Rated frequency:	50 Hz
Tapping range:	±3×2.5%
Connection symbol:	YNd11
Type of cooling:	ONAN
Coil structure:	Circular concentric
Temperature class of insulation:	A
Insulation level:	HV Um/LI/LIC/AC 40.5/200/220/85kV LV Um/LI/LIC/AC 12/75/85/35kV

2. The sample describes

- a) Outdoor.
- b) The sample phase sequence marking of high and low winding is clear and accurate.
- c) The sample external appearance has no collision, damage.

3. Test and decision standard

GB/T 1094.1-2013 *Power transformers-Part 1:General*

GB/T 1094.2-2013 *Power transformers-Part 2: Temperature rise for liquid-immersed transformers*

GB/T 1094.3-2017 *Power transformers-Part 3: Insulation levels, dielectric tests and external clearances in air*

GB/T 1094.5-2008 *Power transformers-Part 5:Ability to withstand short circuit*

GB/T 1094.10-2022 *Power transformers-Part 10:Determination of sound levels*

GB/T 6451-2023 *Specification and technical requirements for oil-immersed power transformers*

JB/T 501-2021 *Test guide for power transformers*

JB/T 501-2006 *Test guide for power transformers*

GB/T 7600-2014 *Determination of water content in transformer oils and turbine oils in service by coulometric method*

GB/T 261-2021 *Determination of flash point-Pensky-Martens closed cup method*

GB/T 17623-2017 *Determination of componental contents of gases dissolved in insulating oil by gas chromatography method*

GB/T 7595-2017 *Quality of transformer oils in service*

JB/T 10088-2016 *Sound level for 6 kV-1 000 kV power transformers*

GB 20052-2024 *Minimum allowable values of energy efficiency and the energy efficiency grades for power transformers*

IEC 60076-1:2011 *Power transformers- Part 1: General*

IEC 60076-2:2011 *Power transformers- Part 2: Temperature rise for liquid- immersed transformers*

IEC 60076-3:2013+AMD1:2018 *Power transformers – Part 3: Insulation levels, dielectric tests and external clearances in air*

IEC 60076-5:2006 *Power transformers-Part 5:Ability to withstand short circuit*

IEC 60076-10:2016 *Power transformers-Part 10:Determination of sound levels*

Technical Service Contract for Oil-immersed Power Transformers-SDQI (Y) 0401-2025

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 8 of 49

4. Test items and result

4.1 Measurement of voltage ratio and check of phase displacement (Routine test)

Date: Sept 22, 2025

Ambient temperature:28.8℃; RH: 54%; Atmospheric pressure:101.2kPa

HV winding		LV winding	Voltage ratio	Voltage ratio deviation (%)			Connection symbol
Tapping	Voltage (kV)	Voltage (kV)		AB/ab	BC/bc	CA/ca	
1	37.625	10.5	3.583	0.20	0.17	0.16	YNd11
2	36.750		3.500	0.05	0.08	0.08	
3	35.875		3.417	-0.05	-0.03	-0.01	
4	35.000		3.333	0.04	0.03	0.07	
5	34.125		3.250	0.06	0.07	0.05	
6	33.250		3.167	0.06	0.07	0.05	
7	32.375		3.083	0.05	0.06	0.04	

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 9 of 49

4.2 Measurement of winding resistance (Routine test)

Date: Sept 22, 2025

Liquid average temperature: 28.8℃; RH: 54%; Atmospheric pressure: 101.2kPa

Winding	Tapping	Winding resistance			Resistance unbalance rate(%)
		A to O	B to O	C to O	
High-voltage (mΩ)	1	68.01	67.99	68.06	0.10
	2	66.95	66.93	67.01	0.12
	3	65.88	65.86	65.93	0.11
	4	64.81	64.79	64.85	0.09
	5	63.68	63.66	63.72	0.09
	6	62.52	62.51	62.59	0.13
	7	61.35	61.35	61.43	0.13
Low-voltage (mΩ)	/	a to b	b to c	c to a	/
		7.421	7.419	7.415	0.08

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 10 of 49

4.3 Measurement of d.c. insulation resistance each winding to earth and between windings and absorption ratio measurements (Routine test) Date: Sept 22, 2025 Liquid average temperature: 28.8°C ; RH: 54%; Atmospheric pressure:101.2kPa			
Measurement position	R_{15} (GΩ)	R_{60} (GΩ)	R_{60} / R_{15}
High-voltage winding to low-voltage winding, core, frame and oil tank of transformer	21.6	34.2	1.58
Low -voltage winding to high -voltage winding, core, frame and oil tank of transformer	25.4	41.0	1.61
High-voltage winding and low-voltage winding to core, frame and oil tank of transformer	21.8	33.2	1.52
4.4 Check of core and frame insulation(Routine test) Liquid average temperature: 28.8°C ; RH: 54%; Atmospheric pressure:101.2kPa Date: Sept 22, 2025			
Measurement position	Measured (GΩ)	Corrected (20°C) (MΩ)	
Core - earth	15.8	22574	
Frame - earth	14.3	20431	
Core - Frame	15.4	22003	
4.5 Measurement of dissipation factor($\tan\delta$) of the insulation system capacitances (Routine test) Ambient temperature: 28.9°C ; RH: 53%; Atmospheric pressure:101.1kPa Date: Sept 22, 2025			
Measurement position	Earthed part	Dissipation factor(%)	
High- voltage	low- voltage,core, frame and oil tank	0.242	
Low- voltage	High- voltage, core, frame and oil tank	0.261	
High voltage,and low voltage	Core, frame and oil tank	0.262	
4.6 Determination of capacitances windings- to- earth and between windings (Routine test) Ambient temperature: 28.9°C ; RH: 53%; Atmospheric pressure:101.1kPa Date: Sept 22, 2025			
Measurement position	Earthed part	Capacitances(nF)	
High- voltage	low- voltage,core, frame and oil tank	5.912	
Low- voltage	High- voltage, core, frame and oil tank	7.935	
High-voltage,and low- voltage	Core, frame and oil tank	6.321	

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 11 of 49

4.7 Applied voltage test(AV) (Routine test)				Date: Sept 22, 2025		
Ambient temperature: 28.9°C; RH: 53%; Atmospheric pressure:101.1kPa						
Position		Test voltage (kV)	Time(s)	Test result		
High-voltage winding to low-voltage winding, tank and earth		85	60	Qualified		
Low-voltage winding to high-voltage winding, tank and earth		35	60			
4.8 Auxiliary wiring insulation test (Routine test)				Date: Sept 22, 2025		
Ambient temperature: 28.9°C; RH: 53%; Atmospheric pressure:101.1kPa						
Test position		Applied voltage value(kV)		Time(s)		
On-load tap-changers connection-earth		2.0		60		
4.9 Induced voltage withstand test (IVW) (Routine test)				Date: Sept 22, 2025		
Oil temperature: 29.0°C; RH: 53%; Atmospheric pressure:101.1kPa						
Tapping	Applied voltage (kV)	Induced AC voltage (kV)	Induction factor	Frequency (Hz)	Time(s)	Test result
	L.V.	H.V.				
4	21	70	2	200	30	Qualified
4.10 Measurement of no-load loss and current (Routine test)				Date: Sept 22, 2025		
Ambient temperature:29.0°C; RH: 52%; Atmospheric pressure:101.1kPa;Transformer temperature:29.0°C						
Test voltage(V)		No – load current		No – load loss(kW)		
Average voltage	RMS value of voltage	(A)	(%)	Measured	Corrected	
10515	10543	1.8132	0.10	11.0292	10.9998	
4.11 Measurement of no – load loss and current at 90% and 110% of rated voltage (Type test)				Date: Sept 22, 2025		
Ambient temperature:29.0°C; RH: 52%; Atmospheric pressure:101.0kPa;Transformer temperature:29.0°C						
Proportion of rated voltage	Test voltage(V)		No – load current		No – load loss(kW)	
	Average voltage	RMS value of voltage	(A)	(%)	Measured	Corrected
90%	9456.2	9481.2	1.2958	0.07	8.7024	8.6794
110%	11567	11599	2.4192	0.14	14.0388	14.0000

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

4.12 Measurement of short – circuit impedance and load loss (Routine test)								Date: Sept 22, 2025	
Liquid average temperature:29.0℃; RH: 52%; Atmospheric pressure:101.0kPa									
Test winding	Tapping	Applied current		Short – circuit impedance		Load loss(kW)	Total loss(kW)		
		(A)	I/Ir (%)	(%)	(Ω)	Correct	Correct		
				t=75℃ I=Ir		t=75℃ I=Ir	t=75℃ I=Ir		
HV – LV	1	400.26	82.8	10.20	4.59	100.7327	111.7325		
	4	442.65	85.2	10.06	3.91	102.1426	113.1424		
	7	492.74	87.7	9.92	3.30	109.6607	120.6605		
4.13 Insulating liquids test (Routine test, Type test ,Entrust test)								Date: Sept 21, 2025&Sept 25, 2025	
Ambient air temperature:28.2℃; RH: 49%; Atmospheric pressure: 100.9kPa									
Strike voltage(kV)					Dielectric loss factor(90℃)				
68.4					0.426%				
Ambient air temperature:28.2℃; RH: 49%; Atmospheric pressure: 101.0kPa									
Moisture content (mg/L)					13.6				
Ambient air temperature:28.2℃; RH: 49%; Atmospheric pressure: 101.0kPa									
Average Flash point (closed)(℃)					139.1				
Ambient air temperature: 28.2 to 28.3℃; RH:43 to 49%; Atmospheric pressure: 101.0 to 101.1kPa									
Gas chromatography analysis of dissolved gas	Components (μL/L)	H ₂	CO	CO ₂	CH ₄	C ₂ H ₄	C ₂ H ₆	C ₂ H ₂	Total hydrocarbons
	Before temperature-rise	14.58	2.45	204.24	4.42	0	0	0	4.42
	After temperature-rise	15.75	2.50	225.44	4.59	0	0	0	4.59

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

4.14 Test On-load tap-Changers-Operation test (Routine test) Date: Sept 22, 2025 Ambient air temperature:29.0℃; RH: 52%; Atmospheric pressure: 101.0kPa				
Test specifications				Test result
with the transformer un-energized, eight complete cycles of operation (a cycle of operation goes from one end of the tapping range to the other, and back again).				Qualified
with the transformer un-energized, and with the auxiliary voltage reduced to 85 % of its rated value, one complete cycle of operation.				
with the transformer energized at rated voltage and frequency at no load, one complete cycle of operation.				
with one winding short-circuited and, as far as practicable, rated current in the tapped winding, 10 tap-change operations across the range of two steps on each side from where a coarse or reversing changeover selector operates, or otherwise from the middle tapping(the tapchanger will pass 20 times through the changeover position)				
4.15 Leak testing with pressure for liquid-immersed transformers (Routine test) Date: Sept 19, 2025 to Sept 21, 2025 Ambient temperature: 28.1 to 28.8℃; RH: 45 to 50%; Atmospheric pressure: 100.6 to 100.9kPa				
Test position	Test method	Applied pressure(kPa)	Duration(h)	Result
Transformer	Inflatable pressure method	50	24	No leakage
On-load tap-Changers oil chamber	Inflatable pressure method	50	24	No leakage
/				

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

4.16 Vacuum deflection test and pressure deflection test on liquid immersed transformers (Special test)													
											Date: Sept 21, 2025		
Ambient temperature: 28.1℃; RH: 50%; Atmospheric pressure: 100.9kPa													
Testing items		Test method			Test pressure(kPa)			Duration(min)					
Vacuum deflection test on liquid immersed transformers		Pumping method			-50			5					
Pressure deflection test on liquid immersed transformers		Inflatable pressure method			45			5					
Measurement items		Test part											
		Box wall									Box lid		
		High- voltage			Low- voltage			L surface	R surface	Length direction middle position			
		L	M	R	L	M	R	M	M	L	M	R	
Vacuum degree	Elastic deformation (mm)	12.21	11.16	10.21	9.26	9.35	8.86	9.46	9.98	8.26	8.02	8.16	
	Permanent deformation (mm)	0.96	1.14	0.86	0.88	0.96	0.92	0.94	0.92	0.99	0.82	0.84	
Positive pressure	Elastic deformation (mm)	13.02	12.82	12.81	11.17	11.86	11.25	11.08	11.01	10.66	10.24	10.27	
	Permanent deformation (mm)	1.25	1.06	0.92	0.86	0.92	0.95	0.89	1.01	0.91	0.95	0.98	
/													

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 15 of 49

4.17 Measurement of zero-sequence impedance(s) on three-phase transformers (Special test)						
						Date: Sept 22, 2025
Ambient temperature: 29.0℃; RH: 52%; Atmospheric pressure: 101.0kPa						
Connection symbol	Power supply terminal	Open circuit terminal	Short circuit terminal	Applied current(A)	Measuring voltage(V)	Impedance (Ω/phase)
YNd11	ABC-O	abc	/	519.5	677.8	3.914
The test current per phase is I/3.						
4.18 Measurement of the harmonics of the no-load current (Entrust test)						
						Date: Sept 22, 2025
Ambient air temperature: 29.0℃; RH:52%; Atmospheric pressure: 101.0kPa						
Harmonic order	A (%)	B (%)	C (%)			
1	100.00	100.00	100.00			
2	6.35	7.11	6.72			
3	10.95	10.87	10.31			
4	4.98	5.63	5.12			
5	11.98	12.13	12.97			
6	4.06	4.85	4.73			
7	6.07	6.12	6.98			
8	3.14	3.85	3.37			
9	4.66	4.65	4.72			
10	3.28	4.10	3.16			
11	1.55	2.04	1.77			
12	0.96	1.43	1.28			
13	0.39	0.77	0.54			
14	0.26	0.45	0.29			
15	0.09	0.17	0.39			
16	0.08	0.11	0.07			
17	0.01	0.01	0.01			
18	0.00	0.00	0.00			
19	0.00	0.00	0.00			

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 16 of 49

4.19 Determination of sound levels (Type test)

Date: Sept 22, 2025

Ambient temperature: 29.0°C;RH: 52%;Atmospheric pressure: 101.0kPa

4.19.1 The load current sound power level:

Equation: $L_{WA,lr} \approx 39 + 18 \times \lg \frac{S_r}{S_p} = \underline{66} \text{ dB(A)}$

Where: $L_{WA,lr}$ — the A-weighted sound power level of the transformer at rated current, rated frequency and impedance voltage, dB(A).

S_r —the rated power in megavolt amperes, 31.5 MVA

S_p —the reference power ,1MVA.

Because the $L_{WA,lr}$ value is more than 10dB(A) lower than the guaranteed sound power level of 77 dB(A), no load current sound level measurement was conducted.

4.19.2 The sound power level measurements

The L.V. Winding test voltage:10500V; Frequency:50.00Hz; Tapping:4;

Measuring point:24; Measuring point height:1.200m; Distance of measuring point:1.000m.

Environmental conditions

The total area of the surface of the test room- S_{Vi} (m ²)		The average acoustic absorption coefficient- α_i		The sound absorption area of the test room -A (m ²)	Distance to the principal radiating surface(m)	The area of the measurement surface-S (m ²)	Environmental correction-K(dB)
Hard ground	Ceiling and walls	Hard ground	Ceiling and walls				
285	1277.8	0.1	0.3	411.84	1.0	81.6	2.53

Result dB(A)

Type of cooling	$\overline{L_{pA0}} = 10 \times \lg \left(\frac{1}{N} \sum_{i=1}^N 10^{0.1L_{pAi}} \right)$	$\overline{L_{pA}} = 10 \times \lg \left(10^{0.1\overline{L_{pA0}}} - 10^{0.1\overline{L_{bgA}}} \right) - K$	$L_{WA} = \overline{L_{pA}} + 10 \times \lg \frac{S}{S_0}$
ONAN	58.2	55.7	74.8

Note: The initial average background noise pressure levels:28.7dB(A),

The final average background noise pressure levels:28.7dB(A).

$\overline{L_{bgA}}$: The lower of the two total spatially average A-weighted background noise levels.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 17 of 49

4.20 Temperature- rise test (Type test) Date: Sept 24, 2025 to Sept 25, 2025
 Ambient air temperature: 29.9 to 30.9°C
 Test by short – circuit method, tapping 7. Test time : 10h, Settling time, 4h. Rated total loss : 120.6605kW, Applied total loss: 120.6910kW, Rated current : 561.7A, Applied current : 562.2A.

Measurement data

Measurement of average winding temperature			The average liquid temperature(°C)			Ambient temperature(°C)	Top liquid temperature at total loss(°C)
Winding	Cold resistance (×10 ⁻³ Ω)	The average winding temperature (°C)	During cold resistance	Total loss end	Rated current end	Total loss end	
H. V. (BC)	116.39	83.81	28.8	71.0	70.7	30.0	81.1
L. V. (bc)	7.419	86.92					

Temperature rise calculation results

Top liquid temperature rise(K)	51.1
Winding temperature rise(K)	High-voltage 54.11
	Low - voltage 57.22
Surface of oil tank and structural parts temperature rise(K)	59.6

Note: The temperature rise calculation result is the corrected value under the specified total loss and current.

4.21 Winding hot-spot temperature-rise (calculation) (Entrust test) Date: Sept 25, 2025

Hot-spot winding temperature-rise	High-voltage (K)	68.14
	Low-voltage (K)	72.19


Note: The hot- spot factor H is taken according to GB/ T 1094.7-2008: 1.3.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Average temperature curve of high – voltage winding : F1




Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Average temperature curve of low – voltage winding : F2



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

4.22 Short-circuit withstand test (Special test)

Date: Sept 25, 2025

Ambient temperature:28.2℃ ;RH:43%;Atmospheric pressure:101.1kPa

4.22.1 Calculation of short circuit current (Reference temperature 75℃)

Tapping	The peak value of the current(kA)	Value of symmetrical short-circuit current (kA)	Values for factor($K\sqrt{2}$)
1	10.254 (tolerance $^{+5}_{-5}$ %)	4.021 (tolerance $^{+10}_{-10}$ %)	2.55
4	10.894 (tolerance $^{+5}_{-5}$ %)	4.272 (tolerance $^{+10}_{-10}$ %)	2.55
7	11.574 (tolerance $^{+5}_{-5}$ %)	4.539 (tolerance $^{+10}_{-10}$ %)	2.55

4.22.2 Applied current

Using a three-phase current test with a short circuit on the low-voltage side, the supply voltage is applied to the outer winding (high-voltage side)

Tapping	Phase	Sequence	Measurement of current					Oscillogram No.
			The peak value of the current		Value of symmetrical short-circuit current		Duration (ms)	
			(kA)	(%)	(kA)	(%)		
1	A	1	10.408	101.50	4.052	100.77	255	B1
		2	10.359	101.02	4.056	100.87	256	B2
		3	10.348	100.92	4.061	100.99	256	B3
		Sequence	Reactance					
			Reactance(Ω)			Tolerance(%)		
			A	B	C	A	B	C
		Before the test	4.5822	4.5522	4.5732	/	/	/
		1	4.5915	4.5558	4.5755	0.18	0.08	0.05
		2	4.5997	4.5635	4.5796	0.36	0.25	0.14
		3	4.6048	4.5699	4.5841	0.47	0.39	0.24

The biggest reactance difference:0.47%.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

4.22.2 Applied current(continued)

Tapping	Phase	Sequence	Measurement of current						
			The peak value of the current		Value of symmetrical short-circuit current		Duration (ms)	Oscillogram No.	
			(kA)	(%)	(kA)	(%)			
4	B	1	10.952	100.53	4.362	102.11	253	B4	
		2	10.984	100.83	4.329	101.33	253	B5	
		3	10.977	100.76	4.323	101.19	252	B6	
		Sequence	Reactance						
			Reactance(Ω)			Tolerance(%)			
			A	B	C	A	B	C	
		Before the test	3.9110	3.8790	3.9051	/	/	/	
		1	3.9330	3.8971	3.9202	0.56	0.47	0.39	
		2	3.9381	3.9012	3.9227	0.69	0.57	0.45	
		3	3.9423	3.9043	3.9269	0.80	0.65	0.56	

The biggest reactance difference:0.80%.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

4.22.2 Applied current(continued)

Tapping	Phase	Sequence	Measurement of current					
			The peak value of the current		Value of symmetrical short-circuit current		Duration (ms)	Oscillogram No.
			(kA)	(%)	(kA)	(%)		
7	C	1	11.675	100.87	4.594	101.21	256	B7
		2	11.719	101.25	4.599	101.32	256	B8
		3	11.723	101.29	4.603	101.41	256	B9
		Sequence	Reactance					
			Reactance(Ω)			Tolerance(%)		
			A	B	C	A	B	C
		Before the test	3.2995	3.2632	3.2927	/	/	/
		1	3.3315	3.2916	3.3152	0.97	0.87	0.68
		2	3.3337	3.2958	3.3180	1.04	1.00	0.77
		3	3.3381	3.2989	3.3212	1.17	1.09	0.87


The biggest reactance difference:1.17%.

No abnormality in test waveform.The biggest reactance difference is 1.17%.After Short circuit test, reveal no defects such as displacements ,deformation of windings ,connections or supporting structures. No traces of internal electrical discharge were found.

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

The out-of-tank inspection before Short-circuit withstand test(HV)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

The out-of-tank inspection after Short-circuit withstand test(HV)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

The out-of-tank inspection before Short-circuit withstand test(LV)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 35 of 49

The out-of-tank inspection after Short-circuit withstand test(LV)



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 36 of 49

4.22.3 Inspection after Short-circuit test

4.22.3.1 Measurement of voltage ratio and check of phase displacement (Routine test)

Date: Sept 26, 2025

Ambient air temperature: 28.8℃; RH: 45%; Atmospheric pressure: 100.8kPa

H. V. winding		L. V. winding	Voltage ratio	Voltage ratio deviation (%)			Connection symbol
Tapping	Voltage (kV)	Voltage (kV)		AB/ab	BC/bc	CA/ca	
1	37.625	10.5	3.583	0.21	0.18	0.17	YNd11
2	36.750		3.500	0.08	0.09	0.09	
3	35.875		3.417	-0.04	-0.03	0.00	
4	35.000		3.333	0.05	0.04	0.07	
5	34.125		3.250	0.07	0.08	0.06	
6	33.250		3.167	0.07	0.08	0.05	
7	32.375		3.083	0.08	0.06	0.05	

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

4.22.3.2 Measurement of winding resistance (Routine test)

Date: Sept 26, 2025

Liquid average temperature: 28.8°C; RH: 45%; Atmospheric pressure:100.8kPa

Winding	Tapping	Winding resistance			Resistance unbalance rate(%)
		A to O	B to O	C to O	
High-voltage (mΩ)	1	68.04	68.02	68.08	0.09
	2	66.97	66.96	67.03	0.10
	3	65.90	65.88	65.96	0.12
	4	64.84	64.81	64.88	0.11
	5	63.71	63.69	63.74	0.08
	6	62.54	62.52	62.60	0.13
	7	61.36	61.38	61.45	0.15
Low-voltage (mΩ)	/	a to b	b to c	c to a	/
		7.446	7.451	7.449	0.07

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 38 of 49

<p>4.22.3.3 Measurement of d.c. insulation resistance each winding to earth and between windings and absorption ratio measurements (Routine test)</p> <p>Liquid average temperature: 28.9°C; RH: 45%; Atmospheric pressure: 100.8kPa Date: Sept 26, 2025</p>			
Measurement position	R ₁₅ (GΩ)	R ₆₀ (GΩ)	R ₆₀ /R ₁₅
High-voltage winding to low-voltage winding, core, frame and oil tank of transformer	20.1	30.1	1.50
Low -voltage winding to high -voltage winding, core, frame and oil tank of transformer	23.2	36.4	1.57
High-voltage winding and low-voltage winding to core, frame and oil tank of transformer	20.5	29.8	1.45
<p>4.22.3.4 Check of core and frame insulation(Routine test) Date: Sept 26, 2025</p> <p>Liquid average temperature: 28.9°C; RH: 45%; Atmospheric pressure: 100.8kPa</p>			
Measurement position	Measured value R ₆₀ (GΩ)	Calibration to 20°C insulation resistance(MΩ)	
Core – earth	14.6	20945	
Frame – earth	13.2	18936	
Core – frame	14.2	20371	
<p>4.22.3.5 Measurement of dissipation factor(tanδ) of the insulation system capacitances and determination of capacitances windings-to-earth and between windings (Routine test)</p> <p style="text-align: right;">Date: Sept 26, 2025</p> <p>Ambient air temperature: 28.9°C; RH: 45%; Atmospheric pressure: 100.8kPa</p>			
Measurement position	Earthed part	Dissipation factor(%)	Capacitance (nF)
High- voltage	Low- voltage, core, frame and oil tank	0.282	6.016
Low- voltage	High - voltage, core, frame and oil tank	0.351	8.027
High-voltage and Low-voltage	Core, frame and oil tank	0.285	6.509

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

4.22.3.6 Applied voltage test (Routine test) Date: Sept 26, 2025 Oil temperature: 28.9°C; RH: 45%; Atmospheric pressure: 100.8kPa						
Position	Test voltage(kV)	Time(s)	Test result			
High-voltage winding to low-voltage winding, oil tank and earth	85	60	Qualified			
Low-voltage winding to high-voltage winding, oil tank and earth	35	60				
4.22.3.7 Auxiliary wiring insulation test (Routine test) Date: Sept 26, 2025 Oil temperature: 28.9°C; RH: 45%; Atmospheric pressure: 100.8kPa						
Test positon	Applied voltage value(kV)		Time(s)			
On- load tap- changers connection - earth	2.0		60			
4.22.3.8 Induced voltage withstand test (Routine test) Date: Sept 26, 2025 Oil temperature: 29.0°C; RH: 46%; Atmospheric pressure: 100.8kPa						
Tapping	Applied voltage(kV)	Induced voltage(kV)	Induction factor	Frequency (Hz)	Time(s)	Test result
	L. V.	H. V.				
4	21	70	2	200	30	Qualified
4.22.3.9 Measurement of no – load loss and current (Routine test) Date: Sept 26, 2025 Ambient air temperature: 29.0°C; RH: 46%; Atmospheric pressure: 100.8kPa; Transformer temperature: 29.0°C						
Test voltage(V)		No – load current		No – load loss(kW)		
Average voltage	RMS value of voltage	(A)	(%)	Measured	Corrected	
10517	10539	1.8332	0.11	11.1265	11.1032	

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 40 of 49

4.22.3.10 Measurement of short – circuit impedance and load loss (Routine test)						Date: Sept 26, 2025	
Liquid average temperature: 29.0℃; RH: 46%; Atmospheric pressure: 100.8kPa							
Test winding	Tapping	Applied current		Short – circuit impedance		Load loss(kW)	Total loss(kW)
		(A)	I/Ir (%)	(%)	(Ω)	Correct	Correct
				t=75℃ I=Ir		t=75℃ I=Ir	t=75℃ I=Ir
H. V. – L. V.	1	403.65	83.5	10.21	4.59	101.1032	112.2064
	4	445.72	85.8	10.06	3.91	102.5219	113.6251
	7	493.76	87.9	9.93	3.30	110.0215	121.1247
4.24.3.11 Insulation liquid test (Routine test)						Date: Sept 26, 2025	
Ambient air temperature: 29.0℃; RH: 46%; Atmospheric pressure: 100.8kPa							
Strike voltage(kV)				Dielectric loss factor(90℃)			
63.9				0.442%			
4.24.3.12 Test on on-load tap-changers-Operation test (Routine test)						Date: Sept 26, 2025	
Ambient air temperature: 29.0℃; RH: 46%; Atmospheric pressure: 100.8kPa							
Test content						Test results	
With the transformer de-energized, eight complete cycles of operation(a cycle of operation goes from one end of the tapping range to the other, and back again)						Qualified	
With the transformer de-energized, and with the auxiliary voltages reduced to 85% of its rated value, one complete cycle of operation							
With the transformer energized at rated voltages and frequency at no load, one complete cycle of operation							
With one winding short-circuited and, as far as practicable, rated current in the tapped winding, 10 cycles of tap-change operations across the range of two steps on each side from where a coarse or reversing changeover selector operates, or otherwise from the middle tapping(the tapchanger will pass 20 times through the changeover position)							

Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Page 41 of 49

4.23 Lightning impulse test(Type test)		Date: Sept 26, 2025	
Ambient air temperature: 29.2℃; RH: 47%; Atmospheric pressure: 100.9kPa			
Withstand terminals	a, b, c	A, B, C	O
Tapping	/	A1, B4,C7	1
Test polarity	Negative	Negative	Negative
Peak voltage(kV)	75 (tolerance $_{-3}^{+3}$ %)	200 (tolerance $_{-3}^{+3}$ %)	200 (tolerance $_{-3}^{+3}$ %)
Chopped voltage(kV)	85 (tolerance $_{-3}^{+3}$ %)	220 (tolerance $_{-3}^{+3}$ %)	/
Wave front time $T_1(\mu\text{s})$	1.2 (tolerance $_{-30}^{+30}$ %)		1.2 (tolerance $_{-30}^{+30}$ %)
Half-wave peak time $T_2(\mu\text{s})$	50 (tolerance $_{-20}^{+20}$ %)		50 (tolerance $_{-20}^{+20}$ %)
Chopped time $T_C(\mu\text{s})$	3~6		/
Chopped impulse of reverse polarity peak K	$\leq 30\%$ Chopped impulse peak		/
Test sequence	<p>One time full-wave reference impulse of 50%~70% of full voltage</p> <p>One time full-wave impulse of 100% full voltage</p> <p>Two times chopped wave impulse of lightning impulse test voltage</p> <p>Two times full-wave impulse of 100% full voltage</p>	<p>One time full- wave reference impulse of 50%~ 70% full voltage</p> <p>Three times full- wave impulse of 100% full voltage</p>	



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)

Lightning impulse Test terminal: a Test polarity: Negative


50%~70% Full wave




First 100% Full wave





First chopped wave





Second chopped wave



Second 100% Full wave



Third 100% Full wave




Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)

Lightning impulse Test terminal: b Test polarity: Negative

50%~70% Full wave




Up = -41.7 kV
 T1 = 1.35 us
 T2 = 51.43 us
 CHI




I_{max} = 91.37 A
 I_{min} = -350.75 A
 CH2

First 100% Full wave




Up = -76.1 kV
 T1 = 1.33 us
 T2 = 52.01 us
 CHI




I_{max} = 95.215 A
 I_{min} = -403.051 A
 CH2

First chopped wave



Up = -83.8 kV Oz = 8.1 %
 T1 = 1.36 us
 Tc = 4.65 us
 CHI




I_{max} = 1.2 kA
 I_{min} = -794.981 A
 CH2

Second chopped wave




Up = -85.7 kV Oz = 7.6 %
 T1 = 1.36 us
 Tc = 4.09 us
 CHI




I_{max} = 1.2 kA
 I_{min} = -788.891 A
 CH2

Second 100% Full wave




Up = -75.7 kV
 T1 = 1.33 us
 T2 = 52.14 us
 CHI




I_{max} = 92.285 A
 I_{min} = -408.419 A
 CH2

Third 100% Full wave



Up = -75.6 kV
 T1 = 1.33 us
 T2 = 52.12 us
 CHI



I_{max} = 86.426 A
 I_{min} = -416.099 A
 CH2


Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)

Lightning impulse Test terminal: c Test polarity: Negative

50%~70% Full wave




CHI




CH2

First 100% Full wave



CHI




CH2

First chopped wave




CHI




CH2

Second chopped wave




CHI




CH2

Second 100% Full wave




CHI




CH2

Third 100% Full wave



CHI



CH2



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)



Test Report (Continuation page)

Lightning impulse Test terminal: A Test polarity: Negative


50%~70% Full wave




First 100% Full wave





First chopped wave




Second chopped wave



Second 100% Full wave



Third 100% Full wave




Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)


Test Report (Continuation page)

Lightning impulse Test terminal: B Test polarity: Negative

50%~70% Full wave




Up = -107.4 kV
T1 = 1.12 us
T2 = 45.84 us
CHI




I_{max} = 18.511 A
I_{min} = -452.681 A
CHI2

First 100% Full wave



Up = -199.6 kV
T1 = 1.13 us
T2 = 45.66 us
CHI




I_{max} = 27.832 A
I_{min} = -815.918 A
CHI2

First chopped wave



Up = -221.1 kV Oz = 2.8 %
T1 = 1.14 us
Tc = 4.05 us
CHI




I_{max} = 918.455 A
I_{min} = -909.664 A
CHI2

Second chopped wave




Up = -220.8 kV Oz = 2.8 %
T1 = 1.13 us
Tc = 4.04 us
CHI




I_{max} = 892.09 A
I_{min} = -909.684 A
CHI2

Second 100% Full wave




Up = -202.0 kV
T1 = 1.12 us
T2 = 45.75 us
CHI




I_{max} = 27.832 A
I_{min} = -830.598 A
CHI2

Third 100% Full wave



Up = -199.4 kV
T1 = 1.12 us
T2 = 45.97 us
CHI



I_{max} = 24.902 A
I_{min} = -837.636 A
CHI2



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)



Test Report (Continuation page)

Lightning impulse Test terminal: C Test polarity: Negative



50%~70% Full wave





First 100% Full wave





First chopped wave





Second chopped wave



Second 100% Full wave



Third 100% Full wave





Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)



Test Report (Continuation page)

Lightning impulse Test terminal:O Test polarity: Negative



50%~70% Full wave





First 100% Full wave



Second 100% Full wave



Third 100% Full wave



Shandong Institute for Product Quality Inspection

National Inspection and Testing Center for Power Transmission and Distribution Equipment(Shandong)

Test Report (Continuation page)

Sample and nameplate photos



电力变压器 Power transformer																						
<table border="1"> <thead> <tr> <th colspan="2">高压侧 High-voltage winding</th> </tr> <tr> <th>电压 (V) Voltage</th> <th>电流 (A) Current</th> </tr> </thead> <tbody> <tr><td>1</td><td>37625</td></tr> <tr><td>2</td><td>36750</td></tr> <tr><td>3</td><td>35875</td></tr> <tr><td>4</td><td>35000</td></tr> <tr><td>5</td><td>34125</td></tr> <tr><td>6</td><td>33250</td></tr> <tr><td>7</td><td>32375</td></tr> </tbody> </table>		高压侧 High-voltage winding		电压 (V) Voltage	电流 (A) Current	1	37625	2	36750	3	35875	4	35000	5	34125	6	33250	7	32375	型号 Product model: SZ22-31500/35-NX1 标准 Product standard: GB/T1094.1-2013 IEC 60076-1:2011		
高压侧 High-voltage winding																						
电压 (V) Voltage	电流 (A) Current																					
1	37625																					
2	36750																					
3	35875																					
4	35000																					
5	34125																					
6	33250																					
7	32375																					
<table border="1"> <thead> <tr> <th colspan="2">低压侧 Low-voltage winding</th> </tr> <tr> <th>电压 (V) Voltage</th> <th>电流 (A) Current</th> </tr> </thead> <tbody> <tr><td>10500</td><td>1732.1</td></tr> </tbody> </table>		低压侧 Low-voltage winding		电压 (V) Voltage	电流 (A) Current	10500	1732.1	出厂序号 Serial number: ZX2508161 出厂时间 Date of manufacture: 2025-08 额定频率 Rated frequency: 50Hz 相数 Phase: 3 相 额定容量 Rated capacity: 31500kVA 额定电压 Rated voltage: (35±3×2.5%) /10.5kV 联结组标号 Connection symbol: YNd11 冷却方式 Type of cooling: ONAN 使用条件 Service: 户外式 Outdoor 绝缘耐热等级 Thermal class: A 级 A-level 绝缘条件 Insulation level:HV Um/LI/LIC/AC 40.5/200/220/85kV LV Um/LI/LIC/AC 12/75/85/35kV														
低压侧 Low-voltage winding																						
电压 (V) Voltage	电流 (A) Current																					
10500	1732.1																					
空载损耗 No load loss	11.214kW	短路阻抗 Short-circuit impedance	最大分接 Maximum tapping	10.17%																		
空载电流 No load current	0.11%		额定分接 Rated tapping	10.06%																		
负载损耗 Load loss	98.68kW		最小分接 Minimum tapping	10.01%																		
器身重 Body weight	25929kg	油重 Oil	11457kg	总重 Total mass	52187kg																	
四川众信通用电能股份有限公司 Sichuan Zhongxin General Electric Energy Co.,Ltd.																						

山东省产品质量检验研究院

山东省产品质量检验研究院（简称山东省质检院，英文缩写SDQI）成立于1980年2月，隶属于山东省市场监督管理局，是集检测、科研、标准制定、技术服务于一体的第三方综合性检验机构。我院已获得国家级检验检测机构“一家一证”资质认定、山东省市场监督管理局检验检测机构资质认定，是中国合格评定国家认可委员会（CNAS）认可的检测实验室。

检验检测领域：

食品及食品添加剂、农产品、饲料、食品相关产品、化妆品、微生物、基因扩增、包装产品、快递用品、降解、轻工、装饰装修、建筑材料、机械产品、太阳能热水器、节能产品、输配电产品、家用电器、电磁兼容、消防及阻燃、玩具、文具、纤维纺织、石油化工、日用化工、肥料、农药、土壤、危险化学品、水处理剂、体育用品、环境监测等众多行业或领域。

认证检验业务：

IECEE CB认证、澳洲SAI认证、巴西INMETRO认证、TÜV Rheinland认证、CE认证、海湾国家GC认证、欧盟SOLAR KEYMARK认证、CCC强制性认证检验、CQC自愿性认证检验、消防产品合格评定中心自愿性认证检验、资源节约及环保认证检验、绿色产品认证检验，能效标识能源效率检验、水效标识检验等。

八个国家质检中心：

- 国家包装产品质量检验检测中心（济南）
- 国家加工食品质量检验检测中心（山东）
- 国家装饰装修材料质量检验检测中心
- 国家节能产品质量检验检测中心
- 国家输配电设备质量检验检测中心（山东）
- 国家消防及阻燃产品质量检验检测中心（山东）
- 国家石油化工产品质量检验检测中心（山东）
- 国家体育用品质量检验检测中心（山东）

具有以下授权资质：

第一批国家级标准验证检验检测点试点单位、全国土壤污染状况详查实验室、全国塑料软包装工业产品质量控制与评价实验室、山东产品质量司法鉴定中心、山东省产品质量安全风险监测中心、山东省新旧动能转换行业公共实训基地、新能源汽车电池及充电设施综合性能检测山东省工程研究中心、智能输配电设备综合性能山东省工程研究中心、山东省碳排放第三方核查机构、山东省材料化学安全检测技术重点实验室等。